

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		No				
FX 010		No				
FX 011		No				
FX 012		No				
FX 013	Kitchen Pot Filler	Yes	0.036	Must be immediately removed from service		
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025	Fountain A Wing Hall	Yes	0.001			No Action Required
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031		No				
FX 032		No				

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 033		No				
FX 034		No				
FX 035	Rm B1 Sink	Yes	0.0009			No Action Required
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051	Bottle Filler B Hall	Yes	0.0009			No Action Required
FX 052		No				
FX 053		No				
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069	Fountain West Gym	Yes	0.001			No Action Required
FX 070		No				
FX 071		No				
FX 072	Bottle Filler East Gym	Yes	0.0009			No Action Required
FX 073		No				
FX 074		No				
FX 075	Fountain Girls Locker	Yes	0.019	Must be immediately removed from service		
FX 076		No				
FX 077		No				
FX 078		No				
FX 079		No				
FX 080		No				
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				
FX 085		No				
FX 086		No				
FX 087		No				
FX 088		No				
FX 089		No				
FX 090		No				
FX 091		No				
FX 092		No				
FX 093		No				
FX 094		No				
FX 095		No				
FX 096	Bottle Filler Gym Hall	Yes	0.0009			No Action Required

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 097	Fountain Gym Hall W	Yes	0.006		Must be fixed, replaced or removed	
FX 098		No				
FX 099		No				
FX 100		No				
FX 101		No				
FX 102		No				
FX 103		No				
FX 104		No				
FX 105		No				
FX 106		No				
FX 107	Bottle Filler Main Hall	Yes	0.0009			No Action Required
FX 108		No				
FX 109		No				
FX 110	Library Work Rm Sink	Yes	0.001			No Action Required
FX 111		No				
FX 112		No				
FX 113		No				
FX 114		No				
FX 115		No				
FX 116		No				
FX 117		No				
FX 118		No				
FX 119		No				
FX 120	Fountain D Wing Hall	Yes	0.002			No Action Required
FX 121		No				
FX 122		No				
FX 123	RM G7 Sink	Yes	0.034	Must be immediately removed from service		
FX 124		No				
FX 125		No				
FX 126		No				
FX 127		No				

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 128		No				
FX 129	Rm G11 Sink	Yes	0.012		Must be fixed, replaced or removed	
FX 130		No				
FX 131	Rm G10 Sink	Yes	0.028	Must be immediately removed from service		
FX 132		No				
FX 133		No				
FX 134		No				
FX 135		No				
FX 136		No				
FX 137		No				
FX 138		No				
FX 139		No				
FX 140		No				
FX 141	Fountain G Wing	Yes	0.0009			No Action Required
FX 142		No				
FX 143		No				
FX 144	Bottle Filler G Wing	Yes	0.0009			No Action Required
FX 145		No				
FX 146		No				
FX 147		No				
FX 148		No				
FX 149		No				
FX 150		No				
FX 151		No				
FX 152		No				
FX 153	Rm H11 Sink	Yes	0.021	Must be immediately removed from service		
FX 154		No				
FX 155		No				
FX 156		No				
FX 157		No				
FX 158		No				

Lead Sample Test Results and Actions

EAST MIDDLE SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 159		No				
FX 160		No				
FX 161		No				
FX 162		No				
FX 163		No				
FX 164		No				
FX 165		No				
FX 166		No				
FX 167		No				
FX 168	Fountain H Wing Hall	Yes	0.008		Must be fixed, replaced or removed	
FX 169		No				
FX 170		No				
FX 171	Bottle Filler H Wing H	Yes	0.0009			No Action Required