



Addendum 2

Project: **RFP NUMBER 2425-13 – TROY SCHOOL DISTRICT OPERABLE WALL REPLACEMENT & INSTALLATION – (HAMILTON & WASS ELEMENTARY AND TROY HIGH SCHOOLS)**

Bid Due date: 2:00 PM Local Time, Wednesday, February 26, 2025 (UNCHANGED)

This Addendum is issued as modifications to the RFP previously issued to provide clarifications to the scope of work. This Addendum supersedes the original RFP. This along with the RFP becomes the bid documents.

I. General Information

1. For questions e-mail lecoleplanners3@gmail.com or through Buildingconnected.com.
2. Any bidder requesting to visit the site should contact Mark Paulus at lecoleplanners3@gmail.com or (248) 880-6791 to schedule a time. No bidder shall visit the building without scheduling it with Mark Paulus.
3. Bid Package. Page 6. Article 2.5. Delete all work at Troy High School.
4. Bid Package. Page 12. Proposal Pricing Form Article A Contractor Pricing. Delete Troy High School Amount. This work has been deleted from this bid package.

II. Questions and Answers

- 1Q. If the existing track is not compatible with the new panels, should the track be replaced?
 - 1A. Yes, the track shall be replaced, and this cost shall be included in your base bid.

END