

Districtwide Lead in Drinking Water Sampling and Remediation Plan

2023-2025

Kingston City School District

The Kingston City School District has developed their 2023-2025 Lead in Drinking Water Sampling and Remediation Plan, as required by the New York State Department of Health.

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion (ppb), to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Kingston City School District buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations
- 2) Kitchen water faucets and pot fillers used in food preparation
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the District and analyzed by a New York State Department of Health ELAP certified laboratory. For results at or below 5 ppb, no further action is required. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location.

The following locations within the Kingston City School District buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)

In these cases, the Kingston City School District staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption.

All faucets that were identified above the action level are labeled with signage indicating that the water is to be used for hand washing and cleaning only and not to be used for drinking. Lead is not absorbed through skin contact, so these locations are safe for hand washing. The district will investigate and remediate these outlets. Once the remediation is complete, they will be resampled against the same action level.

The results of the initial sampling and the remediation action is documented in the tables below for each building.

Test results for each school will be uploaded to the school district website. If you have any questions or concerns regarding this notification, please contact Mr. Dylan Bogart, Director of Facilities at 845-943-3170.



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

Chambers Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202419-1	01 Sink Custodial Bathroom	5.2			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-8	06 Room 7 Sink 1	5.8			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-14	09 Room 5 Sink 2	6.3			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-24	15 Principal Bathroom Sink 1	6.3			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-29	20 Room 10 Sink	21.4			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-31	21 Room 11 Sink 2	5.1			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-33	22 Room 12 Bath Sink 2	5.9			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-34	23 Room 13 Sink 1	5.5			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-37	24 Room 14 Sink 2	6.2			"Do Not Drink" or equivalent sign installed
5/30/2024	05202419-47	38 C-4 Sink 1	9.7			"Do Not Drink" or equivalent sign installed

Edward R. Crosby Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202416-1	74 Girls Sink	5.1			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-3	75 Room 16 Sink	8.6			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-4	76 Room 15 Sink	7.8			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-5	77 Room 17 Sink	14.0			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students. All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

Edward R. Crosby Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202416-6	78 Art Sink	7.0			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-7	79 Bath Sink Portable	8.7			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-8	80 Bath Sink 1 Portable	20.0			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-9	79 Sink 2 Portable	92.1			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-10	80 Bath Sink 2 Portable	38.0			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-11	81 Bath L Sink 1 Portable	10.5			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-12	81 Bath R Sink 2 Portable	26.1			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-13	82 Nurse Sink	6.9			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/30/2024	05202416-14	83 Faculty BK sink	11.4			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-18	87 Room 8 Sink	7.8			"Do Not Drink" or equivalent sign installed
5/30/2024	05202416-19	88 Room 7 Sink	11.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202416-21	90 Room 9 Sink	8.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202416-24	93 Room 1 Sink	5.5			"Do Not Drink" or equivalent sign installed
5/29/2024	05202416-26	95 Kitchen Hand Sink	5.5			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/29/2024	05202416-27	96 Kitchen Dish Sink left	7.2			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/29/2024	05202416-28	97 Kitchen Dish Sink Right	12.4			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

Harry L. Edson Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/29/2024	05202420-3	213 B-28 Sink	8.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-8	218 B-17 Sink	6.8			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-11	221 B-11 Sink	76.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-12	222 A-4 Sink	12.8			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-15	225 A2A Sink	8.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-16	226 C-6 Sink	8.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-17	227 C-15 Sink	8.5			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-18	228 C-18 Sink	43.9			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-19	229 C-14 Sink	11.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-21	231 C-9 Sink	5.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-25	235 B-4 Sink	9.5			"Do Not Drink" or equivalent sign installed
5/29/2024	05202420-26	236 B-21 Sink	14.0			"Do Not Drink" or equivalent sign installed

J. Watson Bailey Middle School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/29/2024	05202418-7	246 301 Sink	11.9			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-9	248 300 Sink	5.6			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-10	249 200 1st Sink	6.5			"Do Not Drink" or equivalent sign installed / New Faucet



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

J. Watson Bailey Middle School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/29/2024	05202418-11	250 200 2nd Sink	7.2			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202418-12	251 200 3rd Sink	8.9			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202418-18	257 202B 3rd Sink	11.6			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202418-19	258 203 1st Sink from Door	6.5			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202418-21	260 203 3rds Sink From Door	727.0			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202418-23	262 Boys Locker Room Sink Left	8.1			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-24	263 Boys Locker Room Sink Right	112.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-27	266 Girls Office Sink	5.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-34	273 Girls Fac Sink	7.6			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-46	283 Principal's Bath Sink	5.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-47	284 Main Office Sink	11.8			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-56	293 Room 1 Sink	13.1			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-57	294 Room 114 Front Sink	6.2			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-59	296 Room 113 Front Sink	6.4			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-60	297 Room 113 Back Sink	220.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-66	303 Room 107 Sink	7.2			"Do Not Drink" or equivalent sign installed
5/29/2024	05202418-68	305 Room 102 Sink	22.6			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

Meagher – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202415-1	98 Kitchen Sink 1	61.9			"Do Not Drink" or equivalent sign installed
5/30/2024	05202415-3	98 Kitchen Bath Sink	10.8			"Do Not Drink" or equivalent sign installed
5/30/2024	05202415-9	102 YMCA Area Front Sink 2	7.3			"Do Not Drink" or equivalent sign installed
5/30/2024	05202415-10	103 Faculty Sink	8.7			"Do Not Drink" or equivalent sign installed

M. Clifford Miller Middle School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/29/2024	05202417-1	51 Room 172 Sink	33.6			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-2	52 Girls Coach Bathroom Sink	12.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-3	53 Sink 1 Kitchen	10.7			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/29/2024	05202417-4	54 Sink 2 Kitchen	6.7			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/29/2024	05202417-5	55 Sink 3 Kitchen	6.2			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/29/2024	05202417-7	57 Room 145 & 147 Middle Sink	11.9			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-9	58 Room 121 Sink 2	5.7			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

M. Clifford Miller Middle School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/29/2024	05202417-10	59 Room 122 Sink 1	11.1			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-11	59 Room 122 Sink 2	7.4			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-12	60 Room 123A Sink 1	48.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-14	62 Sink Main Office	36.8			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-15	64 Principal Bathroom	33.3			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-16	63 Room 115 Sink 1	9.4			"Do Not Drink" or equivalent sign installed / New Faucet
5/29/2024	05202417-20	65 Room 113 Sink 1	70.0			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-23	65 Room 113 Sink 4	8.9			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-24	66 Room 111 Sink 1	11.5			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-25	67 Library Upstairs Sink	10.6			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-26	68 Room 216A Sink	34.1			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-27	69 Room 217 Sink 1	16.2			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-28	70 Faculty Lounge Sink	11.9			"Do Not Drink" or equivalent sign installed
5/29/2024	05202417-30	72 Room 241 Sink 1	14.4			"Do Not Drink" or equivalent sign installed

Ernest C. Myer Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202414-1	200 Room 23 Sink	9.1			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

Ernest C. Myer Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
5/30/2024	05202414-4	203 Back Kitchen Sink	21.5			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/30/2024	05202414-5	204 Front Kitchen Sink	5.5			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
5/30/2024	05202414-8	207 Room 1 Sink	5.3			"Do Not Drink" or equivalent sign installed

Robert Graves Elementary – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
10/29/2024	10232414-1	453 Faucet Kitchen Right	7.4			"Do Not Drink" or equivalent sign installed
10/29/2024	10232414-9	456 Room 21 Faucet	9.8			"Do Not Drink" or equivalent sign installed
10/29/2024	10232414-16	468 Room 8 Faucet	13.9			"Do Not Drink" or equivalent sign installed
10/29/2024	10232414-19	465 Room 14 Faucet	7.5			"Do Not Drink" or equivalent sign installed
10/29/2024	10232414-22	473 Principal's Bath Faucet	48.6			"Do Not Drink" or equivalent sign installed
10/30/2024	10232414-26	474 Portable Faucet Left	160.0			"Do Not Drink" or equivalent sign installed
10/30/2024	10232414-27	473 Portable Faucet Center	269.0			"Do Not Drink" or equivalent sign installed
10/30/2024	10232414-28	475 Portable Faucet Right	8.9			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

George Washington Elementary – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
10/29/2024	10232413-6	517 Auditorium Women's Faucet	5.6			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413-13	518 Faucet Men's Auditorium	8.3			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413.14	512 Faucet Room 108	5.7			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413.21	520 Room 219 Faucet	11.6			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413.23	522 Room 212 Faucet	7.8			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413.25	536 Room 002 Faucet	6.6			"Do Not Drink" or equivalent sign installed
10/29/2024	10232413.36	524 Room 213 Faucet	5.8			"Do Not Drink" or equivalent sign installed

John F. Kennedy Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
10/29/2024	10232415-1	420 Room 204 Faucet	9.4			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-2	421 Room 203 Faucet	7.3			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-4	423 Room 205 Faucet	6.5			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-5	424 Room 207 Faucet	10.4			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-10	419 Room 202 Faucet	6.5			"Do Not Drink" or equivalent sign installed



We Inspire. We Educate. We Graduate.
All Students, All of the Time

Dr. Paul J. Padalino, Superintendent

Dylan Bogart, Director of Facilities
21 Wynkoop Place • Kingston, NY 12401

John F. Kennedy Elementary School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
10/29/2024	10232415-11	410 Room 113 Faucet	6.5			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-13	412 Room 109 Faucet	9.1			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-19	408 Faculty Room Faucet	5.1			"Do Not Drink" or equivalent sign installed
10/29/2024	10232415-55	Kitchen Faucet	16.8			"Do Not Drink" or equivalent sign installed / New Faucet / Point Source Filtration
10/29/2024	10232415-30	428 Room 213 Faucet	10.7			"Do Not Drink" or equivalent sign installed

Kingston High School – Kingston City School District

Date	Sample ID	Location	Lead Level (ppb)	Resampling 1st Draw Results (ppb)	Resampling date	Remarks
11/7/2024	10292416-94	694 Carnegie Basement Faucet	69.7			"Do Not Drink" or equivalent sign installed
11/4/2024	10292416-97	667 S127 Faucet	8.4			"Do Not Drink" or equivalent sign installed