

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)




AT-1807

Laboratory Report

for

Golden State Water Company
401 S. San Dimas Canyon Road
San Dimas, CA 91773
Attention: Kate Martin



Utah ELCP CA00006

DST: David S Tripp
Project Manager

Report: 730615
Project: WILLOWBROOK
Group: Anderson Elementary

* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.

* Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.

* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

* Test results relate only to the sample(s) tested.



Eaton Analytical

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 730615
Project: WILLOWBROOK
Group: Anderson Elementary

Golden State Water Company
Kate Martin
401 S. San Dimas Canyon Road
San Dimas, CA 91773

Samples Received on:
04/10/2018 17:14

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	DLR	Dilution
<u>H Building/Library - lower (201804110837)</u>						Sampled on 04/10/2018 0732			
Static ID: WB-AAD-A									
EPA 200.8 - ICPMS Metals									
04/12/18	04/13/18 16:41	1081751	1082591	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1
<u>Corridor L Building - left (201804110838)</u>						Sampled on 04/10/2018 0739			
Static ID: WB-AAD-B									
EPA 200.8 - ICPMS Metals									
04/12/18	04/13/18 16:44	1081751	1082591	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1
<u>Corridor C Building - left (201804110839)</u>						Sampled on 04/10/2018 0727			
Static ID: WB-AAD-C									
EPA 200.8 - ICPMS Metals									
04/12/18	04/13/18 16:45	1081751	1082591	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1
<u>Kitchen - west wall (201804110840)</u>						Sampled on 04/10/2018 0722			
Static ID: WB-AAD-D									
EPA 200.8 - ICPMS Metals									
04/12/18	04/13/18 16:46	1081751	1082591	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1