


Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18E0473

Report Date: 05/15/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

Page 1 of 1

COMPTON-CITY, WATER DEPT.		User ID: 4TH		System: 1910026	
Dickison Elementary-drinking fountain		Station No.: 1910026-AAF-A		Sampled: 180501 06:50	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	
Dickison Elementary-teacher lounge		Station No.: 1910026-AAF-B		Sampled: 180501 06:55	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	
El Segundo School-drinking fountain		Station No.: 1910026-AAG-A		Sampled: 180501 06:30	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	
El Segundo School-teacher lounge		Station No.: 1910026-AAG-B		Sampled: 180501 06:40	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	
Emerson Elementary-drinking fountain		Station No.: 1910026-AAH-A		Sampled: 180501 07:20	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	
Emerson Elementary-teacher lounge		Station No.: 1910026-AAH-B		Sampled: 180501 07:15	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180511	

Printed: 05/15/2018 03:32:18 PM Results of 18E0473 FINAL WRITEON ALL_SAMPLES

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088

01016

Clinical Laboratory of San Bernardino, Inc.

Chain of Custody

Client		City of Compton Water Department		Client Job No.		Analysis Requested		Turn Around Time	
Address		205 S WILLOWBROOK AVE COMPTON CA 90220		1850473		LEAD (School)		FREE CHLORINE	
System No.		1910026		Destination Laboratory					
Phone No.		310-605-5690 FAX No. 310-605-0663		[X] Clinical Laboratory					
Project:				[] Other:					
Sampled By		6478							
Date	Time	Sample Identification	Matrix	No.	Pres.				
5/1/2018	5:55	1910026-AAF-B(DICKINSON KITCHEN)	DW						
5/1/2018	6:40	1910026-AAF-A(DICKINSON FOUNTAIN AT BLDG 'E')	DW		Y				
5/1/2018	6:40	1910026-AAG-B(MCNAIR'S SCHOOL KITCHEN SINK)	DW		Y				
5/1/2018	6:40	1910026-AAG-A(MCNAIR FOUNTAIN AT 'C')	DW		Y				
5/1/2018	7:10	1910026-AAH-B(EMERSON KITCHEN SINK)	DW		Y				
5/1/2018	7:10	1910026-AAH-A(EMERSON BLDG 'D' FOUNTAIN)	DW		Y				
Preservatives: (1) Na ₂ S ₂ O ₃ (3) Cold (2) H ₂ SO ₄ /HCl (4)						Turn Around Time: (10) 10 Day (normal) (5) Five Day Rush (2) Two Day Rush			
Relinquished By (Sign)		Print Name / Company		Date / Time		Received By (Sign)		Print Name / Company	
		J. Hernandez/CLB		5-2-18/1:30				J. Hernandez/CLB	
Rec'd at Lab By:		Rec'd Date / Time:		Date / Time		Comments:			
				5-2-18/3:00					
Shipped Via		Fed X Golden State		U/PS Client		Other		Page 59C of	

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Compton, City of	Project: Routine	Work Order: 18E0473
205 Willowbrook	Sub Project:	Received: 05/02/18 15:00
Compton CA, 90221	Project Manager: Alex Santos	Reported: 05/15/18

1910026-AAF-B **18E0473-01 (Water)** **Sample Date:** 05/01/18 6:55 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **1.16** mg/L 05/01/18 05/01/18 1818174

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/10/18 05/11/18 1819120

1910026-AAF-A **18E0473-02 (Water)** **Sample Date:** 05/01/18 6:50 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **0.78** mg/L 05/01/18 05/01/18 1818174

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/10/18 05/11/18 1819120

1910026-AAG-B **18E0473-03 (Water)** **Sample Date:** 05/01/18 6:40 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **0.26** mg/L 05/01/18 05/01/18 1818174

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/10/18 05/11/18 1819120

1910026-AAG-A **18E0473-04 (Water)** **Sample Date:** 05/01/18 6:30 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **0.16** mg/L 05/01/18 05/01/18 1818174

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/10/18 05/11/18 1819120

1910026-AAH-B **18E0473-05 (Water)** **Sample Date:** 05/01/18 7:15 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **1.27** mg/L 05/01/18 05/01/18 1818174

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/10/18 05/11/18 1819120

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Compton, City of
205 Willowbrook
Compton CA, 90221

Project: Routine
Sub Project:
Project Manager: Alex Santos

Work Order: 18E0473
Received: 05/02/18 15:00
Reported: 05/15/18

1910026-AAH-A

18E0473-06 (Water)

Sample Date: 05/01/18 7:20

Sampler: J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field)	Field	1.22			mg/L	05/01/18	05/01/18	1818174	
---------------------	-------	------	--	--	------	----------	----------	---------	--

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	05/10/18	05/11/18	1819120	
-----------	----------	----	-----	----	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit

Bob Glaubig

Laboratory Director