


Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18E1414

Report Date: 05/29/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

Page 1 of 1

COMPTON-CITY, WATER DEPT.		User ID: 4TH		System: 1910026	
Longfellow Elementar-drinking fountain		Station No.: 1910026-ABC-A		Sampled: 180511 07:08	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	
Longfellow Elementar-teacher lounge		Station No.: 1910026-ABC-B		Sampled: 180511 07:00	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	
Mayo Elementary-drinking fountain		Station No.: 1910026-ABD-A		Sampled: 180511 06:25	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	
Mayo Elementary-teacher lounge		Station No.: 1910026-ABD-B		Sampled: 180511 06:36	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	
Robert F. Kennedy El-drinking fountain		Station No.: 1910026-ABE-A		Sampled: 180511 07:21	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	
Robert F. Kennedy El-teacher lounge		Station No.: 1910026-ABE-B		Sampled: 180511 07:16	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180529	

Printed: 05/29/2018 04:38:40 PM Results of 18E1414 FINAL WRITEON ALL_SAMPLES

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088

Clinical Laboratory of San Bernardino, Inc.


Chain of Custody

1415
1576

[illegible]

5200

Clinical Laboratory of San Bernardino, Inc.
Celebrating 50 Years of Analytical Service 1967-2017



Compton, City of
 205 Willowbrook
 Compton CA, 90221

Project: Routine
 Sub Project:
 Project Manager: Alex Santos

Work Order: 18E1414
 Received: 05/14/18 18:25
 Reported: 05/29/18

1910026-ABC-B

18E1414-01 (Water)

Sample Date: 05/11/18 7:00 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **0.38** mg/L 05/11/18 05/11/18 1820062

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/29/18 05/29/18 1822012

1910026-ABC-A

18E1414-02 (Water)

Sample Date: 05/11/18 7:08 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **0.39** mg/L 05/11/18 05/11/18 1820062

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/29/18 05/29/18 1822012

1910026-ABD-B

18E1414-03 (Water)

Sample Date: 05/11/18 6:36 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **1.55** mg/L 05/11/18 05/11/18 1820062

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/29/18 05/29/18 1822012

1910026-ABD-A

18E1414-04 (Water)

Sample Date: 05/11/18 6:25 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field **1.12** mg/L 05/11/18 05/11/18 1820062

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/29/18 05/29/18 1822012

1910026-ABE-B

18E1414-05 (Water)

Sample Date: 05/11/18 7:16 **Sampler:** J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses


Cl Res Free (Field) Field **0.16** mg/L 05/11/18 05/11/18 1820062

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/29/18 05/29/18 1822012

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Compton, City of
205 Willowbrook
Compton CA, 90221

Project: Routine
Sub Project:
Project Manager: Alex Santos

Work Order: 18E1414
Received: 05/14/18 18:25
Reported: 05/29/18

1910026-ABE-A

18E1414-06 (Water)

Sample Date: 05/11/18 7:21

Sampler: J. Garfias

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field)	Field	0.20			mg/L	05/11/18	05/11/18	1820062	
---------------------	-------	------	--	--	------	----------	----------	---------	--

Metals

Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	05/29/18	05/29/18	1822012	
-----------	----------	----	-----	----	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit

Bob Glaubig

Laboratory Director