Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1

Work Order: 18E1915
Report Date: 06/01/2018
Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

COMPTON-CITY, WATER DEPT. User ID: 4TH System: 1910026

Francis Willard Scho-drinking fountain		Station No.: 1910026-AAJ-A			Sampled: 180516 06:19
LEAD	Result: ND	Units: UG/L	Entry No.: 01051		Analyzed: 180531
Francis Willard Scho-teacher lounge		Station No.: 1910026-AAJ-B			Sampled: 180516 06:29
LEAD	Result: ND	Units: UG/L	Entry No.: 01051		Analyzed: 180530

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088

Clinical Laboratory of San Bernardino, Inc.

5/6/2

Chain of Custody

Client	City of Compton Municipal Water Dept	Client Job No.	Analysis Requested
Address	205 S WILLOWBROOK AVE	18E1915	
	COMPTON CA 90220		
System No.	1910026	Destination Laboratory	
Phone No.	310-605-5690 FAX No. 310-605-0663	[X] Clinical Laboratory	
		[ ] Other:	
Project:			
Sampled By	D BENNETT		

Date	Time	Sample Identification	Matrix	No.	Pres.	LEAD	FREE CHLORINE	Turn Around Time
5/16/2018	6:29	1910026-AAJ-B Francis Willard K Faucet)	DW			Y	1.09	
5/16/2018	6:19	1910026-AAJ-A Francis Willard D Fountain)	DW			Y	1.24	

Preservatives: (1) $Na_2S_2O_3$ (3) Cold
(2) H_2SO_4/HCl (4)

Turn Around Time: (10) 10 Day (normal) (5) Five Day Rush (2) Two Day Rush
All turn around times are expressed as working days / Not all analyses can be processed as rush

Relinquished By (Sign)	Print Name / Company	Date / Time	Received By (Sign)	Print Name / Company
D. BENNETT	CITY OF COMPTON	5-16-2018		CLSB
	Amy L / CLSB	5/16/18 5:35 pm		CCs

Rec'd at Lab By: Rec'd Date / Time: Comments:

Shipped Via [ ] Fed X [ ] Golden State [ ] UPS [X] Client [ ] Other _____ Page ____ of ____

5.2°C

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017

Compton, City of	Project: Routine	Work Order: 18E1915
205 Willowbrook	Sub Project:	Received: 05/21/18 17:35
Compton CA, 90221	Project Manager: Alex Santos	Reported: 06/01/18

Francis Willard K Faucet **18E1915-01 (Water)** **Sample Date:** 05/16/18 6:29 **Sampler:** D. Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
Field Analyses									
Cl Res Free (Field)	Field	**1.09**			mg/L	05/16/18	05/16/18	1821039	
Metals									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	05/30/18	05/30/18	1822063	

Francis Willard D. Fountain **18E1915-02 (Water)** **Sample Date:** 05/16/18 6:19 **Sampler:** D. Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
Field Analyses									
Cl Res Free (Field)	Field	**1.24**			mg/L	05/16/18	05/16/18	1821039	
Metals									
Lead (Pb)	SM3113-B	ND	5.0	15	ug/L	05/30/18	05/31/18	1822063	

ND Analyte NOT DETECTED at or above the reporting limit

Bob Glaubig

Bob Glaubig

Laboratory Director

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088