


Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18E0061

Report Date: 05/14/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

Page 1 of 1

COMPTON-CITY, WATER DEPT.		User ID: 4TH		System: 1910026	
Bunche Middle-drinking fountain		Station No.: 1910026-AAB-A		Sampled: 180426 06:09	
LEAD	Result: 9.3	Units: UG/L	Entry No.: 01051	Analyzed: 180508	
Bunche Middle-teacher lounge		Station No.: 1910026-AAB-B		Sampled: 180426 06:05	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180508	
Centennial High-drinking fountain		Station No.: 1910026-AAC-A		Sampled: 180426 06:31	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180508	
Centennial High-teacher lounge		Station No.: 1910026-AAC-B		Sampled: 180426 06:24	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051	Analyzed: 180508	

Printed: 05/14/2018 10:51:54 AM Results of 18E0061 FINAL WRITEON ALL_SAMPLES

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088

0/5/4


Chain of Custody

[illegible]

63

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Compton, City of
205 Willowbrook
Compton CA, 90221

Project: Routine
Sub Project:
Project Manager: Alex Santos

Work Order: 18E0061
Received: 04/30/18 16:40
Reported: 05/14/18

1910026-AAB-B

18E0061-01 (Water)

Sample Date: 04/26/18 6:05

Sampler: David Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field 0.07 mg/L 04/26/18 04/26/18 1818053

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/08/18 05/08/18 1819048

1910026-AAB-A

18E0061-02 (Water)

Sample Date: 04/26/18 6:09

Sampler: David Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field 0.04 mg/L 04/26/18 04/26/18 1818053

Metals

Lead (Pb) SM3113-B 9.3 5.0 15 ug/L 05/08/18 05/08/18 1819048

1910026-AAC-B

18E0061-03 (Water)

Sample Date: 04/26/18 6:24

Sampler: David Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field 0.11 mg/L 04/26/18 04/26/18 1818053

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/08/18 05/08/18 1819048

1910026-AAC-A

18E0061-04 (Water)

Sample Date: 04/26/18 6:31

Sampler: David Bennett

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Field Analyses

Cl Res Free (Field) Field 0.08 mg/L 04/26/18 04/26/18 1818053

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 05/08/18 05/08/18 1819048

ND Analyte NOT DETECTED at or above the reporting limit

Bob Glaubig
Laboratory Director