eurofins | Eaton Analytical

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

ilac-MRA

ANAB ACCREDITED ISO/IEC 17025 TESTING LABORATORY
AT-1807

Laboratory Report

for

Golden State Water Company
401 S. San Dimas Canyon Road
San Dimas, CA 91773
Attention: Kate Martin

NELAP RECOGNIZED TNI ACCREDITATION BODY
Utah ELCP CA00006

Date of Issue
04/09/2018
EUROFINS EATON
ANALYTICAL, LLC

DST: David S Tripp
Project Manager

Report: 728829
Project: WILLOWBROOK
Group: Willowbrook Middle School

* Accredited in accordance with TNI 2009 and ISO/IEC 17025:2005.
* Laboratory certifies that the test results meet all **TNI 2009 and ISO/IEC 17025:2005** requirements unless noted under the individual analysis.
* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.
* Test results relate only to the sample(s) tested.

eurofins | Eaton Analytical

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 728829
Project: WILLOWBROOK
Group: Willowbrook Middle School

Golden State Water Company
Kate Martin
401 S. San Dimas Canyon Road
San Dimas, CA 91773

Samples Received on:
04/03/2018 1539

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	DLR	Dilution
Cafeteria - fountain on right (201804031035)							**Sampled on 04/03/2018 0702**		
Static ID: WB-AAB-A									
EPA 200.8 - ICPMS Metals									
04/05/18	04/08/18 12:37	1079755	1080963	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1
Kitchen - East Wall (201804031036)							**Sampled on 04/03/2018 0652**		
Static ID: WB-AAB-B									
EPA 200.8 - ICPMS Metals									
04/05/18	04/08/18 12:41	1079755	1080963	(EPA 200.8)	Lead Total ICAP/MS	7.3	ug/L	5	1
O Building - lower fountain (201804031037)							**Sampled on 04/03/2018 0657**		
Static ID: WB-AAB-C									
EPA 200.8 - ICPMS Metals									
04/05/18	04/08/18 12:42	1079755	1080963	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1
M building - upper fountain (201804031038)							**Sampled on 04/03/2018 0707**		
Static ID: WB-AAB-D									
EPA 200.8 - ICPMS Metals									
04/05/18	04/08/18 12:43	1079755	1080963	(EPA 200.8)	Lead Total ICAP/MS	ND	ug/L	5	1

Rounding on totals after summation.
(c) - indicates calculated results