

**BID ADDENDUM NO. 2**

**OWNER:** EDGEMONT UNION FREE SCHOOL DISTRICT

**PROJECT NAME:** GREENVILLE ELEMENTARY SCHOOL  
HVAC UPGRADES AND CAFETERIA RENOVATIONS

This Addendum is hereby included in and made a part of the Contract Documents, dated January 31, 2025 whether or not attached thereto.

All requirements of the original project specifications and drawings shall remain in force except as amended by this addendum.

DATE: February 21, 2025

This addendum consists of one (1) page.

***THE FOLLOWING ARE MODIFICATIONS, CLARIFICATIONS, DELETIONS OR ADDITIONS TO THE DRAWINGS:***

**DRAWING GVES M101 – FIRST FLOOR MECHANICAL RCP**

Notes, **DELETE** note #2.

**DRAWING GVES E001 – ELECTRICAL LEGEND, NOTES, ABBREVIATIONS, KEY PLAN, & DRAWING SCHEDULE**

GENERAL NOTES, **ADD** “3. Electrical Contractor shall include cost to furnish and install a portable generator for the duration that power will be interrupted. For pricing figure a 10kW generator along with temporary 20x10x8ft high wood frame enclosure with sound blankets. Electrical Contractor shall coordinate with owner to generate a list of essential loads to remain in service during the outage. Submit load summary to design engineer for review and to confirm generator size prior to procurement.”.

**END OF BID ADDENDUM NO. 2**

The following attachments are provided for informational purposes:

**Bidder RFI Responses** (In the event of a discrepancy between these responses and the contract documents, the contract documents shall prevail unless modified by addendum.)

Bid RFI-#005 dated 2/10/2025 (1 page).

Bid RFI-#006 dated 2/18/2025 (1 page).

SECTION 00 2115  
RFI FORM

CONTRACTOR'S REQUEST FOR INTERPRETATION NO. 1

F&D RFI NO: 005  
(F&D USE)

NAME OF PROJECT: HVAC Upgrades And Cafeteria Renovations

NAME OF OWNER: Edgemont Union Free School District

FACILITY: Greenville Elementary School

DATE: 2/10/25

A/E PROJECT NO: 24529.01

ARCHITECT: Fuller and D'Angelo, P.C.

45 Knollwood Road, Elmsford, NY 10523

Tel: 914-592-4444; Fax: 914-592-1717

William Means, RA WilliamM@fullerdangelo.com

Refer to Section 00 2113 Par 1.13 for additional requirements.

FROM (CO. NAME): Sun-Dance Energy Contractors INC., d/b/a Markley Mechanical

CONTACT NAME: Glenn E. Markley Tel: 914-788-0536

SUBJECT: \_\_\_\_\_

DISCIPLINE/TRADE: Sheet metal

DWG./SPEC. REFERENCE: M101

QUESTION: on M101 Note #2 it mentions spiral exposed duct, is this the horizontal duct off the RTU in the cafeteria, if so on drawing A200 ceiling drawing and drawing A427 shows that duct inside of a soffit so is it spiral double wall or is it rectangular duct because its in the soffit?

\_\_\_ FIELD CONDITION \_\_\_\_\_

\_\_\_ DRAWING/SPEC \_\_\_\_\_

\_\_\_ DISCREPANCY \_\_\_\_\_

\_\_\_ OWNER CHANGE \_\_\_\_\_

\_\_\_ CLARIFICATION \_\_\_\_\_

\_\_\_ CONTRACTOR'S SUGGESTION (IF APPLICABLE): \_\_\_\_\_

ANSWER

Regarding Sheet M-101 Note 2, reference to exposed spiral ductwork and field painting are to be removed. Ductwork shall be rectangular at sizes indicated. Sidewall supply registers to be located at soffit fascia.

ARCHITECT'S SIGNATURE:  LFG Inc. DATE: 2-18-25

Note: review and any responses to this request for information by the architect/engineer is strictly for design intent only and does not constitute acknowledgement or acceptance of any cost or schedule implications unless specifically presented by the contractor. By submission of this request for information, the contractor assumes all responsibility in the absence of an approved change order or work directive.

END OF SECTION

FULLER AND D'ANGELO, P.C.  
ARCHITECTS AND PLANNERS

SECTION 00 2115  
RFI FORM 1

CONTRACTOR'S REQUEST FOR INTERPRETATION NO. \_\_\_\_\_

F&D RFI NO: **006**  
(F&D USE)

NAME OF PROJECT: HVAC Upgrades And Cafeteria Renovations

NAME OF OWNER: Edgemont Union Free School District

FACILITY: Greenville Elementary School

DATE: 2-18-25

A/E PROJECT NO: 24529.01

ARCHITECT: Fuller and D'Angelo, P.C.

45 Knollwood Road, Elmsford, NY 10523

Tel: 914-592-4444;

Fax: 914-592-1717

William Means, RA

WilliamM@fullerdangelo.com

Refer to Section 00 2113 Par 1.13 for additional requirements.

FROM (CO. NAME): Camilli & Sons

CONTACT NAME: J Spencer Tel: 914-769-1164

SUBJECT: Insurances

DISCIPLINE/TRADE: \_\_\_\_\_

DWG./SPEC. REFERENCE: \_\_\_\_\_

QUESTION: **Umbrella Excess - Will this project be based on 1 story or 10 feet which would be 5 million or high risk project value greater than 1million requiring 10 million umbrella?**

FIELD CONDITION \_\_\_\_\_

DRAWING/SPEC \_\_\_\_\_

DISCREPANCY \_\_\_\_\_


OWNER CHANGE \_\_\_\_\_

CLARIFICATION \_\_\_\_\_

CONTRACTOR'S SUGGESTION (IF APPLICABLE): \_\_\_\_\_

ANSWER

**Follow requirements as stated in Article 10 of the General Conditions.**

ARCHITECT'S SIGNATURE:  DATE: **2/21/2025**

Note: review and any responses to this request for information by the architect/engineer is strictly for design intent only and does not constitute acknowledgement or acceptance of any cost or schedule implications unless specifically presented by the contractor. By submission of this request for information, the contractor assumes all responsibility in the absence of an approved change order or work directive.

END OF SECTION

FULLER AND D'ANGELO, P.C.  
ARCHITECTS AND PLANNERS