

BARNES_LOCATION (FACILITIES REPIPE PROJECT)	SAMPLE ID	PRELIMINARY SAMPLE DATE	PRELIMINARY LEAD RESULT (ppb)	FLUSH TEST LEAD RESULT (ppb)	SAMPLE DATE	LEAD RESULT (ppb)	FINAL SAMPLE DATE	FINAL LEAD RESULT (ppb)
Classroom A100 (Faucet)	BES-001CFA	1/3/2025	7	-	2/11/2025	ND	-	-
Classroom A100 (Fountain)	BES-002DWA	1/3/2025	3.3	-	2/11/2025	1.5	-	-
Classroom A102 (Faucet)	BES-003CFA	1/3/2025	14.3	ND	2/11/2025	1	-	-
Classroom A102 (Fountain)	BES-004DWA	1/3/2025	2.1	-	2/11/2025	1.5	-	-
Classroom A103 (Faucet)	BES-005CFA	1/3/2025	38.6	15.8	2/11/2025	9.6	-	-
Classroom A103 (Fountain)	BES-006DWA	1/3/2025	16.7	3	2/11/2025	ND	-	-
A Hall Boys Restroom (Far Left Faucet)	BES-007BFA	1/3/2025	29.6	ND	2/11/2025	ND	-	-
A Hall Boys Restroom (Middle Left Faucet)	BES-008BFA	1/3/2025	3.3	-	2/11/2025	2.8	-	-
A Hall Boys Restroom (Middle Right Faucet)	BES-009BFA	1/3/2025	6.5	-	2/11/2025	14.4	-	-
A Hall Boys Restroom (Far Right Faucet)	BES-010BFA	1/3/2025	5.5	-	2/11/2025	3.3	-	-
A Hall Girls Restroom (Left Faucet)	BES-011BFA	1/3/2025	9.2	-	2/11/2025	ND	-	-
A Hall Girls Restroom (Middle Faucet)	BES-012BFA	1/3/2025	36.4	3.3	2/11/2025	ND	-	-
A Hall Girls Restroom (Right Faucet)	BES-013BFA	1/3/2025	4.6	-	2/11/2025	ND	-	-
Classroom A105 (Faucet)	BES-014CFA	1/3/2025	22.7	1.9	2/11/2025	4.2	-	-
Classroom A105 (Fountain)	BES-015DWA	1/3/2025	5.2	-	2/11/2025	1.4	-	-
Classroom A107 (Faucet)	BES-016CFA	1/3/2025	24.4	2.6	2/11/2025	2.7	-	-
Classroom A107 (Fountain)	BES-017DWA	1/3/2025	5.5	-	2/11/2025	2.3	-	-
Classroom A109 (Faucet)	BES-018CFA	1/3/2025	24.7	2.8	2/11/2025	1.7	-	-
Classroom A109 (Fountain)	BES-019DWA	1/3/2025	2.2	-	2/11/2025	ND	-	-
Classroom A111 (Faucet)	BES-020CFA	1/3/2025	15.3	1.6	2/11/2025	5.7	-	-
Classroom A111 (Fountain)	BES-021DWA	1/3/2025	5.7	-	2/11/2025	1.1	-	-
Gymnasium - West Side (Fountain)	BES-022DWA	1/3/2025	45.6	-	2/11/2025	ND	-	-
Gymnasium - East Side (Fountain)	BES-023DWA	1/3/2025	9.3	-	2/11/2025	ND	-	-
Classroom A110 (Faucet)	BES-024CFA	1/3/2025	15.9	2.3	2/11/2025	1.8	-	-
Classroom A110 (Fountain)	BES-025DWA	1/3/2025	16.2	1.7	2/11/2025	ND	-	-
Classroom A108 (Faucet)	BES-026CFA	1/3/2025	46.1	9.3	2/11/2025	1.6	-	-
Classroom A108 (Fountain)	BES-027DWA	1/3/2025	3.6	-	2/11/2025	ND	-	-
Classroom A106 (Faucet)	BES-028CFA	1/3/2025	10.7	-	2/11/2025	2.4	-	-
Classroom A106 (Fountain)	BES-029DWA	1/3/2025	1.6	-	2/11/2025	1.1	-	-
Classroom A010 (Faucet)	BES-030CFA	1/3/2025	4.2	-	2/11/2025	9	-	-
Classroom A011 (Fountain)	BES-031DWA	1/3/2025	5.9	-	2/11/2025	2	-	-
Classroom A011 (Faucet)	BES-032CFA	1/3/2025	3.6	-	2/11/2025	15.6	2/24/2025	ND
Lower A Hall - Left of A006 (Faucet)	BES-033CFA	1/3/2025	4.5	-	2/11/2025	3.8	-	-
Lower A Hall - Left of A006 (Fountain)	BES-034DWA	1/3/2025	1.3	-	2/11/2025	15.9	2/24/2025	1.6
Office A1	BES-035SFA	-	-	-	2/11/2025	12.6	-	-
Upper A Hall (Left Fountain Between Restrooms)	BES-036DWA	-	-	-	2/11/2025	24.6	2/24/2025	ND
Upper A Hall (Bottle Filler Between Restrooms)	BES-037WBA	-	-	-	2/11/2025	17.7	2/24/2025	ND
Upper A Hall (Right Fountain Between Restrooms)	BES-038DWA	-	-	-	2/11/2025	9.6	-	-