

Asbestos Management Plan (AMP) - Inspections Are Good For Three Years

School	Asbestos Present	AMP	3 Year Inspection Date	Next 3 Year Inspection	Remarks
Abraham Lincoln Elementary School*	No	Not Required.	Not Required.	Not Required.	Abe Lincoln was built in 1996. No asbestos containing material was used in the construction material.
Bartlett Building (Former Medford Online Academy)	Yes	Oct 2020	Jul 2024	Jul 2027	This was a building we started leasing in July 2020.
Biddle	No	Jul 2022	Not Required.	Not Required.	We started leasing this space in July of 2021 for the District Office. No ACM were found during inspection.
Central Medford High School on Royal Ave. (Discontinued)	Yes	Oct 2020	Not Required.	Not Required.	We have stopped renting this building.
Excel Building (Discontinued)	No	Jul 2022	Not Required.	Not Required.	We have stopped renting this building.
Griffin Creek Elementary School	Yes	Jul 2012	Aug 2024	Aug 2027	In 2007, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Hedrick Middle School	Yes	Jul 2012	Jul 2024	July 2027	In 2009, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Hoover Elementary School	Yes	Jul 2012	Jul 2024	Jul 2027	In 2007, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Howard Elementary School	Yes	Jan 2013	Aug 2024	Aug 2027	In 2008, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Innovation Academy	Yes	Jul 2024	Jul 2024	Jul 2027	We purchased this building in the summer of 2023.
Jackson Elementary School**	No Longer	Jan 2013	No Longer Required.	No Longer Required.	In 2008, a large scale asbestos abatement project removed ALL of the asbestos-containing materials.
Jacksonville Elementary School	Yes	Jan 2013	Jun 2024	June 2027	In 2008, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Jefferson Elementary School	Yes	Apr 2011	Jul 2024	Jul 2027	In 2007, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Kennedy Elementary School	Yes	Jan 2013	Jul 2024	Jul 2027	In 2007, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Lone Pine Elementary School	Yes?	Mar 2013	Jul 2024	Jul 2027	In 2008/09, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Maslow (500 Monroe)	Yes	Oct 2020	Jul 2024	Jul 2027	Limited asbestos sampling was done in 2011/12 in select spaces. A full survey was done 2016.
McLoughlin Middle School	Yes	Apr 2013	Jul 2024	July 2027	In 2009, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
North High School	Yes	May 2013	Jul 2024	July 2027	In 2008/09/11, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Oak Grove Elementary School	Yes	Jun 2013	Jul 2024	Jul 2027	In 2008/09, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Oakdale Middle School (MSDEC)	Yes	Jan 2013	Jul 2024	July 2027	In 2010/11, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Roosevelt Elementary School**	No Longer	Jun 2013	No Longer Required.	No Longer Required.	In 2008, a large scale asbestos abatement project removed ALL of the asbestos-containing materials.
Ruch Elementary School	Yes	Jun 2013	Jun 2024	June 2027	In 2008, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
South High School*	No	Not Required.	Not Required.	Not Required.	South was built in 2010. No asbestos containing material was used in the construction material.
Warehouse @750 Columbus	Yes	Oct 2020	Aug 2024	Aug 2027	Full survey done in 2016.
Washington Elementary School	Yes	Aug 2013	Aug 2024	Aug 2027	In 2007/08, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.
Wilson Elementary School	Yes	Aug 2013	Jul 2024	July 2027	In 2008, a large scale asbestos abatement project removed/enclosed many of the asbestos-containing materials.

* South and Abraham Lincoln have never had asbestos material in the school; therefore, there is no requirement for an AMP.

** Jackson and Roosevelt have had all asbestos abated; therefore, additional 3 year periodic inspections are no longer required (Confirmed this with Jeff Herren from PBS on 5 Feb 15).

Digital versions of the Asbestos Management Plans are stored on the Facilities Google Drive in the Asbestos Folder.

All files are in the District on-line Asbestos Management System.

Before any work is done at a school site, check the site specific Asbestos Management Plan to ensure that there is no asbestos present in the area you are working.

Before a contractor does any work at a site that currently has asbestos, notify him/her of the presence of asbestos, and the availability of the Asbestos Management Plans.