

**Question and Answers for
RFP 25-028NA
Park Crest Middle School Plumbing Project**

Q: Do you need Buyboard quoting?

A: No

Q: Permits, city inspections, or fees?

A: No permits or fees needed.

Q: Any plumbing drawings available?

A: Due to safety and security issues, we cannot post the campus drawings/map online. If you would like a copy of the drawings/map please email: Nicole.ayer@pfisd.net . I will send it to you.

Q: Would you like for us to include Insulation?

A: No insulation required.

Q: What kind of underground DCW piping is required?

A: From the mechanical room (red line on the provided drawing) we require 2" Type L copper. From the meter (yellow line on the provided drawing) we require a 2" polyline bored underground.

Q: Work to be performed on regular time?

A: All work can be performed during regular business hours except the tie-in to the main.

Q: Will any DCW equipment be affected during shutdowns or tie in?

A: No DCW equipment will be affected.

Q: Are there construction drawings for this project?

A: Not for this project

Q: May we receive the CD drawings?

A: Due to safety and security issues, we cannot post the campus drawings/map online. If you would like a copy of the drawings/map please email: Nicole.ayer@pfisd.net I will send it to you.

Q: Also can you confirm is the water line needs to be copper or PVC 80?

A: From the mechanical room (red line on the provided drawing) we require 2" Type L copper.

From the meter (yellow line on the provided drawing) we require a 2" polyline bored underground.