

WEST IRONDEQUOIT CENTRAL SCHOOL DISTRICT

Template for Recordkeeping of Outlets Tested (Applicable Outlets) that Exceeded the Lead Action Level and the Remedial Actions that were/ are implemented.

Outlets that Exceeded the Lead Action Level and the Remedial Actions that were/are implemented.

Outlets Exceeding the Lead Action Level (5 micrograms per liter)																	
Laboratory ID	Outlet Location (or Sample ID)	Building	Space/ Function		Room	Outlet Type ¹	Sample Results		Remedial Actions (Please check all that apply)								Notes/Comments
							Initial (ppb)	Post Remediation	Outlet or Plumbing Replacement ²	Permanent Removal ³	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Flushing	Engineering Controls ⁴	
70330678001	OV 1	Oakview	Staff Room		Room 5	Sink	7.5		X			X			X		
70330673001	RM 1	Rogers Middle School	Classroom		Room 007	Sink	10.2		X			X	X	X	X		
70330673009	RM 9	Rogers Middle School	Classroom		Room 012	Sink	29.6		X			X	X	X	X		
70330673013	RM 13	Rogers Middle School	Bathroom		Room 138	Sink	13.5		X			X					
70330673014	RM 14	Rogers Middle School	Kitchen		Room 142	Pot Filler	7		X						X		
70330673015	RM 15	Rogers Middle School	Kitchen	Center island handwash	Room 142	Sink	18.5		X						X		
70330673019	RM 19	Rogers Middle School	Kitchen	Dishwasher	Room 142	Sprayer	62.6		X						X		
70330673029	RM 29	Rogers Middle School	Classroom		Room 120	Sink	11.2		X			X	X	X	X		
70330673030	RM 30	Rogers Middle School	Classroom		Room 310	Sink	15.3		X			X	X	X	X		
70330673031	RM 31	Rogers Middle School	Classroom	Right	Room 312	Sink	17.4		X			X	X	X	X		
70330673039	RM 39	Rogers Middle School	Classroom		Room 319	Sink	7.8					X	X	X	X		
70330673043	RM 43	Rogers Middle School	Gym	North side	Room 124	Drinking Fountain	5.7		X		X				X		
70330668013	SL 13	Southlawn Elementary School	Classroom		Room 166	Sink	11		X						X		
70330671004	EM 4	Evans McGraw Learning Center	Tutoring Center		Room 114	Sink	12.5		X		X	X			X		
70330662008	PG 8	Pinegrove	Bathroom		Room 128	Sink	8.1					X			X		
70330662009	PG 9	Pinegrove	Bathroom		Room 129	Sink	9.6					X			X		
70330662010	PG 10	Pinegrove	Classroom	HNC	Room 130	Sink	5.6					X			X		
70330662016	PG 16	Pinegrove	Bathroom	Left sink	Room 109	Sink	8					X			X		
70330662018	PG 18	Pinegrove	Bathroom		Room 106	Sink	11.2					X			X		
70330662019	PG 19	Pinegrove	Bathroom		Room 142	Sink	36.1					X			X		
70330662020	PG 20	Pinegrove	Bathroom		Room 143	Sink	23					X			X		
70330662021	PG 21	Pinegrove	Workspace		Room 141	Sink	22.6					X			X		
70330665008	SI 8	Seneca Elementary School	Faculty Room		Room 002	Sink	6.5		X						X		
70330665009	SI 9	Seneca Elementary School	Nurses Office		Room 106	Sink	11.9		X						X		
70330665017	SI 17	Seneca Elementary School	Classroom		Room 121	Sink	6.2		X						X		
70330653010	IM 10	Iroquois Middle School	Kitchen	Dishwash double left sink	Room 036	Sink	118		X						X		
70330653012	IM 12	Iroquois Middle School	Kitchen	Dishwasher sprayer	Room 036	Sprayer	10.2		X			X			X		
70330653013	IM 13	Iroquois Middle School	Art Room	Front left	Room 041	Sink	7		X			X	X	X	X	X	
70330653014	IM 14	Iroquois Middle School	Art Room	Front Right	Room 041	Sink	13.1		X			X	X	X	X	X	
70330653025	IM 25	Iroquois Middle School	Classroom	Left sink	Room 316	Sink	6.6		X			X			X		
70330637007	ES 7	Environmental Services	Service Bay		Matt's Area	Sink	10.6					X			X		

WEST IRONDEQUOIT CENTRAL SCHOOL DISTRICT

Template for Recordkeeping of Outlets Tested (Applicable Outlets) that Exceeded the Lead Action Level and the Remedial Actions that were/ are implemented.

Outlets that Exceeded the Lead Action Level and the Remedial Actions that were/are implemented.

Outlets Exceeding the Lead Action Level (5 micrograms per liter)																	
Laboratory ID	Outlet Location (or Sample ID)	Building	Space/ Function		Room	Outlet Type ¹	Sample Results		Remedial Actions (Please check all that apply)								Notes/Comments
							Initial (ppb)	Post Remediation	Outlet or Plumbing Replacement ²	Permanent Removal ³	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Flushing	Engineering Controls ⁴	
70330654001	IH 1	Irondequoit High School	Classroom		Room 1000	Sink	10.8					X	X	X	X		
70330654004	IH 4	Irondequoit High School	Classroom	Left of the exit door	Room 1010	Sink	28.7					X	X	X	X		
70330654013	IH 13	Irondequoit High School	Kitchen	Under Ansul System	Room 1030-5	Sink	171		X						X		
70330654017	IH 17	Irondequoit High School	Kitchen	Near locker room	Room 1030-9	Sink	12.1		X						X		
70330965001	IH 18	Irondequoit High School	Kitchen	Right of gas stove	Room 1030-10	Pot Filler	8.2		X						X		
70330965002	IH 19	Irondequoit High School	Kitchen	Right of gas stove	Room 1030-11	Pot Filler	5.8		X						X		
70330965005	IH 22	Irondequoit High School	Kitchen	Right of gas oven	Room 1030-13	Pot Filler	6.2		X						X		
70330965007	IH 24	Irondequoit High School	Kitchen	Locker room	Room 1032	Sink	6		X		X						
70330965010	IH 27	Irondequoit High School	Kitchen	Serving line	Room 1039	Sink	12.3		X						X		
70330965016	IH 33	Irondequoit High School	Classroom		Room 1071	Sink	15.9		X		X				X		
70330654056	IH 55-B	Irondequoit High School	Office		Room 2004	Sink	6.7		X		X						
70330654057	IH 56	Irondequoit High School	Hallway	Next to	Room 2021	Drinking Fountain	13.6		X		X				X		
70330654068	IH 67	Irondequoit High School	Classroom		Room 3031	Sink	67.6		X		X				X		
70330654069	IH 68	Irondequoit High School	Classroom		Room 3032	Sink	13.7		X		X				X		
70330654070	IH 69	Irondequoit High School	Hallway	Across from classroom	Room 3033	Drinking Fountain	7.9		X		X				X		
70330814006	DJ 6	Dake Junior High School	Classroom	Back wall left	Room 133-1	Sink	6		X						X		
70330814007	DJ 7	Dake Junior High School	Classroom	Back wall right	Room 133-2	Sink	7.2		X						X		
70330814008	DJ 8	Dake Junior High School	Classroom	Right wall left	Room 133-3	Sink	11.5		X						X		
70330814020	DJ 20	Dake Junior High School	Kitchen		Room 170-1	Sink	5.2		X						X		
70330814026	DJ 26	Dake Junior High School	Kitchen		Room 170-7	Pot Filler	87.9		X						X		
70330814027	DJ 27	Dake Junior High School	Kitchen		Room 170-6	Sprayer	22.2		X						X		
70330814050	DJ 50	Dake Junior High School	Bathroom		Room 350	Sink	5.7		X		X				X		

¹ Outlet type may include a drinking fountain/bubbler, kitchen outlets, or other.

² Outlet or Plumbing Replacement: Would include replacing existing fixtures or plumbing components with options that meet the 2014 Safe Drinking Water Act 1417 (a) (4) definition of lead-free (not containing more than 0.2 percent lead when used with respect to solder and flux; and not more than a weighted average of 0.25 percent lead when used with respect to the wetted surfaces of pipes, pipe fittings, plumbing fittings, and fixtures).

³ Removing the fixture and/or capping the supply line before the fixture.

⁴ Engineering controls may include locked doors, keys to operate an outside hose bib, or other.