

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4956004	Test Start :	01/15/2025 @ 10:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:43
Location :	1st FL = E-112/Asst.Princ.	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 15:51
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4953861	Test Start :	01/15/2025 @ 10:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:11
Location :	1st FL = E-110	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 16:06
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955974	Test Start :	01/15/2025 @ 10:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:11
Location :	1st FL = E-110/BL	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:30
SEAL PEELED OFF			

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4956055	Test Start :	01/15/2025 @ 10:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:12
Location :	1st FL = E-109	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:08
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955981	Test Start :	01/15/2025 @ 10:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:14
Location :	1st FL = E-108	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/21/2025 @ 10:43
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4953836	Test Start :	01/15/2025 @ 10:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:15
Location :	1st FL = E-107/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:26
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4955404	Test Start :	01/15/2025 @ 10:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:15
Location :	1st FL = E-107/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 15:26

Average of Side by Side Canisters 0.2 pCi/L
Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955395	Test Start :	01/15/2025 @ 10:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:16
Location :	1st FL = E-106	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:24
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955388	Test Start :	01/15/2025 @ 10:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:16
Location :	1st FL = E-105	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 15:29
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955458	Test Start :	01/15/2025 @ 10:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:17
Location :	1st FL = E-104	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 15:17
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955381	Test Start :	01/15/2025 @ 10:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:18
Location :	1st FL = E-103	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 16:06



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4955399	Test Start :	01/15/2025 @ 10:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:19
Location :	1st FL = E-102	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 15:12
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955312	Test Start :	01/15/2025 @ 10:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:21
Location :	1st FL = E-100	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 15:17
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955305	Test Start :	01/15/2025 @ 10:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:22
Location :	1st FL = E-100-A	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:06
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955385	Test Start :	01/15/2025 @ 10:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:23
Location :	1st FL = E-101	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:18
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	4955349	Test Start :	01/15/2025 @ 10:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:23
Location :	1st FL = Clinic/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 16:01
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955394	Test Start :	01/15/2025 @ 10:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:23
Location :	1st FL = Clinic/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 16:38



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4955301	Test Start :	01/15/2025 @ 10:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:24
Location :	1st FL=Clinic/Side Off.	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:01
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4955359	Test Start :	01/15/2025 @ 10:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:24
Location :	1st FL = ITW/Break Rm	Received:	01/20/2025 @ 11:24
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 16:45
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955313	Test Start :	01/15/2025 @ 10:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:25
Location :	1st FL = Parent Rm	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:43
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955345	Test Start :	01/15/2025 @ 10:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:25
Location :	1st FL = Suite 5	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 10:43
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955299	Test Start :	01/15/2025 @ 10:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:25
Location :	1st FL = Suite 6	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 15:00
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955356	Test Start :	01/15/2025 @ 10:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:34
Location :	1st FL = Auditorium	Received:	01/20/2025 @ 11:24
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 15:34
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955376	Test Start :	01/15/2025 @ 10:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:34
Location :	1st FL = Auditorium	Received:	01/20/2025 @ 11:24
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 16:17
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955353	Test Start :	01/15/2025 @ 10:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:35
Location :	1st FL = A-109	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:38
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955398	Test Start :	01/15/2025 @ 10:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:36
Location :	1st FL = A-108	Received:	01/20/2025 @ 11:24
Radon Level :	0.8 pCi/L	Analyzed:	01/20/2025 @ 15:26
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4953804	Test Start :	01/15/2025 @ 10:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:37
Location :	1st FL = A-106	Received:	01/20/2025 @ 11:24
Radon Level :	0.7 pCi/L	Analyzed:	01/20/2025 @ 16:43
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955375	Test Start :	01/15/2025 @ 10:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:38
Location :	1st FL = A-104	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 16:09



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955411	Test Start :	01/15/2025 @ 11:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:40
Location :	1st FL = A-105	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 15:44
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955357	Test Start :	01/15/2025 @ 11:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:42
Location :	1st FL = C-126	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 16:39
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955384	Test Start :	01/15/2025 @ 11:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:43
Location :	1st FL = C-124	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:17
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	4955390	Test Start :	01/15/2025 @ 11:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:46
Location :	1st FL = C-131/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:43
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4956020	Test Start :	01/15/2025 @ 11:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:46
Location :	1st FL = C-131/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 16:45

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955448 Test Start : 01/15/2025 @ 11:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:47
Location : 1st FL = C-129 Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:39
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4955351 Test Start : 01/15/2025 @ 11:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:48
Location : 1st FL = C-127 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 15:29
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4953830 Test Start : 01/15/2025 @ 11:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:48
Location : 1st FL = C-122 Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 15:49
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956013 Test Start : 01/15/2025 @ 11:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:50
Location : 1st FL = C-120 Received: 01/20/2025 @ 11:24
Radon Level : 0.2 pCi/L Analyzed: 01/20/2025 @ 16:17
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955433 Test Start : 01/15/2025 @ 11:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:50
Location : 1st FL = C-125 Received: 01/20/2025 @ 11:24
Radon Level : 0.5 pCi/L Analyzed: 01/20/2025 @ 15:32
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955430 Test Start : 01/15/2025 @ 11:21
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:51
Location : 1st FL = C-118 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 16:39
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955373	Test Start :	01/15/2025 @ 11:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:59
Location :	1st FL = C-112/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 15:44
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955457	Test Start :	01/15/2025 @ 11:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:59
Location :	1st FL = C-112/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 15:32

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955992	Test Start :	01/15/2025 @ 11:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:01
Location :	1st FL = C-110	Received:	01/20/2025 @ 11:24
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 16:21
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4949120	Test Start :	01/15/2025 @ 11:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:01
Location :	1st FL = C-110/BL	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:32
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955948	Test Start :	01/15/2025 @ 11:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:01
Location :	1st FL = C-115	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 15:43
Error for Measurement is: ±	0.3 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4953865 Test Start : 01/15/2025 @ 11:40
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:02
Location : 1st FL = C-113 Received: 01/20/2025 @ 11:24
Radon Level : 0.6 pCi/L Analyzed: 01/20/2025 @ 16:03
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955454 Test Start : 01/15/2025 @ 11:43
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:05
Location : 1st FL = Aux. Gym Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:24
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955463 Test Start : 01/15/2025 @ 11:43
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:05
Location : 1st FL = Aux. Gym Received: 01/20/2025 @ 11:24
Radon Level : 0.5 pCi/L Analyzed: 01/20/2025 @ 15:00
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955456 Test Start : 01/15/2025 @ 11:44
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:07
Location : 1st FL = Aux. Gym Off. Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:00
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955371 Test Start : 01/15/2025 @ 11:48
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:08
Location : 1st FL = D-111 Received: 01/20/2025 @ 11:24
Radon Level : 0.6 pCi/L Analyzed: 01/20/2025 @ 15:15
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4949067 Test Start : 01/15/2025 @ 11:49
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:08
Location : 1st FL = D-109 Received: 01/20/2025 @ 11:24
Radon Level : 0.5 pCi/L Analyzed: 01/20/2025 @ 16:21
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955946 Test Start : 01/15/2025 @ 11:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:09
Location : 1st FL = D-107 Received: 01/20/2025 @ 11:24
Radon Level : 0.6 pCi/L Analyzed: 01/20/2025 @ 16:08
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956057 Test Start : 01/15/2025 @ 11:52
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:14
Location : 1st FL = D-105 Received: 01/20/2025 @ 11:24
Radon Level : 0.1 pCi/L Analyzed: 01/20/2025 @ 15:26
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955423 Test Start : 01/15/2025 @ 11:55
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:10
Location : 1st FL = D-103/DP Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 15:26
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4959312 Test Start : 01/15/2025 @ 11:55
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:10
Location : 1st FL = D-103/DP Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:30

Average of Side by Side Canisters 0.4 pCi/L
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955418 Test Start : 01/15/2025 @ 11:56
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:11
Location : 1st FL = D-101 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 15:51
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955307 Test Start : 01/15/2025 @ 11:57
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:14
Location : 1st FL = 6th Grade Off. Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 15:46



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4955360	Test Start :	01/15/2025 @ 11:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:15
Location :	1st FL = L-2 Office	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 10:19
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955437	Test Start :	01/15/2025 @ 12:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:15
Location :	1st FL = Mail Rm	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:46
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4956018	Test Start :	01/15/2025 @ 12:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:16
Location :	1st FL=Principal Off.	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 16:30
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955438	Test Start :	01/15/2025 @ 12:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:17
Location :	1st FL = A-K Office	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 15:51
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955368	Test Start :	01/15/2025 @ 12:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:17
Location :	1st FL = 6th Grade Break Rm	Received:	01/20/2025 @ 11:24
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 15:43
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955450	Test Start :	01/15/2025 @ 12:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:18
Location :	1st FL = D-102	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 16:06



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4956017	Test Start :	01/15/2025 @ 12:04
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:18
Location :	1st FL = D-104	Received:	01/20/2025 @ 11:24
Radon Level :	0.5 pCi/L	Analyzed:	01/21/2025 @ 10:19
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4955372	Test Start :	01/15/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:20
Location :	1st FL = D-106/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:17
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4955460	Test Start :	01/15/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:20
Location :	1st FL = D-106/DP	Received:	01/20/2025 @ 11:24
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:15

Average of Side by Side Canisters 0.1 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4955387	Test Start :	01/15/2025 @ 12:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:20
Location :	1st FL = D-108	Received:	01/20/2025 @ 11:24
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 15:49
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955993	Test Start :	01/15/2025 @ 12:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:21
Location :	1st FL = D-110	Received:	01/20/2025 @ 11:24
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 15:26
Error for Measurement is: ±	0.3 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955435 Test Start : 01/15/2025 @ 12:09
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:22
Location : 1st FL = D-112 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 16:18
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4955963 Test Start : 01/15/2025 @ 12:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:27
Location : 1st FL = D-114 Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:24
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955403 Test Start : 01/15/2025 @ 12:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:24
Location : 1st FL = D-116 Received: 01/20/2025 @ 11:24
Radon Level : 0.9 pCi/L Analyzed: 01/20/2025 @ 15:12
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4953803 Test Start : 01/15/2025 @ 12:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:24
Location : 1st FL = D-118 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 16:03
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956011 Test Start : 01/15/2025 @ 12:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:26
Location : 2nd FL = B-205 Received: 01/20/2025 @ 11:24
Radon Level : 0.2 pCi/L Analyzed: 01/20/2025 @ 16:08
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959403 Test Start : 01/15/2025 @ 12:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:27
Location : 2nd FL = B-213 Received: 01/20/2025 @ 11:24
Radon Level : 0.5 pCi/L Analyzed: 01/20/2025 @ 15:15
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4956068 Test Start : 01/15/2025 @ 12:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:28
Location : 2nd FL = 8th Grade Counselor Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:03
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955420 Test Start : 01/15/2025 @ 12:24
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:30
Location : 2nd FL = B-229/DP Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 15:34
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955455 Test Start : 01/15/2025 @ 12:24
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:30
Location : 2nd FL = B-229/DP Received: 01/20/2025 @ 11:24
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 16:03

Average of Side by Side Canisters 0.3 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4953808 Test Start : 01/15/2025 @ 12:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:31
Location : 2nd FL = Library Off. Received: 01/20/2025 @ 11:24
Radon Level : 0.6 pCi/L Analyzed: 01/20/2025 @ 16:43
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4955421 Test Start : 01/15/2025 @ 12:27
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:32
Location : 2nd FL = E-203 Received: 01/20/2025 @ 11:24
Radon Level : 0.2 pCi/L Analyzed: 01/20/2025 @ 16:21
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4949119 Test Start : 01/15/2025 @ 12:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 13:34
Location : 2nd FL = E-210 Received: 01/20/2025 @ 11:24
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 15:17



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956006
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL = E-210/BL
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.1 pCi/L

Test Start : 01/15/2025 @ 12:29
Test Stop : 01/17/2025 @ 13:34
Received: 01/20/2025 @ 11:24
Analyzed: 01/20/2025 @ 16:30

Canister ID# : 4956067
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL = D-214
Radon Level : 0.3 pCi/L
Error for Measurement is: \pm 0.3 pCi/L

Test Start : 01/15/2025 @ 12:31
Test Stop : 01/17/2025 @ 13:36
Received: 01/20/2025 @ 11:24
Analyzed: 01/20/2025 @ 16:00

Canister ID# : 4955366
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL = D-200/DP
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Test Start : 01/15/2025 @ 12:37
Test Stop : 01/17/2025 @ 13:37
Received: 01/20/2025 @ 11:24
Analyzed: 01/20/2025 @ 16:00

Canister ID# : 4955410
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL = D-200/DP
Radon Level : 0.1 pCi/L

Test Start : 01/15/2025 @ 12:37
Test Stop : 01/17/2025 @ 13:37
Received: 01/20/2025 @ 11:24
Analyzed: 01/21/2025 @ 10:19

Average of Side by Side Canisters 0.1 pCi/L

Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Francis Hammond M.S.
Test Location: 4646 Seminary Road
Alexandria, VA 22304-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201