

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# : 4949086 Test Start : 01/10/2025 @ 13:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:47
Location : 1st FL = Front Office Received: 01/14/2025 @ 10:24
Radon Level : 0.8 pCi/L Analyzed: 01/15/2025 @ 15:16
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949060 Test Start : 01/10/2025 @ 14:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:48
Location : 1st FL = V.P. Office Received: 01/14/2025 @ 10:24
Radon Level : 0.7 pCi/L Analyzed: 01/15/2025 @ 15:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949062 Test Start : 01/10/2025 @ 14:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:49
Location : 1st FL = Principal's Off. Received: 01/14/2025 @ 10:25
Radon Level : 0.7 pCi/L Analyzed: 01/15/2025 @ 15:47
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949085 Test Start : 01/10/2025 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:50
Location : 1st FL = Library/DP Received: 01/14/2025 @ 10:25
Radon Level : 0.9 pCi/L Analyzed: 01/15/2025 @ 16:39
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949165 Test Start : 01/10/2025 @ 14:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:50
Location : 1st FL = Library/DP Received: 01/14/2025 @ 10:24
Radon Level : 0.8 pCi/L Analyzed: 01/15/2025 @ 15:52

Average of Side by Side Canisters 0.9 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4948934 Test Start : 01/10/2025 @ 14:08
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:51
Location : 1st FL=Library/Break Rm Received: 01/14/2025 @ 10:25
Radon Level : 0.8 pCi/L Analyzed: 01/15/2025 @ 15:16



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4949175	Test Start :	01/10/2025 @ 14:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:53
Location :	1st FL=Library/Off.	Received:	01/14/2025 @ 10:24
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 15:13
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949096	Test Start :	01/10/2025 @ 14:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:54
Location :	1st FL=Library/Storage	Received:	01/14/2025 @ 10:25
Radon Level :	1.3 pCi/L	Analyzed:	01/15/2025 @ 16:19
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949133	Test Start :	01/10/2025 @ 14:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:55
Location :	1st FL = Clinic Office	Received:	01/14/2025 @ 10:25
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:19
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949112	Test Start :	01/10/2025 @ 14:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:56
Location :	1st FL = Clinic	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 15:52
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949061	Test Start :	01/10/2025 @ 14:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:58
Location :	1st FL = 36/Art	Received:	01/14/2025 @ 10:25
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 15:47
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949065	Test Start :	01/10/2025 @ 14:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:59
Location :	1st FL = Staff Break Rm	Received:	01/14/2025 @ 10:24
Radon Level :	0.9 pCi/L	Analyzed:	01/15/2025 @ 16:19



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4948981	Test Start :	01/10/2025 @ 14:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:00
Location :	1st FL = Cafeteria	Received:	01/14/2025 @ 10:25
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 15:29
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949068	Test Start :	01/10/2025 @ 14:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:01
Location :	1st FL = Kitchen	Received:	01/14/2025 @ 10:24
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 16:45
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949074	Test Start :	01/10/2025 @ 14:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:01
Location :	1st FL = Kitchen/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 16:08
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4949093	Test Start :	01/10/2025 @ 14:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:03
Location :	1st FL = Rm 01/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 16:39
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949098	Test Start :	01/10/2025 @ 14:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:03
Location :	1st FL = Rm 01/DP	Received:	01/14/2025 @ 10:25
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 15:47

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# : 4949087 Test Start : 01/10/2025 @ 14:46
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:04
Location : 1st FL = Rm 03 Received: 01/14/2025 @ 10:25
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 16:12
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949070 Test Start : 01/10/2025 @ 14:48
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:06
Location : 1st FL = Rm 05 Received: 01/14/2025 @ 10:25
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 15:47
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949127 Test Start : 01/10/2025 @ 14:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:07
Location : 1st FL = Rm 07 Received: 01/14/2025 @ 10:25
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 15:36
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4949092 Test Start : 01/10/2025 @ 14:52
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:08
Location : 1st FL = Rm 09 Received: 01/14/2025 @ 10:24
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 16:19
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959411 Test Start : 01/10/2025 @ 14:52
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:08
Location : 1st FL = Rm 09/BL Received: 01/14/2025 @ 10:25
Radon Level : 0.1 pCi/L Analyzed: 01/15/2025 @ 15:47
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4949150 Test Start : 01/10/2025 @ 14:57
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:09
Location : 1st FL = Rm 10 Received: 01/14/2025 @ 10:25
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 15:00
Error for Measurement is: \pm 0.1 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# :	4959295	Test Start :	01/10/2025 @ 14:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:12
Location :	1st FL = Rm 11/DP	Received:	01/14/2025 @ 10:25
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 16:39
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959322	Test Start :	01/10/2025 @ 14:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:12
Location :	1st FL = Rm 11/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 16:28

Average of Side by Side Canisters 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4949130	Test Start :	01/10/2025 @ 15:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:13
Location :	1st FL = Rm 13	Received:	01/14/2025 @ 10:25
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 15:36
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959407	Test Start :	01/10/2025 @ 15:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:14
Location :	1st FL = Rm 15	Received:	01/14/2025 @ 10:25
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 15:33
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949106	Test Start :	01/10/2025 @ 15:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:15
Location :	1st FL = Rm 17	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 16:28
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959358	Test Start :	01/10/2025 @ 15:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:17
Location :	1st FL = Rm 18	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 16:45



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959369	Test Start :	01/10/2025 @ 15:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:18
Location :	1st FL = Rm 16	Received:	01/14/2025 @ 10:25
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 16:19
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949140	Test Start :	01/10/2025 @ 15:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:18
Location :	1st FL = Rm 16/Side Rm	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 16:05
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959305	Test Start :	01/10/2025 @ 15:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:20
Location :	1st FL = Rm 14	Received:	01/14/2025 @ 10:25
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 16:19
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959300	Test Start :	01/10/2025 @ 15:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:21
Location :	1st FL = Rm 12	Received:	01/14/2025 @ 10:25
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 15:47
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949118	Test Start :	01/10/2025 @ 15:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:24
Location :	1st FL = Rm 19	Received:	01/14/2025 @ 10:24
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 16:30
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949158	Test Start :	01/10/2025 @ 15:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:24
Location :	1st FL = Rm 20	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:39



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959330	Test Start :	01/10/2025 @ 15:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:25
Location :	1st FL = Rm 21	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:07
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949155	Test Start :	01/10/2025 @ 15:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:26
Location :	1st FL = Rm 22	Received:	01/14/2025 @ 10:25
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 15:21
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949153	Test Start :	01/10/2025 @ 15:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:27
Location :	1st FL = Rm 23	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:39
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949099	Test Start :	01/10/2025 @ 15:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:28
Location :	1st FL = Rm 24/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 16:42
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959327	Test Start :	01/10/2025 @ 15:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:28
Location :	1st FL = Rm 24/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:05

Average of Side by Side Canisters 0.7 pCi/L

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# :	4959311	Test Start :	01/10/2025 @ 15:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:30
Location :	1st FL = Rm 25	Received:	01/14/2025 @ 10:24
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 16:05
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959309	Test Start :	01/10/2025 @ 15:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:30
Location :	1st FL = Rm 26	Received:	01/14/2025 @ 10:25
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 15:29
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959391	Test Start :	01/10/2025 @ 15:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:32
Location :	1st FL = Rm 27	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:45
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959307	Test Start :	01/10/2025 @ 15:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:34
Location :	1st FL = Rm 28	Received:	01/14/2025 @ 10:24
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 16:13
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959348	Test Start :	01/10/2025 @ 15:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:35
Location :	1st FL = Rm 29	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 15:47
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959371	Test Start :	01/10/2025 @ 15:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:36
Location :	1st FL = Rm 30	Received:	01/14/2025 @ 10:25
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 15:47
Error for Measurement is:	± 0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# : 4949113 Test Start : 01/10/2025 @ 15:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:38
Location : 1st FL = Rm 31 Received: 01/14/2025 @ 10:25
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 16:19
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959368 Test Start : 01/10/2025 @ 15:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:38
Location : 1st FL = Rm 31/BL Received: 01/14/2025 @ 10:25
Radon Level : 0.1 pCi/L Analyzed: 01/15/2025 @ 16:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959301 Test Start : 01/10/2025 @ 16:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:40
Location : 1st FL = Rm 32 Received: 01/14/2025 @ 10:25
Radon Level : 0.6 pCi/L Analyzed: 01/15/2025 @ 16:39
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959315 Test Start : 01/10/2025 @ 16:05
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:41
Location : 1st FL = Rm 34 Received: 01/14/2025 @ 10:24
Radon Level : 0.7 pCi/L Analyzed: 01/15/2025 @ 16:56
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959377 Test Start : 01/10/2025 @ 16:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:42
Location : 1st FL = Staff Work Rm Received: 01/14/2025 @ 10:24
Radon Level : 0.5 pCi/L Analyzed: 01/15/2025 @ 16:39
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959329 Test Start : 01/10/2025 @ 16:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:44
Location : 1st FL = Rm 33 Received: 01/14/2025 @ 10:25
Radon Level : 0.6 pCi/L Analyzed: 01/15/2025 @ 12:25
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# : 4959392 Test Start : 01/10/2025 @ 16:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:44
Location : 1st FL = Rm 33 Received: 01/14/2025 @ 10:24
Radon Level : 0.7 pCi/L Analyzed: 01/15/2025 @ 16:25
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4949097 Test Start : 01/10/2025 @ 16:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:46
Location : 1st FL = Rm 35 Received: 01/14/2025 @ 10:25
Radon Level : 0.6 pCi/L Analyzed: 01/15/2025 @ 16:19
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959386 Test Start : 01/10/2025 @ 16:22
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:47
Location : 1st FL = Storage/Left Received: 01/14/2025 @ 10:24
Radon Level : 0.7 pCi/L Analyzed: 01/15/2025 @ 16:43
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959351 Test Start : 01/10/2025 @ 16:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:50
Location : 1st FL = Rm 06 Received: 01/14/2025 @ 10:25
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 16:39
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959381 Test Start : 01/10/2025 @ 16:27
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:49
Location : 1st FL = Rm 04 Received: 01/14/2025 @ 10:25
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 16:25
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4948935 Test Start : 01/10/2025 @ 16:31
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:51
Location : 1st FL = Rm 08 Received: 01/14/2025 @ 10:24
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 16:30
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

Canister ID# :	4949076	Test Start :	01/10/2025 @ 16:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:54
Location :	2nd FL = Rm 46/DP	Received:	01/14/2025 @ 10:25
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 13:18
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4949089	Test Start :	01/10/2025 @ 16:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:54
Location :	2nd FL = Rm 46/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 13:18

Average of Side by Side Canisters 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959361	Test Start :	01/10/2025 @ 16:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:58
Location :	1st FL = Rm 02/DP	Received:	01/14/2025 @ 10:25
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 16:56
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959375	Test Start :	01/10/2025 @ 16:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:58
Location :	1st FL = Rm 02/DP	Received:	01/14/2025 @ 10:25
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 15:27

Average of Side by Side Canisters 0.4 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959299	Test Start :	01/10/2025 @ 16:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:24
Location :	1st FL = Rm 19/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 16:05
Error for Measurement is: ±	0.7 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Cora Kelly E.S.
Test Location: 3600 Commonwealth Avenue
Alexandria, VA 22305-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201