

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4950607	Test Start :	12/16/2024 @ 11:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 11:58
Location :	1st FL = Break Rm	Received:	12/23/2024 @ 12:17
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 10:31
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950604	Test Start :	12/16/2024 @ 11:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 11:59
Location :	1st FL = Front Off./DP	Received:	12/23/2024 @ 12:17
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 11:24
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950625	Test Start :	12/16/2024 @ 11:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 11:59
Location :	1st FL = Front Off./DP	Received:	12/23/2024 @ 12:17
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 12:07

Average of Side by Side Canisters 0.5 pCi/L
Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	4951028	Test Start :	12/16/2024 @ 11:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:03
Location :	1st FL = Mech Rm	Received:	12/23/2024 @ 12:16
Radon Level :	1.9 pCi/L	Analyzed:	12/24/2024 @ 11:00
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	4951067	Test Start :	12/16/2024 @ 11:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:03
Location :	1st FL = Mech Rm/BL	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 11:24
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4951021	Test Start :	12/16/2024 @ 11:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:04
Location :	1st FL = Rm 034	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 10:14



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4950633	Test Start :	12/16/2024 @ 11:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:05
Location :	1st FL = Rm 035	Received:	12/23/2024 @ 12:17
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 11:35
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4950596	Test Start :	12/16/2024 @ 11:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:06
Location :	1st FL = Rm 036/DP	Received:	12/23/2024 @ 12:16
Radon Level :	0.3 pCi/L	Analyzed:	12/24/2024 @ 12:25
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4950609	Test Start :	12/16/2024 @ 11:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:06
Location :	1st FL = Rm 036/DP	Received:	12/23/2024 @ 12:17
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:50

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4951026	Test Start :	12/16/2024 @ 11:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:07
Location :	1st FL = Rm 037	Received:	12/23/2024 @ 12:16
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 10:52
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4951037	Test Start :	12/16/2024 @ 11:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:08
Location :	1st FL = Rm 039	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 10:34
Error for Measurement is: \pm	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4950588	Test Start :	12/16/2024 @ 11:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:20
Location :	1st FL = Rm 050	Received:	12/23/2024 @ 12:16
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 10:11
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	4949032	Test Start :	12/16/2024 @ 11:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:21
Location :	2nd FL = Rm 053/DP	Received:	12/23/2024 @ 12:17
Radon Level :	0.3 pCi/L	Analyzed:	12/24/2024 @ 10:44
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4951041	Test Start :	12/16/2024 @ 11:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:21
Location :	2nd FL = Rm 053/DP	Received:	12/23/2024 @ 12:16
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 10:45

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4951044	Test Start :	12/16/2024 @ 12:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:27
Location :	2nd FL=Rm 030-B(30-A)	Received:	12/23/2024 @ 12:16
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 12:12
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950618	Test Start :	12/16/2024 @ 12:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:28
Location :	2nd FL = Rm 026	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 09:57
Error for Measurement is: ±	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4950624	Test Start :	12/16/2024 @ 12:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:30
Location :	2nd FL = Cafeteria	Received:	12/23/2024 @ 12:16
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 12:25

ABOVE CRAWLSPACE

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4951009	Test Start :	12/16/2024 @ 12:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:30
Location :	2nd FL = Cafeteria/BL	Received:	12/23/2024 @ 12:17
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 11:59

ABOVE CRAWLSPACE

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4950631	Test Start :	12/16/2024 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:30
Location :	2nd FL = Cafeteria Off.	Received:	12/23/2024 @ 12:17
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 11:05

ABOVE CRAWLSPACE

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4950620	Test Start :	12/16/2024 @ 12:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:33
Location :	2nd FL = NRT Office	Received:	12/23/2024 @ 12:17
Radon Level :	0.7 pCi/L	Analyzed:	12/24/2024 @ 10:01

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4948015	Test Start :	12/16/2024 @ 12:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:34
Location :	2nd FL = Librarian Off.	Received:	12/23/2024 @ 12:16
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 11:50

Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4950622	Test Start :	12/16/2024 @ 12:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:35
Location :	2nd FL = Library	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:36

BREAK ROOM

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4951003	Test Start :	12/16/2024 @ 12:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:36
Location :	2nd FL = Rm 023	Received:	12/23/2024 @ 12:17
Radon Level :	0.7 pCi/L	Analyzed:	12/24/2024 @ 12:07

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4950600	Test Start :	12/16/2024 @ 12:13
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:37
Location :	2nd FL = Rm 024	Received:	12/23/2024 @ 12:17
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 11:35

Error for Measurement is: \pm 0.3 pCi/L

Canister ID# :	4950603	Test Start :	12/16/2024 @ 12:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:38
Location :	2nd FL = Library	Received:	12/23/2024 @ 12:16
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 11:21

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4950590	Test Start :	12/16/2024 @ 12:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:39
Location :	2nd FL = Rm 021	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:18

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4950592	Test Start :	12/16/2024 @ 12:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:40
Location :	2nd FL = Rm 017	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:24



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4950623	Test Start :	12/16/2024 @ 12:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:40
Location :	2nd FL = Rm 019	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 12:26
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	4951008	Test Start :	12/16/2024 @ 12:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:41
Location :	2nd FL = Rm 020	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 11:36
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950595	Test Start :	12/16/2024 @ 12:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:44
Location :	2nd FL = Rm 018	Received:	12/23/2024 @ 12:16
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 10:14
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4950602	Test Start :	12/16/2024 @ 12:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:45
Location :	2nd FL = Rm 015	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 11:18
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4951042	Test Start :	12/16/2024 @ 12:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:46
Location :	2nd FL = Rm 016	Received:	12/23/2024 @ 12:16
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 11:00
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950621	Test Start :	12/16/2024 @ 12:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:47
Location :	2nd FL = Rm 014	Received:	12/23/2024 @ 12:16
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 11:35



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.7 pCi/L

Canister ID# :	4950610	Test Start :	12/16/2024 @ 12:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:54
Location :	2nd FL = Rm 013	Received:	12/23/2024 @ 12:16
Radon Level :	1.0 pCi/L	Analyzed:	12/24/2024 @ 11:41
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950627	Test Start :	12/16/2024 @ 12:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:55
Location :	2nd FL = Rm 011	Received:	12/23/2024 @ 12:17
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 10:28
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950636	Test Start :	12/16/2024 @ 12:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:55
Location :	2nd FL = Rm 012	Received:	12/23/2024 @ 12:17
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:41
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4945323	Test Start :	12/16/2024 @ 12:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:56
Location :	2nd FL = Rm 010	Received:	12/23/2024 @ 12:17
Radon Level :	0.7 pCi/L	Analyzed:	12/24/2024 @ 10:01
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950605	Test Start :	12/16/2024 @ 12:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:57
Location :	2nd FL = Rm 009	Received:	12/23/2024 @ 12:17
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 11:59
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4950597	Test Start :	12/16/2024 @ 12:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:58
Location :	2nd FL = Lounge/DP	Received:	12/23/2024 @ 12:16
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 11:35



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4950601	Test Start :	12/16/2024 @ 12:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 12:58
Location :	2nd FL = Lounge/DP	Received:	12/23/2024 @ 12:16
Radon Level :	0.3 pCi/L	Analyzed:	12/24/2024 @ 10:31

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	4948026	Test Start :	12/16/2024 @ 12:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:00
Location :	2nd FL = Rm 008	Received:	12/23/2024 @ 12:16
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 11:01

Error for Measurement is: \pm 0.9 pCi/L

Canister ID# :	4950619	Test Start :	12/16/2024 @ 12:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:01
Location :	2nd FL = Rm 007	Received:	12/23/2024 @ 12:17
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 12:26

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4951052	Test Start :	12/16/2024 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:01
Location :	2nd FL = Rm 006	Received:	12/23/2024 @ 12:16
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 10:14

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4950616	Test Start :	12/16/2024 @ 12:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:02
Location :	2nd FL = Rm 005	Received:	12/23/2024 @ 12:17
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:21

Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4950608	Test Start :	12/16/2024 @ 12:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:03
Location :	2nd FL = Rm 004	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 10:14
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950586	Test Start :	12/16/2024 @ 12:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:03
Location :	2nd FL = Rm 003	Received:	12/23/2024 @ 12:17
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 12:07
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	4950598	Test Start :	12/16/2024 @ 12:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:04
Location :	2nd FL = Rm 002	Received:	12/23/2024 @ 12:16
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 11:37
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	4950614	Test Start :	12/16/2024 @ 12:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 13:04
Location :	2nd FL = Rm 001	Received:	12/23/2024 @ 12:16
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 10:31
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: James K. Polk E.S.
Test Location: 5000 Polk Avenue
Alexandria, VA 22304-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201