

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Canister ID# : 4930366 Test Start : 12/16/2024 @ 09:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:46
Location : 1st FL = Gym Received: 12/20/2024 @ 11:32
Radon Level : 0.3 pCi/L Analyzed: 12/23/2024 @ 12:44
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4930493 Test Start : 12/16/2024 @ 09:48
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:46
Location : 1st FL = Gym Received: 12/20/2024 @ 11:32
Radon Level : 0.1 pCi/L Analyzed: 12/23/2024 @ 14:25
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4930437 Test Start : 12/16/2024 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:17
Location : 1st FL = Aux. Gym Received: 12/20/2024 @ 11:32
Radon Level : 0.4 pCi/L Analyzed: 12/23/2024 @ 14:08
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4930433 Test Start : 12/16/2024 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:16
Location : 1st FL = Rm 153/DP Received: 12/20/2024 @ 11:32
Radon Level : 0.3 pCi/L Analyzed: 12/23/2024 @ 12:31
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4930460 Test Start : 12/16/2024 @ 09:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:16
Location : 1st FL = Rm 153/DP Received: 12/20/2024 @ 11:32
Radon Level : 0.4 pCi/L Analyzed: 12/23/2024 @ 12:58

Average of Side by Side Canisters 0.4 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4915460 Test Start : 12/16/2024 @ 09:56
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:14
Location : 1st FL = Rm 156 Received: 12/20/2024 @ 11:32
Radon Level : 0.1 pCi/L Analyzed: 12/23/2024 @ 14:25



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	4930349	Test Start :	12/16/2024 @ 09:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:13
Location :	1st FL = Rm 143	Received:	12/20/2024 @ 11:32
Radon Level :	0.3 pCi/L	Analyzed:	12/23/2024 @ 12:31
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930411	Test Start :	12/16/2024 @ 10:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:13
Location :	1st FL = Rm 147	Received:	12/20/2024 @ 11:32
Radon Level :	0.1 pCi/L	Analyzed:	12/23/2024 @ 13:34
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	4930375	Test Start :	12/16/2024 @ 10:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:12
Location :	1st FL = Rm 149	Received:	12/20/2024 @ 11:32
Radon Level :	0.2 pCi/L	Analyzed:	12/23/2024 @ 14:08
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4930426	Test Start :	12/16/2024 @ 10:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:12
Location :	1st FL = Rm 148	Received:	12/20/2024 @ 11:32
Radon Level :	0.6 pCi/L	Analyzed:	12/23/2024 @ 12:58
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4930331	Test Start :	12/16/2024 @ 10:04
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:10
Location :	1st FL = Rm 144	Received:	12/20/2024 @ 11:32
Radon Level :	1.0 pCi/L	Analyzed:	12/23/2024 @ 13:55
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930360	Test Start :	12/16/2024 @ 10:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:08
Location :	1st FL = Rm 142/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.1 pCi/L	Analyzed:	12/23/2024 @ 13:21



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4930363	Test Start :	12/16/2024 @ 10:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:08
Location :	1st FL = Rm 142/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.4 pCi/L	Analyzed:	12/23/2024 @ 12:44

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930396	Test Start :	12/16/2024 @ 10:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:07
Location :	1st FL = Rm 138	Received:	12/20/2024 @ 11:32
Radon Level :	0.2 pCi/L	Analyzed:	12/23/2024 @ 14:08

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930374	Test Start :	12/16/2024 @ 10:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:07
Location :	1st FL = Rm 134	Received:	12/20/2024 @ 11:32
Radon Level :	0.4 pCi/L	Analyzed:	12/23/2024 @ 14:14

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930410	Test Start :	12/16/2024 @ 10:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:07
Location :	1st FL = Rm 134/BL	Received:	12/20/2024 @ 11:32
Radon Level :	0.3 pCi/L	Analyzed:	12/23/2024 @ 13:42

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930417	Test Start :	12/16/2024 @ 10:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:06
Location :	1st FL = Rm 132	Received:	12/20/2024 @ 11:32
Radon Level :	0.1 pCi/L	Analyzed:	12/23/2024 @ 14:25

Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Canister ID# : 4930351 Test Start : 12/16/2024 @ 10:14
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:05
Location : 1st FL = Rm 139 Received: 12/20/2024 @ 11:32
Radon Level : 0.3 pCi/L Analyzed: 12/23/2024 @ 13:48
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4930386 Test Start : 12/16/2024 @ 10:15
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:05
Location : 1st FL = Rm 137 Received: 12/20/2024 @ 11:32
Radon Level : 0.1 pCi/L Analyzed: 12/23/2024 @ 12:44
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4930414 Test Start : 12/16/2024 @ 10:17
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:04
Location : 1st FL = Rm 133 Received: 12/20/2024 @ 11:32
Radon Level : 0.1 pCi/L Analyzed: 12/23/2024 @ 14:25
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930358 Test Start : 12/16/2024 @ 10:19
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:03
Location : 1st FL=Rm 128/Theater Received: 12/20/2024 @ 11:32
Radon Level : 0.8 pCi/L Analyzed: 12/23/2024 @ 14:24
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930332 Test Start : 12/16/2024 @ 10:21
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:02
Location : 1st FL=Rm 129/Orchestra Received: 12/20/2024 @ 11:32
Radon Level : 0.7 pCi/L Analyzed: 12/23/2024 @ 14:24
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4930354 Test Start : 12/16/2024 @ 10:22
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:01
Location : 1st FL = Rm 126 Received: 12/20/2024 @ 11:32
Radon Level : 0.5 pCi/L Analyzed: 12/23/2024 @ 13:34
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Canister ID# : 4930372 Test Start : 12/16/2024 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:01
Location : 1st FL = Rm 123 Received: 12/20/2024 @ 11:32
Radon Level : 0.4 pCi/L Analyzed: 12/23/2024 @ 13:34
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 4930367 Test Start : 12/16/2024 @ 10:26
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:00
Location : 1st FL = Rm 118 Received: 12/20/2024 @ 11:32
Radon Level : 0.5 pCi/L Analyzed: 12/23/2024 @ 13:48
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4930406 Test Start : 12/16/2024 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:59
Location : 1st FL = Rm 116/DP Received: 12/20/2024 @ 11:32
Radon Level : 1.1 pCi/L Analyzed: 12/23/2024 @ 13:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4930435 Test Start : 12/16/2024 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:59
Location : 1st FL = Rm 116/DP Received: 12/20/2024 @ 11:32
Radon Level : 0.8 pCi/L Analyzed: 12/23/2024 @ 14:24

Average of Side by Side Canisters 1.0 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4930369 Test Start : 12/16/2024 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:58
Location : 1st FL = Rm 112 Received: 12/20/2024 @ 11:32
Radon Level : 0.1 pCi/L Analyzed: 12/23/2024 @ 12:57
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 4930365 Test Start : 12/16/2024 @ 10:28
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:59
Location : 1st FL = Rm 114 Received: 12/20/2024 @ 11:32
Radon Level : 0.6 pCi/L Analyzed: 12/23/2024 @ 12:57



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4930373	Test Start :	12/16/2024 @ 10:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:57
Location :	1st FL = Rm 119	Received:	12/20/2024 @ 11:32
Radon Level :	0.8 pCi/L	Analyzed:	12/23/2024 @ 13:55
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4930370	Test Start :	12/16/2024 @ 10:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:55
Location :	1st FL = Rm 117-F	Received:	12/20/2024 @ 11:32
Radon Level :	1.1 pCi/L	Analyzed:	12/23/2024 @ 13:55
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	4930371	Test Start :	12/16/2024 @ 10:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:55
Location :	1st FL = Rm 117-P	Received:	12/20/2024 @ 11:32
Radon Level :	0.5 pCi/L	Analyzed:	12/23/2024 @ 12:57
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4930356	Test Start :	12/16/2024 @ 10:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:54
Location :	1st FL = Rm 117-C	Received:	12/20/2024 @ 11:32
Radon Level :	0.1 pCi/L	Analyzed:	12/23/2024 @ 12:57
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	4930463	Test Start :	12/16/2024 @ 10:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:54
Location :	1st FL = Nurse	Received:	12/20/2024 @ 11:32
Radon Level :	0.7 pCi/L	Analyzed:	12/23/2024 @ 14:24
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	4930429	Test Start :	12/16/2024 @ 10:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:54
Location :	1st FL = Nurse/BL	Received:	12/20/2024 @ 11:32
Radon Level :	0.2 pCi/L	Analyzed:	12/23/2024 @ 14:08



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4930413	Test Start :	12/16/2024 @ 10:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:52
Location :	1st FL = Rm 117-A	Received:	12/20/2024 @ 11:32
Radon Level :	1.1 pCi/L	Analyzed:	12/23/2024 @ 13:42
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930350	Test Start :	12/16/2024 @ 10:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:51
Location :	1st FL = Rm 110-I	Received:	12/20/2024 @ 11:32
Radon Level :	1.1 pCi/L	Analyzed:	12/23/2024 @ 13:55
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930352	Test Start :	12/16/2024 @ 10:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:51
Location :	1st FL = Rm 110-H	Received:	12/20/2024 @ 11:32
Radon Level :	0.5 pCi/L	Analyzed:	12/23/2024 @ 14:08
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	4930400	Test Start :	12/16/2024 @ 10:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:51
Location :	1st FL = Mail Rm	Received:	12/20/2024 @ 11:32
Radon Level :	1.5 pCi/L	Analyzed:	12/23/2024 @ 12:31
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930333	Test Start :	12/16/2024 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:50
Location :	1st FL = Rm 110-B/DP	Received:	12/20/2024 @ 11:32
Radon Level :	1.2 pCi/L	Analyzed:	12/23/2024 @ 13:21
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4930387	Test Start :	12/16/2024 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:50
Location :	1st FL = Rm 110-B/DP	Received:	12/20/2024 @ 11:32
Radon Level :	1.4 pCi/L	Analyzed:	12/23/2024 @ 14:14



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Average of Side by Side Canisters 1.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930422	Test Start :	12/16/2024 @ 10:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:49
Location :	1st FL = Rm 108	Received:	12/20/2024 @ 11:32
Radon Level :	0.8 pCi/L	Analyzed:	12/23/2024 @ 14:01
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4930399	Test Start :	12/16/2024 @ 10:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:47
Location :	1st FL = Cafeteria	Received:	12/20/2024 @ 11:32
Radon Level :	0.4 pCi/L	Analyzed:	12/23/2024 @ 12:44
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4930415	Test Start :	12/16/2024 @ 10:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:48
Location :	1st FL = Kitchen	Received:	12/20/2024 @ 11:32
Radon Level :	0.6 pCi/L	Analyzed:	12/23/2024 @ 14:01
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4930407	Test Start :	12/16/2024 @ 10:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:48
Location :	1st FL=Kitchen Mgr.Off.	Received:	12/20/2024 @ 11:32
Radon Level :	0.5 pCi/L	Analyzed:	12/23/2024 @ 14:08
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	4930376	Test Start :	12/16/2024 @ 10:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 09:56
Location :	1st FL = Rm 117-E	Received:	12/20/2024 @ 11:32
Radon Level :	0.9 pCi/L	Analyzed:	12/23/2024 @ 13:48
Error for Measurement is: ±	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Canister ID# : 4930379 Test Start : 12/16/2024 @ 10:55
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 09:48
Location : 1st FL = Rm 107/Janitor Off. Received: 12/20/2024 @ 11:32
Radon Level : 0.6 pCi/L Analyzed: 12/23/2024 @ 14:01
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930330 Test Start : 12/16/2024 @ 10:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:20
Location : 2nd FL = Rm 201/DP Received: 12/20/2024 @ 11:32
Radon Level : 0.4 pCi/L Analyzed: 12/23/2024 @ 12:31
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930420 Test Start : 12/16/2024 @ 10:59
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:20
Location : 2nd FL = Rm 201/DP Received: 12/20/2024 @ 11:32
Radon Level : 0.6 pCi/L Analyzed: 12/23/2024 @ 13:42

Average of Side by Side Canisters 0.5 pCi/L
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930341 Test Start : 12/16/2024 @ 11:02
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:23
Location : 2nd FL = Rm 213 Received: 12/20/2024 @ 11:32
Radon Level : 0.6 pCi/L Analyzed: 12/23/2024 @ 14:14
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930398 Test Start : 12/16/2024 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:25
Location : 2nd FL = Rm 226 Received: 12/20/2024 @ 11:32
Radon Level : 0.4 pCi/L Analyzed: 12/23/2024 @ 13:48
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4930464 Test Start : 12/16/2024 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 12/18/2024 @ 10:25
Location : 2nd FL = Rm 226/BL Received: 12/20/2024 @ 11:32
Radon Level : 0.2 pCi/L Analyzed: 12/23/2024 @ 12:58



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930339	Test Start :	12/16/2024 @ 11:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:27
Location :	2nd FL=Rm 237-A/Library/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.2 pCi/L	Analyzed:	12/23/2024 @ 14:08
Error for Measurement is: ± 0.5 pCi/L			

Canister ID# :	4930342	Test Start :	12/16/2024 @ 11:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:27
Location :	2nd FL=Rm 237-A/Library/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.4 pCi/L	Analyzed:	12/23/2024 @ 13:21

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4930380	Test Start :	12/16/2024 @ 11:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:29
Location :	3rd FL = Rm 300/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.7 pCi/L	Analyzed:	12/23/2024 @ 13:21
Error for Measurement is: ± 0.4 pCi/L			

Canister ID# :	4930384	Test Start :	12/16/2024 @ 11:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:29
Location :	3rd FL = Rm 300/DP	Received:	12/20/2024 @ 11:32
Radon Level :	0.2 pCi/L	Analyzed:	12/23/2024 @ 13:34

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4930424	Test Start :	12/16/2024 @ 11:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:31
Location :	3rd FL=Rm 319/Copy Rm	Received:	12/20/2024 @ 11:32
Radon Level :	0.3 pCi/L	Analyzed:	12/23/2024 @ 12:58
Error for Measurement is: ± 0.4 pCi/L			



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 12/20/2024

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Jefferson-Houston PreK-8 IB School
Test Location: 1501 Cameron Street
Alexandria, VA 22314-

Individual Canister Results

Canister ID# :	4930353	Test Start :	12/16/2024 @ 11:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:31
Location :	3rd FL = Rm 318	Received:	12/20/2024 @ 11:32
Radon Level :	0.5 pCi/L	Analyzed:	12/23/2024 @ 14:01
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4930364	Test Start :	12/16/2024 @ 11:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/18/2024 @ 10:32
Location :	3rd FL = Rm 320	Received:	12/20/2024 @ 11:32
Radon Level :	0.5 pCi/L	Analyzed:	12/23/2024 @ 14:08
Error for Measurement is: ±	0.4 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201