

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4959372	Test Start :	01/10/2025 @ 10:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:54
Location :	1st FL = 159/Lobby	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:33
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959342	Test Start :	01/10/2025 @ 10:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:54
Location :	1st FL = 159/Lobby/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 11:55
Error for Measurement is:	± 0.7 pCi/L		

Canister ID# :	4959310	Test Start :	01/10/2025 @ 10:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:35
Location :	1st FL = 160	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:41
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959389	Test Start :	01/10/2025 @ 10:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:56
Location :	1st FL = 162/Conf.Rm	Received:	01/14/2025 @ 10:23
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:43
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959359	Test Start :	01/10/2025 @ 10:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:57
Location :	1st FL = 163/Conf.Rm	Received:	01/14/2025 @ 10:23
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 10:58
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959395	Test Start :	01/10/2025 @ 10:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:58
Location :	1st FL = 158-B/Mail Rm	Received:	01/14/2025 @ 10:23
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 11:54
Error for Measurement is:	± 0.7 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4959356	Test Start :	01/10/2025 @ 10:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:00
Location :	1st FL = 151/Health/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 10:46

SAMPLES FOUND MOVED

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959402	Test Start :	01/10/2025 @ 10:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:00
Location :	1st FL = 151/Health/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 13:30

SAMPLES FOUND MOVED

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959355	Test Start :	01/10/2025 @ 11:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:01
Location :	1st FL = 155/Exam Rm	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 11:12

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959332	Test Start :	01/10/2025 @ 11:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:02
Location :	1st FL = 152	Received:	01/14/2025 @ 10:23
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 10:58

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959405	Test Start :	01/10/2025 @ 11:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:02
Location :	1st FL = 153/Dental	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:43

Error for Measurement is: \pm 0.1 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Canister ID# : 4959412 Test Start : 01/10/2025 @ 11:06
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:03
Location : 1st FL = 154 Received: 01/14/2025 @ 10:24
Radon Level : 0.1 pCi/L Analyzed: 01/15/2025 @ 11:33
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959363 Test Start : 01/10/2025 @ 11:10
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:05
Location : 1st FL = 146/Music Received: 01/14/2025 @ 10:24
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 13:16
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959393 Test Start : 01/10/2025 @ 11:12
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:06
Location : 1st FL = 145/Music Received: 01/14/2025 @ 10:24
Radon Level : 0.4 pCi/L Analyzed: 01/15/2025 @ 13:30
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959350 Test Start : 01/10/2025 @ 11:14
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:07
Location : 1st FL = 144/Music/DP Received: 01/14/2025 @ 10:24
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 11:12
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959401 Test Start : 01/10/2025 @ 11:14
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:07
Location : 1st FL = 144/Music/DP Received: 01/14/2025 @ 10:24
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 10:46

Average of Side by Side Canisters 0.3 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959396 Test Start : 01/10/2025 @ 11:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:08
Location : 1st FL = Gym Received: 01/14/2025 @ 10:24
Radon Level : 0.3 pCi/L Analyzed: 01/15/2025 @ 11:43



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959367	Test Start :	01/10/2025 @ 11:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:08
Location :	1st FL = Gym/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 11:55
Error for Measurement is: \pm	0.7 pCi/L		

Canister ID# :	4959352	Test Start :	01/10/2025 @ 11:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:10
Location :	1st FL = 143/Multi.Purp.	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:12
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959408	Test Start :	01/10/2025 @ 11:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:12
Location :	1st FL = 138/Storage	Received:	01/14/2025 @ 10:23
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 11:33
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959365	Test Start :	01/10/2025 @ 11:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:14
Location :	1st FL = 147	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:41
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959416	Test Start :	01/10/2025 @ 11:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:15
Location :	1st FL = 105/Serving	Received:	01/14/2025 @ 10:23
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:01
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959357	Test Start :	01/10/2025 @ 11:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:16
Location :	1st FL = 106/Kitchen/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 10:46



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959360	Test Start :	01/10/2025 @ 11:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:16
Location :	1st FL = 106/Kitchen/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:19

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959319	Test Start :	01/10/2025 @ 11:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:18
Location :	1st FL = 109/Cafeteria	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:12

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959398	Test Start :	01/10/2025 @ 11:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:20
Location :	1st FL=115/Bldg.Svcs.	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:54

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959346	Test Start :	01/10/2025 @ 11:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:20
Location :	1st FL=115B/Bldg.Svc.Off.	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:41

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959339	Test Start :	01/10/2025 @ 11:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:23
Location :	1st FL = 124/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:28

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4959397	Test Start :	01/10/2025 @ 11:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:23
Location :	1st FL = 124/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:12

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959394	Test Start :	01/10/2025 @ 11:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:24
Location :	1st FL = 125	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:54

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959404	Test Start :	01/10/2025 @ 11:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:26
Location :	1st FL = 126	Received:	01/14/2025 @ 10:24
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 11:43

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959294	Test Start :	01/10/2025 @ 11:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:27
Location :	1st FL = 127	Received:	01/14/2025 @ 10:23
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:28

Error for Measurement is: ± 0.1 pCi/L

Canister ID# :	4959293	Test Start :	01/10/2025 @ 11:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:27
Location :	1st FL = 128	Received:	01/14/2025 @ 10:23
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 12:12

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959318	Test Start :	01/10/2025 @ 11:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:29
Location :	1st FL = 129	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:19



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959409	Test Start :	01/10/2025 @ 11:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:29
Location :	1st FL = 129/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 13:30
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	4959413	Test Start :	01/10/2025 @ 11:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:30
Location :	1st FL = 130	Received:	01/14/2025 @ 10:23
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:01
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959325	Test Start :	01/10/2025 @ 11:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:31
Location :	1st FL = 131	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:28
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959366	Test Start :	01/10/2025 @ 12:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:33
Location :	1st FL = 132	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:33
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959320	Test Start :	01/10/2025 @ 12:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:34
Location :	1st FL = 133	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 12:12
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959382	Test Start :	01/10/2025 @ 12:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:35
Location :	1st FL = 134	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:12



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959390	Test Start :	01/10/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:36
Location :	1st FL = 136/Art/DP	Received:	01/14/2025 @ 10:23
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 11:33
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959406	Test Start :	01/10/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:36
Location :	1st FL = 136/Art/DP	Received:	01/14/2025 @ 10:23
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 10:46

Average of Side by Side Canisters 0.7 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959331	Test Start :	01/10/2025 @ 12:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:38
Location :	2nd FL = 222/Library	Received:	01/14/2025 @ 10:23
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 10:58
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959333	Test Start :	01/10/2025 @ 12:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:42
Location :	2nd FL = 222/Resource	Received:	01/14/2025 @ 10:23
Radon Level :	0.5 pCi/L	Analyzed:	01/15/2025 @ 11:01
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959364	Test Start :	01/10/2025 @ 12:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:42
Location :	2nd FL=222/Resource/BL	Received:	01/14/2025 @ 10:24
Radon Level :	0.1 pCi/L	Analyzed:	01/15/2025 @ 11:41
Error for Measurement is: ±	0.6 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4959383	Test Start :	01/10/2025 @ 12:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:46
Location :	2nd FL = 210/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:33
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959410	Test Start :	01/10/2025 @ 12:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:46
Location :	2nd FL = 210/DP	Received:	01/14/2025 @ 10:23
Radon Level :	0.1 pCi/L	Analyzed:	01/14/2025 @ 16:44

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.1 pCi/L

Canister ID# :	4959415	Test Start :	01/10/2025 @ 12:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:47
Location :	3rd FL = 312	Received:	01/14/2025 @ 10:23
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 10:58
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959345	Test Start :	01/10/2025 @ 12:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:50
Location :	3rd FL = 322	Received:	01/14/2025 @ 10:24
Radon Level :	0.3 pCi/L	Analyzed:	01/15/2025 @ 11:19
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959334	Test Start :	01/10/2025 @ 12:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:52
Location :	3rd FL = 339/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 13:16
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959414	Test Start :	01/10/2025 @ 12:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:52
Location :	3rd FL = 339/DP	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:54



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

Average of Side by Side Canisters 0.2 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959380	Test Start :	01/10/2025 @ 12:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:54
Location :	3rd FL = 302/Work Rm	Received:	01/14/2025 @ 10:24
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:12
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959354	Test Start :	01/10/2025 @ 12:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:58
Location :	1st FL = 121/Work Rm	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 13:30
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959362	Test Start :	01/10/2025 @ 12:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:59
Location :	1st FL = 161/Principal	Received:	01/14/2025 @ 10:24
Radon Level :	0.2 pCi/L	Analyzed:	01/15/2025 @ 11:28
Error for Measurement is: ±	0.1 pCi/L		

Canister ID# :	4959306	Test Start :	01/10/2025 @ 12:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:03
Location :	1st FL = 101	Received:	01/14/2025 @ 10:23
Radon Level :	0.4 pCi/L	Analyzed:	01/15/2025 @ 11:12
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Douglas MacArthur E.S.
Test Location: 1101 Janney's Lane
Alexandria, VA 22302-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201