

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Canister ID# : 4950167 Test Start : 12/17/2024 @ 14:12  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:38  
Location : 2nd FL=Tech.Office/DP Received: 12/23/2024 @ 12:36  
Radon Level : 0.4 pCi/L Analyzed: 12/24/2024 @ 15:13  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4950469 Test Start : 12/17/2024 @ 14:12  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:38  
Location : 2nd FL=Tech.Office/DP Received: 12/23/2024 @ 12:36  
Radon Level : 0.5 pCi/L Analyzed: 12/24/2024 @ 14:43

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4950513 Test Start : 12/17/2024 @ 14:13  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:39  
Location : 2nd FL = Library Off. Received: 12/23/2024 @ 12:36  
Radon Level : 0.7 pCi/L Analyzed: 12/24/2024 @ 15:13  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4950524 Test Start : 12/17/2024 @ 14:13  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:39  
Location : 2nd FL=Library Off/BL Received: 12/23/2024 @ 12:36  
Radon Level : 0.1 pCi/L Analyzed: 12/24/2024 @ 14:58  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4950424 Test Start : 12/17/2024 @ 14:15  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:40  
Location : 1st FL = Rm 10 Received: 12/23/2024 @ 12:36  
Radon Level : 0.4 pCi/L Analyzed: 12/24/2024 @ 14:27  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950423 Test Start : 12/17/2024 @ 14:16  
Canister Type : Charcoal Canister 3 inch Test Stop : 12/19/2024 @ 14:41  
Location : 1st FL = Rm 18 Received: 12/23/2024 @ 12:36  
Radon Level : 0.6 pCi/L Analyzed: 12/24/2024 @ 14:45



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4950436	Test Start :	12/17/2024 @ 14:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:41
Location :	1st FL = Rm 17/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.8 pCi/L	Analyzed:	12/24/2024 @ 15:12
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950503	Test Start :	12/17/2024 @ 14:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:41
Location :	1st FL = Rm 17/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:40

Average of Side by Side Canisters 0.7 pCi/L

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4950428	Test Start :	12/17/2024 @ 14:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:42
Location :	1st FL = Rm 16	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 14:45
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950471	Test Start :	12/17/2024 @ 14:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:43
Location :	1st FL = Moquin's Class	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 15:12
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950527	Test Start :	12/17/2024 @ 14:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:44
Location :	1st FL = Rm 12	Received:	12/23/2024 @ 12:36
Radon Level :	1.1 pCi/L	Analyzed:	12/24/2024 @ 14:45
Error for Measurement is: ±	0.4 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4950505	Test Start :	12/17/2024 @ 14:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:44
Location :	1st FL = Rm 11	Received:	12/23/2024 @ 12:36
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 14:25
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	4950506	Test Start :	12/17/2024 @ 14:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:45
Location :	1st FL = Rm 13	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	4950502	Test Start :	12/17/2024 @ 14:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:45
Location :	1st FL = Rm 13/BL	Received:	12/23/2024 @ 12:36
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 14:14
Error for Measurement is:	± 0.3 pCi/L		

Canister ID# :	4950188	Test Start :	12/17/2024 @ 14:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:46
Location :	1st FL = Rm 15	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:57
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	4950533	Test Start :	12/17/2024 @ 14:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:47
Location :	1st FL = Rm 19	Received:	12/23/2024 @ 12:36
Radon Level :	2.6 pCi/L	Analyzed:	12/24/2024 @ 13:58
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	4950171	Test Start :	12/17/2024 @ 14:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:48
Location :	1st FL = Rm 20	Received:	12/23/2024 @ 12:36
Radon Level :	1.0 pCi/L	Analyzed:	12/24/2024 @ 14:27
Error for Measurement is:	± 0.4 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4950155	Test Start :	12/17/2024 @ 14:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:49
Location :	1st FL = Rm 21	Received:	12/23/2024 @ 12:36
Radon Level :	1.3 pCi/L	Analyzed:	12/24/2024 @ 14:45
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950480	Test Start :	12/17/2024 @ 14:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:49
Location :	1st FL = Cafeteria/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.2 pCi/L	Analyzed:	12/24/2024 @ 14:57
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950488	Test Start :	12/17/2024 @ 14:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:49
Location :	1st FL = Cafeteria/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 14:57

Average of Side by Side Canisters 0.4 pCi/L  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4950496	Test Start :	12/17/2024 @ 14:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:50
Location :	1st FL = Cafeteria	Received:	12/23/2024 @ 12:36
Radon Level :	0.7 pCi/L	Analyzed:	12/24/2024 @ 14:57
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950473	Test Start :	12/17/2024 @ 14:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:51
Location :	1st FL = Custodial Off.	Received:	12/23/2024 @ 12:36
Radon Level :	0.8 pCi/L	Analyzed:	12/24/2024 @ 14:27
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950519	Test Start :	12/17/2024 @ 14:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:52
Location :	1st FL = Rm 23	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 14:40



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

### Individual Canister Results

Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# :	4950421	Test Start :	12/17/2024 @ 14:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:52
Location :	1st FL = Rm 23/BL	Received:	12/23/2024 @ 12:36
Radon Level :	0.1 pCi/L	Analyzed:	12/24/2024 @ 14:43
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950501	Test Start :	12/17/2024 @ 14:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:53
Location :	1st FL = Rm 25	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:58
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950484	Test Start :	12/17/2024 @ 14:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:54
Location :	1st FL = Rm 27	Received:	12/23/2024 @ 12:36
Radon Level :	0.7 pCi/L	Analyzed:	12/24/2024 @ 11:50
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950525	Test Start :	12/17/2024 @ 14:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:54
Location :	1st FL = Rm 26/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.9 pCi/L	Analyzed:	12/24/2024 @ 14:30
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950529	Test Start :	12/17/2024 @ 14:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:54
Location :	1st FL = Rm 26/DP	Received:	12/23/2024 @ 12:36
Radon Level :	0.8 pCi/L	Analyzed:	12/24/2024 @ 14:57

Average of Side by Side Canisters 0.9 pCi/L

Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4950500	Test Start :	12/17/2024 @ 14:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:55
Location :	1st FL = Rm 24	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 14:30
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950058	Test Start :	12/17/2024 @ 14:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:56
Location :	1st FL = Rm 22	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:43
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950493	Test Start :	12/17/2024 @ 14:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:57
Location :	1st FL = Rm 28	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 13:58
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950466	Test Start :	12/17/2024 @ 14:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:58
Location :	1st FL = Rm 29	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4949081	Test Start :	12/17/2024 @ 14:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:59
Location :	1st FL = Rm 31	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 14:14
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4949779	Test Start :	12/17/2024 @ 14:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 14:59
Location :	1st FL = Rm 30	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is: ±	0.5 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Canister ID# :	4948115	Test Start :	12/17/2024 @ 14:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:00
Location :	1st FL = Gym	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 11:50
NEAR WALL			

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4950520	Test Start :	12/17/2024 @ 14:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:17
Location :	1st FL = PE Office	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 14:57
Error for Measurement is: ± 0.5 pCi/L			

Canister ID# :	4949632	Test Start :	12/17/2024 @ 14:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:01
Location :	1st FL = Rm 09-A	Received:	12/23/2024 @ 12:36
Radon Level :	0.6 pCi/L	Analyzed:	12/24/2024 @ 14:30
TEACHERS LOUNGE			

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4950443	Test Start :	12/17/2024 @ 14:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:02
Location :	1st FL = Rm 09	Received:	12/23/2024 @ 12:36
Radon Level :	0.4 pCi/L	Analyzed:	12/24/2024 @ 15:12
Error for Measurement is: ± 0.4 pCi/L			

Canister ID# :	4950068	Test Start :	12/17/2024 @ 14:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:03
Location :	1st FL = Reading Rm	Received:	12/23/2024 @ 12:36
Radon Level :	1.5 pCi/L	Analyzed:	12/24/2024 @ 14:25
Error for Measurement is: ± 0.5 pCi/L			



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

### Individual Canister Results

Canister ID# :	4948040	Test Start :	12/17/2024 @ 14:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:03
Location :	1st FL = R-01 & R-02/DP	Received:	12/23/2024 @ 12:36
Radon Level :	2.1 pCi/L	Analyzed:	12/24/2024 @ 14:30
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4949826	Test Start :	12/17/2024 @ 14:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:03
Location :	1st FL = R-01 & R-02/DP	Received:	12/23/2024 @ 12:36
Radon Level :	2.1 pCi/L	Analyzed:	12/24/2024 @ 14:14

Average of Side by Side Canisters 2.1 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4949115	Test Start :	12/17/2024 @ 14:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:03
Location :	1st FL = R-03	Received:	12/23/2024 @ 12:36
Radon Level :	1.7 pCi/L	Analyzed:	12/24/2024 @ 14:14
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950617	Test Start :	12/17/2024 @ 15:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:04
Location :	1st FL = R-04	Received:	12/23/2024 @ 12:36
Radon Level :	2.1 pCi/L	Analyzed:	12/24/2024 @ 14:27
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4951033	Test Start :	12/17/2024 @ 15:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:03
Location :	1st FL = R-05	Received:	12/23/2024 @ 12:36
Radon Level :	2.1 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4948936	Test Start :	12/17/2024 @ 15:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:06
Location :	1st FL = Rm 03	Received:	12/23/2024 @ 12:36
Radon Level :	1.0 pCi/L	Analyzed:	12/24/2024 @ 14:57



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

### Individual Canister Results

Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# :	4950460	Test Start :	12/17/2024 @ 15:04
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:11
Location :	1st FL = Rm 08	Received:	12/23/2024 @ 12:36
Radon Level :	0.3 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is:	$\pm$ 0.5 pCi/L		

Canister ID# :	4949111	Test Start :	12/17/2024 @ 15:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:12
Location :	1st FL = Rm 04	Received:	12/23/2024 @ 12:36
Radon Level :	0.5 pCi/L	Analyzed:	12/24/2024 @ 14:43
Error for Measurement is:	$\pm$ 0.4 pCi/L		

Canister ID# :	4950144	Test Start :	12/17/2024 @ 15:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:12
Location :	1st FL=Asst. Principal	Received:	12/23/2024 @ 12:36
Radon Level :	0.9 pCi/L	Analyzed:	12/24/2024 @ 15:13
Error for Measurement is:	$\pm$ 0.5 pCi/L		

Canister ID# :	4950216	Test Start :	12/17/2024 @ 15:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:13
Location :	1st FL = Front Office	Received:	12/23/2024 @ 12:36
Radon Level :	1.0 pCi/L	Analyzed:	12/24/2024 @ 14:40
Error for Measurement is:	$\pm$ 0.5 pCi/L		

Canister ID# :	4949796	Test Start :	12/17/2024 @ 15:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:16
Location :	1st FL = Rm 06	Received:	12/23/2024 @ 12:36
Radon Level :	0.3 pCi/L	Analyzed:	12/24/2024 @ 15:12
Error for Measurement is:	$\pm$ 0.4 pCi/L		

Canister ID# :	4948006	Test Start :	12/17/2024 @ 15:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:16
Location :	1st FL=Breastfeeding Rm	Received:	12/23/2024 @ 12:36
Radon Level :	1.1 pCi/L	Analyzed:	12/24/2024 @ 14:57



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 12/23/2024

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: George Mason E.S.  
Test Location: 2601 Cameron Mills Road  
Alexandria, VA 22302-

Individual Canister Results

Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# :	4951004	Test Start :	12/17/2024 @ 15:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	12/19/2024 @ 15:34
Location :	1st FL = Rm 03-A	Received:	12/23/2024 @ 12:36
Radon Level :	0.9 pCi/L	Analyzed:	12/24/2024 @ 14:58
Error for Measurement is: $\pm$	0.4 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon ([www.epa.gov/radon/pubs/citguide.html](http://www.epa.gov/radon/pubs/citguide.html)). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201