

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959151 Test Start : 01/10/2025 @ 09:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:19
Location : 1st FL=C-103 Received: 01/14/2025 @ 10:38
Radon Level : 1.7 pCi/L Analyzed: 01/14/2025 @ 15:53
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959460 Test Start : 01/10/2025 @ 09:36
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:20
Location : 1st FL=C-104 Received: 01/14/2025 @ 10:38
Radon Level : 1.5 pCi/L Analyzed: 01/14/2025 @ 15:21
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959485 Test Start : 01/10/2025 @ 09:37
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:21
Location : 1st FL=C-106 Received: 01/14/2025 @ 10:38
Radon Level : 1.7 pCi/L Analyzed: 01/14/2025 @ 15:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959473 Test Start : 01/10/2025 @ 09:38
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:23
Location : 1st FL=C-101 Received: 01/14/2025 @ 10:38
Radon Level : 1.1 pCi/L Analyzed: 01/14/2025 @ 15:26
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959459 Test Start : 01/10/2025 @ 09:40
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:24
Location : 1st FL=C-105 Received: 01/14/2025 @ 10:38
Radon Level : 1.8 pCi/L Analyzed: 01/14/2025 @ 15:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959508 Test Start : 01/10/2025 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:25
Location : 1st FL=C-107 Received: 01/14/2025 @ 10:38
Radon Level : 1.3 pCi/L Analyzed: 01/14/2025 @ 15:04
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959453 Test Start : 01/10/2025 @ 09:41
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:28
Location : 1st FL=C-110 Received: 01/14/2025 @ 10:38
Radon Level : 2.3 pCi/L Analyzed: 01/14/2025 @ 16:50
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959156 Test Start : 01/10/2025 @ 09:42
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:31
Location : 1st FL=C-109 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 16:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959663 Test Start : 01/10/2025 @ 09:44
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:32
Location : 1st FL=C-111 Received: 01/14/2025 @ 10:38
Radon Level : 0.9 pCi/L Analyzed: 01/14/2025 @ 16:37
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959471 Test Start : 01/10/2025 @ 09:46
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:34
Location : 1st FL=C-113/Malone Received: 01/14/2025 @ 10:38
Radon Level : 0.6 pCi/L Analyzed: 01/14/2025 @ 14:38
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959579 Test Start : 01/10/2025 @ 09:47
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:36
Location : 1st FL=C-113/Jackson Received: 01/14/2025 @ 10:38
Radon Level : 0.4 pCi/L Analyzed: 01/14/2025 @ 15:26
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 4959115 Test Start : 01/10/2025 @ 09:49
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:38
Location : 1st FL=C-113/Rick Received: 01/14/2025 @ 10:38
Radon Level : 0.4 pCi/L Analyzed: 01/14/2025 @ 15:26
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959475 Test Start : 01/10/2025 @ 09:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:40
Location : 1st FL=C-113/Hampton Received: 01/14/2025 @ 10:38
Radon Level : 0.5 pCi/L Analyzed: 01/15/2025 @ 10:06
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959515 Test Start : 01/10/2025 @ 09:51
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:41
Location : 1st FL=C-113/Main Off. Received: 01/14/2025 @ 10:38
Radon Level : 0.6 pCi/L Analyzed: 01/14/2025 @ 14:55
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 4959447 Test Start : 01/10/2025 @ 09:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:43
Location : 1st FL=C-119/DP Received: 01/14/2025 @ 10:38
Radon Level : 1.6 pCi/L Analyzed: 01/14/2025 @ 15:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959509 Test Start : 01/10/2025 @ 09:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:43
Location : 1st FL=C-119/DP Received: 01/14/2025 @ 10:38
Radon Level : 1.5 pCi/L Analyzed: 01/14/2025 @ 16:44

Average of Side by Side Canisters 1.6 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959478 Test Start : 01/10/2025 @ 10:03
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:53
Location : 1st FL=C-121 Received: 01/14/2025 @ 10:38
Radon Level : 0.5 pCi/L Analyzed: 01/14/2025 @ 15:39
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959665 Test Start : 01/10/2025 @ 10:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 09:55
Location : 1st FL=C-116 Received: 01/14/2025 @ 10:38
Radon Level : 0.5 pCi/L Analyzed: 01/14/2025 @ 16:29



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959633	Test Start :	01/10/2025 @ 10:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:58
Location :	1st FL=C-118	Received:	01/14/2025 @ 10:38
Radon Level :	0.6 pCi/L	Analyzed:	01/14/2025 @ 15:22
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959464	Test Start :	01/10/2025 @ 10:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:58
Location :	1st FL=C-118/BL	Received:	01/14/2025 @ 10:38
Radon Level :	0.1 pCi/L	Analyzed:	01/14/2025 @ 16:06
Error for Measurement is: \pm	0.1 pCi/L		

Canister ID# :	4959458	Test Start :	01/10/2025 @ 10:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 09:59
Location :	1st FL=C-120	Received:	01/14/2025 @ 10:38
Radon Level :	1.6 pCi/L	Analyzed:	01/14/2025 @ 16:37
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959483	Test Start :	01/10/2025 @ 10:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:01
Location :	1st FL=C-122	Received:	01/14/2025 @ 10:38
Radon Level :	1.2 pCi/L	Analyzed:	01/14/2025 @ 16:17
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959472	Test Start :	01/10/2025 @ 10:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:02
Location :	1st FL=C-123	Received:	01/14/2025 @ 10:38
Radon Level :	2.1 pCi/L	Analyzed:	01/14/2025 @ 15:53
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959452	Test Start :	01/10/2025 @ 10:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:03
Location :	1st FL=C-124	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 14:50



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959463	Test Start :	01/10/2025 @ 10:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:03
Location :	1st FL=C-125/DP	Received:	01/14/2025 @ 10:38
Radon Level :	2.3 pCi/L	Analyzed:	01/14/2025 @ 15:08
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959635	Test Start :	01/10/2025 @ 10:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:03
Location :	1st FL=C-125/DP	Received:	01/14/2025 @ 10:38
Radon Level :	2.1 pCi/L	Analyzed:	01/15/2025 @ 09:53

Average of Side by Side Canisters 2.2 pCi/L

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959162	Test Start :	01/10/2025 @ 10:13
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:05
Location :	1st FL=C-128	Received:	01/14/2025 @ 10:38
Radon Level :	0.5 pCi/L	Analyzed:	01/14/2025 @ 15:40
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959462	Test Start :	01/10/2025 @ 10:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:06
Location :	1st FL=C-132	Received:	01/14/2025 @ 10:38
Radon Level :	0.6 pCi/L	Analyzed:	01/15/2025 @ 09:53
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959456	Test Start :	01/10/2025 @ 10:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:08
Location :	1st FL=C-131	Received:	01/14/2025 @ 10:38
Radon Level :	2.4 pCi/L	Analyzed:	01/14/2025 @ 16:37
Error for Measurement is: \pm	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959481 Test Start : 01/10/2025 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:34
Location : 1st FL=A-106/DP Received: 01/14/2025 @ 10:38
Radon Level : 2.8 pCi/L Analyzed: 01/14/2025 @ 14:55
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959482 Test Start : 01/10/2025 @ 10:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:34
Location : 1st FL=A-106/DP Received: 01/14/2025 @ 10:38
Radon Level : 2.6 pCi/L Analyzed: 01/14/2025 @ 16:29

Average of Side by Side Canisters 2.7 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959480 Test Start : 01/10/2025 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:36
Location : 1st FL=A-100/Perkins Received: 01/14/2025 @ 10:38
Radon Level : 1.3 pCi/L Analyzed: 01/14/2025 @ 15:13
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959150 Test Start : 01/10/2025 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:38
Location : 1st FL=A-100/Shackelford Received: 01/14/2025 @ 10:38
Radon Level : 1.2 pCi/L Analyzed: 01/14/2025 @ 15:07
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959653 Test Start : 01/10/2025 @ 10:37
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:39
Location : 1st FL=A-100/Najjar Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 15:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959655 Test Start : 01/10/2025 @ 10:38
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:40
Location : 1st FL=A-100/Conf. Rm Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 14:50



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959479	Test Start :	01/10/2025 @ 10:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:40
Location :	1st FL=A-100/Main Off.	Received:	01/14/2025 @ 10:38
Radon Level :	1.1 pCi/L	Analyzed:	01/15/2025 @ 10:06
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959582	Test Start :	01/10/2025 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:42
Location :	1st FL=A-108	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 14:51
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959484	Test Start :	01/10/2025 @ 10:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:44
Location :	1st FL=A-101/Principal	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/15/2025 @ 09:53
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959523	Test Start :	01/10/2025 @ 10:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:46
Location :	1st FL=A-109/DP	Received:	01/14/2025 @ 10:37
Radon Level :	2.5 pCi/L	Analyzed:	01/14/2025 @ 16:50
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959642	Test Start :	01/10/2025 @ 10:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:46
Location :	1st FL=A-109/DP	Received:	01/14/2025 @ 10:38
Radon Level :	2.0 pCi/L	Analyzed:	01/15/2025 @ 09:53

Average of Side by Side Canisters 2.3 pCi/L

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959469 Test Start : 01/10/2025 @ 10:49
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:48
Location : 1st FL=A-110 Received: 01/14/2025 @ 10:38
Radon Level : 0.8 pCi/L Analyzed: 01/14/2025 @ 16:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959513 Test Start : 01/10/2025 @ 10:51
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:49
Location : 1st FL=A-111 Received: 01/14/2025 @ 10:38
Radon Level : 1.8 pCi/L Analyzed: 01/14/2025 @ 16:32
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959516 Test Start : 01/10/2025 @ 10:51
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:52
Location : 1st FL=A-114 Received: 01/14/2025 @ 10:38
Radon Level : 0.7 pCi/L Analyzed: 01/14/2025 @ 16:43
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959474 Test Start : 01/10/2025 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:54
Location : 1st FL=A-113 Received: 01/14/2025 @ 10:38
Radon Level : 3.4 pCi/L Analyzed: 01/14/2025 @ 16:32
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959155 Test Start : 01/10/2025 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:57
Location : 1st FL=A-119 Received: 01/14/2025 @ 10:38
Radon Level : 0.7 pCi/L Analyzed: 01/14/2025 @ 16:32
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959644 Test Start : 01/10/2025 @ 11:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:57
Location : 1st FL=A-119/BL Received: 01/14/2025 @ 10:38
Radon Level : 0.1 pCi/L Analyzed: 01/14/2025 @ 16:17
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959648 Test Start : 01/10/2025 @ 11:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:06
Location : 1st FL=A-120 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 16:50
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959120 Test Start : 01/10/2025 @ 11:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:10
Location : 1st FL=A-122 Received: 01/14/2025 @ 10:38
Radon Level : 1.4 pCi/L Analyzed: 01/14/2025 @ 16:50
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959116 Test Start : 01/10/2025 @ 11:05
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:13
Location : 1st FL=A-124/DP Received: 01/14/2025 @ 10:38
Radon Level : 1.3 pCi/L Analyzed: 01/14/2025 @ 16:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959161 Test Start : 01/10/2025 @ 11:05
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:13
Location : 1st FL=A-124/DP Received: 01/14/2025 @ 10:37
Radon Level : 1.3 pCi/L Analyzed: 01/14/2025 @ 16:29

Average of Side by Side Canisters 1.3 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959476 Test Start : 01/10/2025 @ 11:07
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:16
Location : 1st FL=A-128 Received: 01/14/2025 @ 10:37
Radon Level : 1.6 pCi/L Analyzed: 01/14/2025 @ 16:37
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959522 Test Start : 01/10/2025 @ 11:09
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 11:18
Location : 1st FL=A-129 Received: 01/14/2025 @ 10:37
Radon Level : 0.9 pCi/L Analyzed: 01/14/2025 @ 16:44



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959465	Test Start :	01/10/2025 @ 11:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:20
Location :	1st FL=A-130	Received:	01/14/2025 @ 10:38
Radon Level :	1.2 pCi/L	Analyzed:	01/15/2025 @ 10:06
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959657	Test Start :	01/10/2025 @ 11:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:21
Location :	1st FL=A-132	Received:	01/14/2025 @ 10:38
Radon Level :	1.2 pCi/L	Analyzed:	01/14/2025 @ 16:44
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959524	Test Start :	01/10/2025 @ 11:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:27
Location :	1st FL=A-136	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 16:29
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959517	Test Start :	01/10/2025 @ 11:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:29
Location :	1st FL=A-138	Received:	01/14/2025 @ 10:38
Radon Level :	1.3 pCi/L	Analyzed:	01/14/2025 @ 16:43
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959636	Test Start :	01/10/2025 @ 11:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:36
Location :	1st FL=A-160	Received:	01/14/2025 @ 10:38
Radon Level :	1.2 pCi/L	Analyzed:	01/14/2025 @ 15:39
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959510	Test Start :	01/10/2025 @ 11:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:53
Location :	1st FL=A-161/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 14:55



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959652	Test Start :	01/10/2025 @ 11:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:53
Location :	1st FL=A-161/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.9 pCi/L	Analyzed:	01/14/2025 @ 15:40

Average of Side by Side Canisters 0.9 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959450	Test Start :	01/10/2025 @ 11:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:54
Location :	1st FL=A-162	Received:	01/14/2025 @ 10:38
Radon Level :	0.5 pCi/L	Analyzed:	01/14/2025 @ 16:06

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959664	Test Start :	01/10/2025 @ 11:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:56
Location :	1st FL=A-165/Teachers Lounge	Received:	01/14/2025 @ 10:38
Radon Level :	1.1 pCi/L	Analyzed:	01/14/2025 @ 15:22

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959467	Test Start :	01/10/2025 @ 11:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:06
Location :	1st FL=B-100/Forbes	Received:	01/14/2025 @ 10:38
Radon Level :	1.5 pCi/L	Analyzed:	01/14/2025 @ 14:33

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959647	Test Start :	01/10/2025 @ 11:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:07
Location :	1st FL=B-100/Lares	Received:	01/14/2025 @ 10:38
Radon Level :	0.9 pCi/L	Analyzed:	01/14/2025 @ 15:40

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959154 Test Start : 01/10/2025 @ 11:34
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:09
Location : 1st FL=B-100/Grados Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 15:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959637 Test Start : 01/10/2025 @ 11:36
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:10
Location : 1st FL=B-100/Ross Received: 01/14/2025 @ 10:38
Radon Level : 0.8 pCi/L Analyzed: 01/14/2025 @ 15:28
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959111 Test Start : 01/10/2025 @ 11:38
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:11
Location : 1st FL=B-100/Moody Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 14:53
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959466 Test Start : 01/10/2025 @ 11:39
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:13
Location : 1st FL=B-100/Clinic Assist. Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 15:55
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959153 Test Start : 01/10/2025 @ 11:41
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:14
Location : 1st FL=B-100/Clinic Mertsock Received: 01/14/2025 @ 10:38
Radon Level : 1.1 pCi/L Analyzed: 01/14/2025 @ 15:40
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959114 Test Start : 01/10/2025 @ 11:42
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:16
Location : 1st FL=B-100/Main Received: 01/14/2025 @ 10:38
Radon Level : 0.9 pCi/L Analyzed: 01/14/2025 @ 15:21
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959634 Test Start : 01/10/2025 @ 11:45
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:17
Location : 1st FL=B-102/Library Received: 01/14/2025 @ 10:38
Radon Level : 1.2 pCi/L Analyzed: 01/14/2025 @ 16:06
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959640 Test Start : 01/10/2025 @ 11:46
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:17
Location : 1st FL=B-102/Library Received: 01/14/2025 @ 10:38
Radon Level : 0.9 pCi/L Analyzed: 01/14/2025 @ 15:55
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959658 Test Start : 01/10/2025 @ 11:47
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:18
Location : 1st FL=B-102/Library Off. Received: 01/14/2025 @ 10:38
Radon Level : 1.7 pCi/L Analyzed: 01/14/2025 @ 15:26
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959654 Test Start : 01/10/2025 @ 11:50
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:20
Location : 1st FL=B-102/Multi.Purp. Received: 01/14/2025 @ 10:38
Radon Level : 0.6 pCi/L Analyzed: 01/14/2025 @ 14:38
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959457 Test Start : 01/10/2025 @ 11:52
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:21
Location : 1st FL=B-104/NRT Training Received: 01/14/2025 @ 10:38
Radon Level : 1.1 pCi/L Analyzed: 01/14/2025 @ 15:40
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959518 Test Start : 01/10/2025 @ 11:53
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:23
Location : 1st FL=B-104/NRT Main Received: 01/14/2025 @ 10:38
Radon Level : 1.1 pCi/L Analyzed: 01/14/2025 @ 14:53
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959632 Test Start : 01/10/2025 @ 12:01
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:43
Location : 1st FL=B-109 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 15:53
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959152 Test Start : 01/10/2025 @ 12:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:00
Location : 1st FL=D-102/DP Received: 01/14/2025 @ 10:38
Radon Level : 0.4 pCi/L Analyzed: 01/14/2025 @ 14:44
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959641 Test Start : 01/10/2025 @ 12:13
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:00
Location : 1st FL=D-102/DP Received: 01/14/2025 @ 10:38
Radon Level : 0.7 pCi/L Analyzed: 01/14/2025 @ 15:21

Average of Side by Side Canisters 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959461 Test Start : 01/10/2025 @ 12:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:48
Location : 1st FL=D-109/Instructor Received: 01/14/2025 @ 10:38
Radon Level : 0.6 pCi/L Analyzed: 01/14/2025 @ 15:40
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959584 Test Start : 01/10/2025 @ 12:18
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:13
Location : 1st FL=D-100 Received: 01/14/2025 @ 10:38
Radon Level : 0.4 pCi/L Analyzed: 01/14/2025 @ 15:04
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959585 Test Start : 01/10/2025 @ 12:20
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 12:51
Location : 1st FL=D-105 Received: 01/14/2025 @ 10:38
Radon Level : 0.5 pCi/L Analyzed: 01/14/2025 @ 16:07



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4959583	Test Start :	01/10/2025 @ 12:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:50
Location :	1st FL=D-107/PE Dir.	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 15:28
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959659	Test Start :	01/10/2025 @ 12:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:45
Location :	1st FL=Womens P.E. Off.	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 17:04
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959455	Test Start :	01/10/2025 @ 12:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:55
Location :	1st FL=Main Gym	Received:	01/14/2025 @ 10:38
Radon Level :	0.3 pCi/L	Analyzed:	01/14/2025 @ 14:53
Error for Measurement is: \pm	0.1 pCi/L		

Canister ID# :	4959477	Test Start :	01/10/2025 @ 12:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:55
Location :	1st FL=Main Gym	Received:	01/14/2025 @ 10:38
Radon Level :	0.3 pCi/L	Analyzed:	01/14/2025 @ 15:04
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959639	Test Start :	01/10/2025 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:40
Location :	1st FL=C-100-B	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 15:04
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959113	Test Start :	01/10/2025 @ 12:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:41
Location :	1st FL=C-100-C	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 15:55



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959451	Test Start :	01/10/2025 @ 12:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:42
Location :	1st FL=C-100-A/Asst. Principal	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 17:04
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959651	Test Start :	01/10/2025 @ 12:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:19
Location :	1st FL=Kitchen Off./DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.6 pCi/L	Analyzed:	01/14/2025 @ 14:55
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959662	Test Start :	01/10/2025 @ 12:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:19
Location :	1st FL=Kitchen Off./DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.6 pCi/L	Analyzed:	01/14/2025 @ 15:21

Average of Side by Side Canisters 0.6 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4959511	Test Start :	01/10/2025 @ 12:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:21
Location :	1st FL=Kitchen Pass	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 16:07
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959519	Test Start :	01/10/2025 @ 12:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:25
Location :	1st FL=Cafeteria	Received:	01/14/2025 @ 10:38
Radon Level :	0.5 pCi/L	Analyzed:	01/14/2025 @ 16:07

FOUND UPSIDE DOWN

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4959514 Test Start : 01/10/2025 @ 12:59
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:25
Location : 1st FL=Cafeteria/BL Received: 01/14/2025 @ 10:38
Radon Level : 0.1 pCi/L Analyzed: 01/14/2025 @ 15:22
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 4959112 Test Start : 01/10/2025 @ 13:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:31
Location : 1st FL=Cafeteria Received: 01/14/2025 @ 10:38
Radon Level : 0.6 pCi/L Analyzed: 01/14/2025 @ 14:50
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959449 Test Start : 01/10/2025 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:38
Location : 1st FL=C-112/DP Received: 01/14/2025 @ 10:38
Radon Level : 1.3 pCi/L Analyzed: 01/14/2025 @ 15:22
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959454 Test Start : 01/10/2025 @ 13:25
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:38
Location : 1st FL=C-112/DP Received: 01/14/2025 @ 10:38
Radon Level : 1.2 pCi/L Analyzed: 01/14/2025 @ 14:31

Average of Side by Side Canisters 1.3 pCi/L
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959445 Test Start : 01/10/2025 @ 13:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:40
Location : 1st FL=C-114 Received: 01/14/2025 @ 10:38
Radon Level : 0.8 pCi/L Analyzed: 01/14/2025 @ 15:40
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959468 Test Start : 01/10/2025 @ 13:41
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 10:20
Location : 1st FL=C-133 Received: 01/14/2025 @ 10:38
Radon Level : 2.3 pCi/L Analyzed: 01/14/2025 @ 16:06



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950472	Test Start :	01/10/2025 @ 13:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:23
Location :	1st FL=C-130/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.5 pCi/L	Analyzed:	01/14/2025 @ 15:53
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950528	Test Start :	01/10/2025 @ 13:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:23
Location :	1st FL=C-130/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.5 pCi/L	Analyzed:	01/14/2025 @ 15:13

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950463	Test Start :	01/10/2025 @ 13:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:25
Location :	1st FL=C-126	Received:	01/14/2025 @ 10:38
Radon Level :	0.9 pCi/L	Analyzed:	01/14/2025 @ 16:43
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950491	Test Start :	01/10/2025 @ 13:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 10:59
Location :	1st FL=A-112	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 15:40
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950442	Test Start :	01/10/2025 @ 13:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:01
Location :	1st FL=A-116/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 16:17
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# :	4950509	Test Start :	01/10/2025 @ 13:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:01
Location :	1st FL=A-116/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.9 pCi/L	Analyzed:	01/14/2025 @ 16:32

Average of Side by Side Canisters 0.9 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950511	Test Start :	01/10/2025 @ 13:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:03
Location :	1st FL=A-118	Received:	01/14/2025 @ 10:38
Radon Level :	2.3 pCi/L	Analyzed:	01/14/2025 @ 15:39

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950479	Test Start :	01/10/2025 @ 14:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:08
Location :	1st FL=A-121	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/15/2025 @ 10:06

FOUND MOVED

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950457	Test Start :	01/10/2025 @ 14:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:25
Location :	1st FL=A-134	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 16:17

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950426	Test Start :	01/10/2025 @ 14:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 11:23
Location :	1st FL=A-131	Received:	01/14/2025 @ 10:38
Radon Level :	1.5 pCi/L	Analyzed:	01/14/2025 @ 16:43

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# :	4950435	Test Start :	01/10/2025 @ 14:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:15
Location :	1st FL=Aux. Gym/DP	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 15:08
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950534	Test Start :	01/10/2025 @ 14:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:15
Location :	1st FL=Aux. Gym/DP	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 15:40

Average of Side by Side Canisters 1.0 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4949634	Test Start :	01/10/2025 @ 14:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:36
Location :	1st FL=Security/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 14:53
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950532	Test Start :	01/10/2025 @ 14:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 12:36
Location :	1st FL=Security/DP	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 14:38

Average of Side by Side Canisters 0.7 pCi/L
Error for Measurement is: ± 0.1 pCi/L

Canister ID# :	4950486	Test Start :	01/10/2025 @ 14:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 13:45
Location :	2nd FL=C-200	Received:	01/14/2025 @ 10:38
Radon Level :	0.7 pCi/L	Analyzed:	01/14/2025 @ 15:04
Error for Measurement is: ±	0.2 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Canister ID# : 4950507 Test Start : 01/10/2025 @ 14:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:48
Location : 2nd FL=A-202 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 14:44
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950492 Test Start : 01/10/2025 @ 14:32
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:50
Location : 2nd FL=A-216 Received: 01/14/2025 @ 10:38
Radon Level : 1.4 pCi/L Analyzed: 01/14/2025 @ 15:55
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950464 Test Start : 01/10/2025 @ 14:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:53
Location : 2nd FL=Stage Received: 01/14/2025 @ 10:38
Radon Level : 0.5 pCi/L Analyzed: 01/14/2025 @ 16:52
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950451 Test Start : 01/10/2025 @ 14:36
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:53
Location : 2nd FL=Auditorium Received: 01/14/2025 @ 10:38
Radon Level : 0.7 pCi/L Analyzed: 01/14/2025 @ 14:31
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950516 Test Start : 01/10/2025 @ 14:39
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:56
Location : 2nd FL=A-228 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 16:07
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950450 Test Start : 01/10/2025 @ 14:40
Canister Type : Charcoal Canister 3 inch Test Stop : 01/13/2025 @ 13:59
Location : 3rd FL=A-342 Received: 01/14/2025 @ 10:38
Radon Level : 1.0 pCi/L Analyzed: 01/14/2025 @ 15:13
FOUND MOSTLY COVERED



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4950523	Test Start :	01/10/2025 @ 14:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 14:01
Location :	3rd FL=A-348	Received:	01/14/2025 @ 10:38
Radon Level :	1.0 pCi/L	Analyzed:	01/14/2025 @ 14:38

FOUND MOSTLY COVERED

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4949783	Test Start :	01/10/2025 @ 14:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 14:05
Location :	3rd FL=A-316	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 15:13

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4950415	Test Start :	01/10/2025 @ 14:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/13/2025 @ 14:07
Location :	3rd FL=A-308	Received:	01/14/2025 @ 10:38
Radon Level :	0.8 pCi/L	Analyzed:	01/14/2025 @ 15:08

Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/14/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: George Washington M.S.
Test Location: 1005 Mount Vernon Avenue
Alexandria, VA 22301-

Individual Canister Results

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201