

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955441 Test Start : 01/14/2025 @ 10:27
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:05
Location : 1st FL = C-103 Received: 01/17/2025 @ 10:27
Radon Level : 0.4 pCi/L Analyzed: 01/17/2025 @ 16:20
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956060 Test Start : 01/14/2025 @ 10:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:06
Location : 1st FL = C-104 Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 16:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955989 Test Start : 01/14/2025 @ 10:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:07
Location : 1st FL = C-105 Received: 01/17/2025 @ 10:27
Radon Level : 0.7 pCi/L Analyzed: 01/17/2025 @ 15:53
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956081 Test Start : 01/14/2025 @ 10:32
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:08
Location : 1st FL = 100-C Received: 01/17/2025 @ 10:27
Radon Level : 0.6 pCi/L Analyzed: 01/17/2025 @ 15:03
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955447 Test Start : 01/14/2025 @ 10:34
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:09
Location : 1st FL = 100-D Received: 01/17/2025 @ 10:27
Radon Level : 0.3 pCi/L Analyzed: 01/17/2025 @ 15:53
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959291 Test Start : 01/14/2025 @ 10:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:09
Location : 1st FL = 100-F Received: 01/17/2025 @ 10:27
Radon Level : 0.6 pCi/L Analyzed: 01/17/2025 @ 15:53
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4956073	Test Start :	01/14/2025 @ 10:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:10
Location :	1st FL = 100-G	Received:	01/17/2025 @ 10:27
Radon Level :	0.6 pCi/L	Analyzed:	01/17/2025 @ 15:38
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959326	Test Start :	01/14/2025 @ 10:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:11
Location :	1st FL = 100-H	Received:	01/17/2025 @ 10:27
Radon Level :	0.7 pCi/L	Analyzed:	01/17/2025 @ 14:54
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4955434	Test Start :	01/14/2025 @ 10:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:12
Location :	1st FL = 100-J	Received:	01/17/2025 @ 10:27
Radon Level :	0.8 pCi/L	Analyzed:	01/17/2025 @ 15:54
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4949091	Test Start :	01/14/2025 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:15
Location :	1st FL = 100-K/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.6 pCi/L	Analyzed:	01/17/2025 @ 14:57
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959384	Test Start :	01/14/2025 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:15
Location :	1st FL = 100-K/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:35

Average of Side by Side Canisters 0.5 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4955374	Test Start :	01/14/2025 @ 10:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:17
Location :	1st FL = 100-Q	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 15:32



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4956069
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 100-R
Radon Level : 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 01/14/2025 @ 10:47
Test Stop : 01/16/2025 @ 14:18
Received: 01/17/2025 @ 10:27
Analyzed: 01/17/2025 @ 15:32

Canister ID# : 4956022
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 101
Radon Level : 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 01/14/2025 @ 10:49
Test Stop : 01/16/2025 @ 14:25
Received: 01/17/2025 @ 10:27
Analyzed: 01/17/2025 @ 15:54

Canister ID# : 4955442
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 101-A
Radon Level : 0.7 pCi/L
NEAR WINDOW

Test Start : 01/14/2025 @ 10:51
Test Stop : 01/16/2025 @ 14:26
Received: 01/17/2025 @ 10:27
Analyzed: 01/17/2025 @ 15:38

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4959400
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 101-E
Radon Level : 0.5 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 01/14/2025 @ 10:52
Test Stop : 01/16/2025 @ 14:26
Received: 01/17/2025 @ 10:27
Analyzed: 01/17/2025 @ 15:18

Canister ID# : 4949095
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = 106
Radon Level : 0.4 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 01/14/2025 @ 10:54
Test Stop : 01/16/2025 @ 14:28
Received: 01/17/2025 @ 10:27
Analyzed: 01/17/2025 @ 16:07



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955998 Test Start : 01/14/2025 @ 10:56
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:38
Location : 1st FL = 115 Received: 01/17/2025 @ 10:27
Radon Level : 0.2 pCi/L Analyzed: 01/17/2025 @ 15:51
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4949134 Test Start : 01/14/2025 @ 10:58
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:40
Location : 1st FL = 118 Received: 01/17/2025 @ 10:27
Radon Level : 0.3 pCi/L Analyzed: 01/17/2025 @ 14:57
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4955407 Test Start : 01/14/2025 @ 11:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:44
Location : 1st FL = 121 Received: 01/17/2025 @ 10:27
Radon Level : 0.3 pCi/L Analyzed: 01/17/2025 @ 16:09
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4955453 Test Start : 01/14/2025 @ 11:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:42
Location : 1st FL = 122/DP Received: 01/17/2025 @ 10:27
Radon Level : 0.6 pCi/L Analyzed: 01/17/2025 @ 16:07
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4956000 Test Start : 01/14/2025 @ 11:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:42
Location : 1st FL = 122/DP Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 16:04

Average of Side by Side Canisters 0.6 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4949038 Test Start : 01/14/2025 @ 11:05
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 14:45
Location : 1st FL = 123 Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 14:42



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4955950	Test Start :	01/14/2025 @ 11:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:45
Location :	1st FL = 123/BL	Received:	01/17/2025 @ 10:27
Radon Level :	0.1 pCi/L	Analyzed:	01/17/2025 @ 15:54
Error for Measurement is:	\pm 0.3 pCi/L		

Canister ID# :	4955436	Test Start :	01/14/2025 @ 11:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:46
Location :	1st FL = 124	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:05
Error for Measurement is:	\pm 0.2 pCi/L		

Canister ID# :	4949117	Test Start :	01/14/2025 @ 11:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:47
Location :	1st FL = 127	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 15:38
Error for Measurement is:	\pm 0.2 pCi/L		

Canister ID# :	4949094	Test Start :	01/14/2025 @ 11:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:50
Location :	1st FL = 128	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:34
Error for Measurement is:	\pm 0.2 pCi/L		

Canister ID# :	4955417	Test Start :	01/14/2025 @ 11:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:53
Location :	1st FL = 126	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 15:51
Error for Measurement is:	\pm 0.2 pCi/L		

Canister ID# :	4956077	Test Start :	01/14/2025 @ 11:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:54
Location :	1st FL = 125	Received:	01/17/2025 @ 10:27
Radon Level :	0.2 pCi/L	Analyzed:	01/17/2025 @ 16:05



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4955409	Test Start :	01/14/2025 @ 11:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:56
Location :	1st FL = 120	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 16:04
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4956043	Test Start :	01/14/2025 @ 11:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:57
Location :	1st FL = 119	Received:	01/17/2025 @ 10:27
Radon Level :	0.2 pCi/L	Analyzed:	01/17/2025 @ 16:21
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955446	Test Start :	01/14/2025 @ 11:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:58
Location :	1st FL = 117	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 16:07
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959292	Test Start :	01/14/2025 @ 11:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:59
Location :	1st FL = 116/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.5 pCi/L	Analyzed:	01/17/2025 @ 15:18
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4959399	Test Start :	01/14/2025 @ 11:23
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:59
Location :	1st FL = 116/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.5 pCi/L	Analyzed:	01/17/2025 @ 15:51

Average of Side by Side Canisters 0.5 pCi/L

Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4956010 Test Start : 01/14/2025 @ 11:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:02
Location : 1st FL = 111 Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 16:09
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955401 Test Start : 01/14/2025 @ 11:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:03
Location : 1st FL = 110 Received: 01/17/2025 @ 10:27
Radon Level : 0.6 pCi/L Analyzed: 01/17/2025 @ 16:21
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955445 Test Start : 01/14/2025 @ 11:30
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:04
Location : 1st FL = 109 Received: 01/17/2025 @ 10:27
Radon Level : 0.2 pCi/L Analyzed: 01/17/2025 @ 16:05
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956063 Test Start : 01/14/2025 @ 11:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:05
Location : 1st FL = 108 Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 14:55
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955402 Test Start : 01/14/2025 @ 11:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:05
Location : 1st FL = 108/BL Received: 01/17/2025 @ 10:27
Radon Level : 0.1 pCi/L Analyzed: 01/17/2025 @ 16:04
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955970 Test Start : 01/14/2025 @ 11:37
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:06
Location : 1st FL = 107 Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 16:07
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4959303	Test Start :	01/14/2025 @ 11:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:09
Location :	1st FL = 103	Received:	01/17/2025 @ 10:27
Radon Level :	0.5 pCi/L	Analyzed:	01/17/2025 @ 16:20
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4959344	Test Start :	01/14/2025 @ 11:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:22
Location :	1st FL = Kitchen	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 15:54
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4949107	Test Start :	01/14/2025 @ 11:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:21
Location :	1st FL=Kitchen Off./DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.2 pCi/L	Analyzed:	01/17/2025 @ 14:57
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4955976	Test Start :	01/14/2025 @ 11:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:21
Location :	1st FL=Kitchen Off./DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:35

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4956005	Test Start :	01/14/2025 @ 11:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 14:23
Location :	1st FL = Serving	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:21
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	4955444	Test Start :	01/14/2025 @ 11:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:17
Location :	1st FL = 140	Received:	01/17/2025 @ 10:27
Radon Level :	0.5 pCi/L	Analyzed:	01/17/2025 @ 15:15



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Error for Measurement is: \pm 0.2 pCi/L

Canister ID# :	4955459	Test Start :	01/14/2025 @ 12:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:21
Location :	1st FL = 142-G	Received:	01/17/2025 @ 10:27
Radon Level :	0.3 pCi/L	Analyzed:	01/17/2025 @ 16:05
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4956007	Test Start :	01/14/2025 @ 12:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:21
Location :	1st FL = 142-E	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 15:38
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4959373	Test Start :	01/14/2025 @ 12:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:24
Location :	1st FL = 147	Received:	01/17/2025 @ 10:27
Radon Level :	0.6 pCi/L	Analyzed:	01/17/2025 @ 16:09
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4949069	Test Start :	01/14/2025 @ 12:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:25
Location :	1st FL = Cafetorium/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 16:09
Error for Measurement is: \pm	0.2 pCi/L		

Canister ID# :	4955979	Test Start :	01/14/2025 @ 12:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:25
Location :	1st FL = Cafetorium/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.4 pCi/L	Analyzed:	01/17/2025 @ 15:15

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# : 4955364 Test Start : 01/14/2025 @ 12:23
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:26
Location : 1st FL = Cafetorium Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 15:51
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4959353 Test Start : 01/14/2025 @ 12:37
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:33
Location : 2nd FL = 200-E Received: 01/17/2025 @ 10:27
Radon Level : 0.5 pCi/L Analyzed: 01/17/2025 @ 15:18
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4948932 Test Start : 01/14/2025 @ 12:40
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:35
Location : 2nd FL = 219 Received: 01/17/2025 @ 10:27
Radon Level : 0.3 pCi/L Analyzed: 01/17/2025 @ 16:20
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4956044 Test Start : 01/14/2025 @ 12:42
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:37
Location : 2nd FL = 230 Received: 01/17/2025 @ 10:27
Radon Level : 0.3 pCi/L Analyzed: 01/17/2025 @ 13:52
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955414 Test Start : 01/14/2025 @ 12:45
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:39
Location : 3rd FL = 306 Received: 01/17/2025 @ 10:27
Radon Level : 0.4 pCi/L Analyzed: 01/17/2025 @ 16:21
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 4955965 Test Start : 01/14/2025 @ 12:48
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 15:40
Location : 3rd FL = 320/DP Received: 01/17/2025 @ 10:27
Radon Level : 0.2 pCi/L Analyzed: 01/17/2025 @ 16:20
Error for Measurement is: \pm 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/17/2025

Ms. Catey Bourne
ECS MID-ATLANTIC, LLC
14026 Thunderbolt Place
Suite 100
Chantilly, VA 20151-

Client: Patrick Henry K-8 School
Test Location: 4643 Taney Avenue
Alexandria, VA 22304-

Individual Canister Results

Canister ID# :	4955996	Test Start :	01/14/2025 @ 12:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 15:40
Location :	3rd FL = 320/DP	Received:	01/17/2025 @ 10:27
Radon Level :	0.2 pCi/L	Analyzed:	01/17/2025 @ 15:53

Average of Side by Side Canisters 0.2 pCi/L

Error for Measurement is: ± 0.1 pCi/L

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201