

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Canister ID# :	4950575	Test Start :	01/15/2025 @ 11:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:09
Location :	1st FL = Lobby/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.5 pCi/L	Analyzed:	01/21/2025 @ 10:08
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4956045	Test Start :	01/15/2025 @ 11:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:09
Location :	1st FL = Lobby/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:56

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4956079	Test Start :	01/15/2025 @ 11:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:10
Location :	1st FL = Office/ELL	Received:	01/20/2025 @ 11:43
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 09:34
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4949800	Test Start :	01/15/2025 @ 11:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:10
Location :	1st FL = 112-2	Received:	01/20/2025 @ 11:42
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 09:34
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4956001	Test Start :	01/15/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:11
Location :	1st FL = 113	Received:	01/20/2025 @ 11:42
Radon Level :	0.5 pCi/L	Analyzed:	01/21/2025 @ 09:49
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4955391	Test Start :	01/15/2025 @ 12:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:11
Location :	1st FL = 113/BL	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:45



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4949813
Canister Type : Charcoal Canister 3 inch
Location : 7th FL = 7-1
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.3 pCi/L

Test Start : 01/15/2025 @ 12:15
Test Stop : 01/17/2025 @ 12:15
Received: 01/20/2025 @ 11:43
Analyzed: 01/20/2025 @ 16:56

Canister ID# : 4949797
Canister Type : Charcoal Canister 3 inch
Location : 7th FL = 710-8/DP
Radon Level : 0.4 pCi/L
Error for Measurement is: ± 0.3 pCi/L

Test Start : 01/15/2025 @ 12:17
Test Stop : 01/17/2025 @ 12:17
Received: 01/20/2025 @ 11:42
Analyzed: 01/21/2025 @ 10:08

Canister ID# : 4956078
Canister Type : Charcoal Canister 3 inch
Location : 7th FL = 710-8/DP
Radon Level : 0.2 pCi/L

Test Start : 01/15/2025 @ 12:17
Test Stop : 01/17/2025 @ 12:17
Received: 01/20/2025 @ 11:43
Analyzed: 01/21/2025 @ 09:53

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4951011
Canister Type : Charcoal Canister 3 inch
Location : 7th FL = 7-3
Radon Level : 0.2 pCi/L
Error for Measurement is: ± 0.3 pCi/L

Test Start : 01/15/2025 @ 12:19
Test Stop : 01/17/2025 @ 12:19
Received: 01/20/2025 @ 11:43
Analyzed: 01/21/2025 @ 10:20

Canister ID# : 4950185
Canister Type : Charcoal Canister 3 inch
Location : 6th FL = 610-9
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.2 pCi/L

Test Start : 01/15/2025 @ 12:23
Test Stop : 01/17/2025 @ 12:23
Received: 01/20/2025 @ 11:43
Analyzed: 01/21/2025 @ 09:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Canister ID# : 4956056 Test Start : 01/15/2025 @ 12:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:27
Location : 6th FL = 610-14 Received: 01/20/2025 @ 11:43
Radon Level : 0.3 pCi/L Analyzed: 01/21/2025 @ 10:08
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4956083 Test Start : 01/15/2025 @ 12:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:29
Location : 6th FL = 620-15 Received: 01/20/2025 @ 11:43
Radon Level : 0.6 pCi/L Analyzed: 01/21/2025 @ 09:46
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4955984 Test Start : 01/15/2025 @ 12:29
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:29
Location : 6th FL = 620-15/BL Received: 01/20/2025 @ 11:43
Radon Level : 0.2 pCi/L Analyzed: 01/21/2025 @ 10:29
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4955982 Test Start : 01/15/2025 @ 12:31
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:31
Location : 6th FL = 600-6 Received: 01/20/2025 @ 11:43
Radon Level : 0.5 pCi/L Analyzed: 01/21/2025 @ 09:46
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4955303 Test Start : 01/15/2025 @ 12:33
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:34
Location : 5th FL = 500-6 Received: 01/20/2025 @ 11:42
Radon Level : 0.4 pCi/L Analyzed: 01/21/2025 @ 09:49
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4956058 Test Start : 01/15/2025 @ 12:35
Canister Type : Charcoal Canister 3 inch Test Stop : 01/17/2025 @ 12:36
Location : 5th FL = 510-1 Received: 01/20/2025 @ 11:43
Radon Level : 0.4 pCi/L Analyzed: 01/21/2025 @ 09:49
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Canister ID# :	4951050	Test Start :	01/15/2025 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:37
Location :	5th FL = 510-14/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 09:34
Error for Measurement is:	± 0.3 pCi/L		

Canister ID# :	4959149	Test Start :	01/15/2025 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:37
Location :	5th FL = 510-14/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 09:46

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	4951022	Test Start :	01/15/2025 @ 12:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:40
Location :	5th FL = 520-9	Received:	01/20/2025 @ 11:43
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 10:05
Error for Measurement is:	± 0.3 pCi/L		

Canister ID# :	4956008	Test Start :	01/15/2025 @ 12:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:44
Location :	1st FL = Lrg Conf. Rm	Received:	01/20/2025 @ 11:43
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 10:05
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	4956065	Test Start :	01/15/2025 @ 12:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:47
Location :	1st FL = Side Conf. Rm	Received:	01/20/2025 @ 11:43
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 09:46
Error for Measurement is:	± 0.3 pCi/L		

Canister ID# :	4956071	Test Start :	01/15/2025 @ 12:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:46
Location :	1st FL = Break Rm	Received:	01/20/2025 @ 11:43
Radon Level :	0.5 pCi/L	Analyzed:	01/21/2025 @ 10:20



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	4949075	Test Start :	01/15/2025 @ 12:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:50
Location :	4th FL = 420-34	Received:	01/20/2025 @ 11:42
Radon Level :	0.5 pCi/L	Analyzed:	01/21/2025 @ 09:34
Error for Measurement is:	\pm 0.3 pCi/L		

Canister ID# :	4959686	Test Start :	01/15/2025 @ 12:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:50
Location :	4th FL = 420-34/BL	Received:	01/20/2025 @ 11:42
Radon Level :	0.1 pCi/L	Analyzed:	01/21/2025 @ 10:29
Error for Measurement is:	\pm 0.3 pCi/L		

Canister ID# :	4955389	Test Start :	01/15/2025 @ 12:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:53
Location :	4th FL = 420-43	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:24
Error for Measurement is:	\pm 0.2 pCi/L		

Canister ID# :	4949639	Test Start :	01/15/2025 @ 12:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:57
Location :	4th FL = 420-19	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:56
Error for Measurement is:	\pm 0.1 pCi/L		

Canister ID# :	4959160	Test Start :	01/15/2025 @ 12:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 12:59
Location :	4th FL = 420-30	Received:	01/20/2025 @ 11:43
Radon Level :	0.3 pCi/L	Analyzed:	01/21/2025 @ 10:20
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	4955380	Test Start :	01/15/2025 @ 13:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:01
Location :	3rd FL = 3-1	Received:	01/20/2025 @ 11:43
Radon Level :	0.3 pCi/L	Analyzed:	01/21/2025 @ 09:53



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4948070	Test Start :	01/15/2025 @ 13:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:03
Location :	3rd FL = 310-1	Received:	01/20/2025 @ 11:43
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 10:06
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4959705	Test Start :	01/15/2025 @ 13:03
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:03
Location :	3rd FL = 310-1	Received:	01/20/2025 @ 11:43
Radon Level :	0.3 pCi/L	Analyzed:	01/21/2025 @ 09:53
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950467	Test Start :	01/15/2025 @ 13:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:08
Location :	3rd FL = 320-10	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/21/2025 @ 10:05
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4955432	Test Start :	01/15/2025 @ 13:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:11
Location :	2nd FL = 220-5/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.6 pCi/L	Analyzed:	01/21/2025 @ 10:29
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4959715	Test Start :	01/15/2025 @ 13:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:11
Location :	2nd FL = 220-5/DP	Received:	01/20/2025 @ 11:43
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 10:20

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski
ECS MID-ATLANTIC, LLC
4004 Hunterstand Court
Suite 102
Charlottesville, VA 22911-

Client: ACPS Main Office
Test Location: 1340 Braddock Road
Alexandria, VA 22311-

Individual Canister Results

Canister ID# :	4949794	Test Start :	01/15/2025 @ 13:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:14
Location :	2nd FL = 200-7	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/21/2025 @ 10:43
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950481	Test Start :	01/15/2025 @ 13:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/17/2025 @ 13:18
Location :	2nd FL = 2-3	Received:	01/20/2025 @ 11:43
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 16:56
Error for Measurement is: ±	0.1 pCi/L		

The reported results indicate that radon levels in the building tested are below the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends retesting if your living patterns change and you begin occupying a lower level of the building, such as a basement or if major remodeling is done.

General radon information may be obtained by consulting the EPA booklet: A Citizen's Guide to Radon (www.epa.gov/radon/pubs/citguide.html). To request a copy or for further information, please contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201