

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Canister ID# : 4950461                      Test Start : 01/14/2025 @ 10:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:32  
Location : 1st FL = 100-B                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.2 pCi/L                      Analyzed: 01/20/2025 @ 14:40  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 4950441                      Test Start : 01/14/2025 @ 10:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:33  
Location : 1st FL = 100-J                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.5 pCi/L                      Analyzed: 01/20/2025 @ 11:45  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 4950521                      Test Start : 01/14/2025 @ 10:36  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:33  
Location : 1st FL = 100-K                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.5 pCi/L                      Analyzed: 01/20/2025 @ 14:55  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 4950482                      Test Start : 01/14/2025 @ 10:37  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:34  
Location : 1st FL = 100-L                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 16:18  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 4949612                      Test Start : 01/14/2025 @ 10:38  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:35  
Location : 1st FL = 100-M/DP                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 14:40  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 4949809                      Test Start : 01/14/2025 @ 10:38  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:35  
Location : 1st FL = 100-M/DP                      Received: 01/20/2025 @ 11:20  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 12:35

Average of Side by Side Canisters              0.1 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4950517	Test Start :	01/14/2025 @ 10:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:36
Location :	1st FL = 100-N	Received:	01/20/2025 @ 11:21
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 11:58
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4949799	Test Start :	01/14/2025 @ 10:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:36
Location :	1st FL = 100-P	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 12:13
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4930412	Test Start :	01/14/2025 @ 10:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:37
Location :	1st FL=100/Break Rm	Received:	01/20/2025 @ 11:21
Radon Level :	0.3 pCi/L	Analyzed:	01/21/2025 @ 10:43
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950526	Test Start :	01/14/2025 @ 10:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:37
Location :	1st FL = 100-Y	Received:	01/20/2025 @ 11:20
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 15:07
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4949804	Test Start :	01/14/2025 @ 10:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:38
Location :	1st FL = 101	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 13:11
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4950419	Test Start :	01/14/2025 @ 10:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:39
Location :	1st FL = 103	Received:	01/20/2025 @ 11:20
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 12:35



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	4930428	Test Start :	01/14/2025 @ 10:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:41
Location :	1st FL = 102/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 12:20
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950512	Test Start :	01/14/2025 @ 10:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:41
Location :	1st FL = 102/DP	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 13:37

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	4867544	Test Start :	01/14/2025 @ 10:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:42
Location :	1st FL = 104	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:49
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950490	Test Start :	01/14/2025 @ 10:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:43
Location :	1st FL = 105	Received:	01/20/2025 @ 11:20
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 15:06
Error for Measurement is: ±	0.2 pCi/L		

Canister ID# :	4930357	Test Start :	01/14/2025 @ 10:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 11:44
Location :	1st FL = 106	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:35
Error for Measurement is: ±	0.3 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Canister ID# : 4950468                      Test Start : 01/14/2025 @ 10:49  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:45  
Location : 1st FL = 107                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L                      Analyzed: 01/21/2025 @ 10:17  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4930359                      Test Start : 01/14/2025 @ 10:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:46  
Location : 1st FL = 108                      Received: 01/20/2025 @ 11:20  
Radon Level : 0.2 pCi/L                      Analyzed: 01/20/2025 @ 13:26  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4950495                      Test Start : 01/14/2025 @ 10:51  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:47  
Location : 1st FL = 109                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L                      Analyzed: 01/20/2025 @ 14:53  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950445                      Test Start : 01/14/2025 @ 10:52  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:48  
Location : 1st FL = 109-D                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.5 pCi/L                      Analyzed: 01/20/2025 @ 12:22  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950449                      Test Start : 01/14/2025 @ 10:53  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:48  
Location : 1st FL = 110                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L                      Analyzed: 01/20/2025 @ 12:34  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950462                      Test Start : 01/14/2025 @ 10:53  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 11:49  
Location : 1st FL = 111                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 15:07  
Error for Measurement is: ± 0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4930390 Test Start : 01/14/2025 @ 11:00  
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 11:54  
Location : 1st FL = 115-D Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 13:11  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4930346 Test Start : 01/14/2025 @ 11:01  
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 11:55  
Location : 1st FL = 116 Received: 01/20/2025 @ 11:21  
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 14:53  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4930381 Test Start : 01/14/2025 @ 11:02  
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 11:56  
Location : 1st FL = 117 Received: 01/20/2025 @ 11:20  
Radon Level : 0.4 pCi/L Analyzed: 01/20/2025 @ 13:23  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 4950494 Test Start : 01/14/2025 @ 11:02  
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 11:57  
Location : 1st FL = 118 Received: 01/20/2025 @ 11:20  
Radon Level : 0.1 pCi/L Analyzed: 01/20/2025 @ 12:35  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4930423 Test Start : 01/14/2025 @ 11:03  
Canister Type : Charcoal Canister 3 inch Test Stop : 01/16/2025 @ 11:58  
Location : 1st FL = 119/DP Received: 01/20/2025 @ 11:21  
Radon Level : 0.3 pCi/L Analyzed: 01/20/2025 @ 12:33  
Error for Measurement is: ± 0.3 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.2 pCi/L

Canister ID# :	4950418	Test Start :	01/14/2025 @ 11:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:04
Location :	1st FL = 124	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 13:11
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950182	Test Start :	01/14/2025 @ 11:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:05
Location :	1st FL = 125	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 14:55
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950074	Test Start :	01/14/2025 @ 11:13
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:06
Location :	1st FL = 128	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:49
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950138	Test Start :	01/14/2025 @ 11:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:07
Location :	1st FL = 126	Received:	01/20/2025 @ 11:20
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 12:20
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950215	Test Start :	01/14/2025 @ 11:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:07
Location :	1st FL = 127	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:12
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950530	Test Start :	01/14/2025 @ 11:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:12
Location :	1st FL = 136	Received:	01/20/2025 @ 11:20
Radon Level :	1.0 pCi/L	Analyzed:	01/20/2025 @ 14:55



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# :	4851476	Test Start :	01/14/2025 @ 11:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:08
Location :	1st FL = 133-A	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 14:35
Error for Measurement is: $\pm$	0.2 pCi/L		

Canister ID# :	4950432	Test Start :	01/14/2025 @ 11:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:10
Location :	1st FL = 134/DP	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:49
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4950446	Test Start :	01/14/2025 @ 11:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:10
Location :	1st FL = 134/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 13:00

Average of Side by Side Canisters 0.2 pCi/L

Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# :	4930377	Test Start :	01/14/2025 @ 11:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:11
Location :	1st FL = 135	Received:	01/20/2025 @ 11:21
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 12:13
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950039	Test Start :	01/14/2025 @ 11:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:13
Location :	1st FL = Gym-R	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 10:17
Error for Measurement is: $\pm$	0.3 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Canister ID# : 4950483                      Test Start : 01/14/2025 @ 11:23  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:14  
Location : 1st FL = Gym-L                      Received: 01/20/2025 @ 11:20  
Radon Level : 0.4 pCi/L                      Analyzed: 01/20/2025 @ 13:23  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950422                      Test Start : 01/14/2025 @ 11:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:15  
Location : 1st FL = 129                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/21/2025 @ 10:17  
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950459                      Test Start : 01/14/2025 @ 11:26  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:15  
Location : 1st FL = 130                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.3 pCi/L                      Analyzed: 01/20/2025 @ 11:45  
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950437                      Test Start : 01/14/2025 @ 11:26  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:15  
Location : 1st FL = 130/BL                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.3 pCi/L                      Analyzed: 01/20/2025 @ 12:46  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950048                      Test Start : 01/14/2025 @ 11:29  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:16  
Location : 1st FL = 131                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L                      Analyzed: 01/20/2025 @ 14:32  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950430                      Test Start : 01/14/2025 @ 11:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:17  
Location : 1st FL = 132                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.2 pCi/L                      Analyzed: 01/20/2025 @ 12:13  
Error for Measurement is: ± 0.3 pCi/L



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Canister ID# : 4950477                      Test Start : 01/14/2025 @ 11:30  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:18  
Location : 1st FL = 145                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.6 pCi/L                      Analyzed: 01/20/2025 @ 12:33  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950071                      Test Start : 01/14/2025 @ 11:31  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:19  
Location : 1st FL = 144                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 12:12  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 4950429                      Test Start : 01/14/2025 @ 11:31  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:20  
Location : 1st FL = 143                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 12:35  
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 4950433                      Test Start : 01/14/2025 @ 11:32  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:21  
Location : 1st FL = 138                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.4 pCi/L                      Analyzed: 01/20/2025 @ 14:32  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950439                      Test Start : 01/14/2025 @ 11:32  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:22  
Location : 1st FL = 139                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 14:35  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 4950518                      Test Start : 01/14/2025 @ 11:33  
Canister Type : Charcoal Canister 3 inch      Test Stop : 01/16/2025 @ 12:23  
Location : 1st FL = 142                      Received: 01/20/2025 @ 11:21  
Radon Level : 0.1 pCi/L                      Analyzed: 01/20/2025 @ 14:32  
Error for Measurement is: ± 0.3 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.

Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# :	4950454	Test Start :	01/14/2025 @ 11:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:31
Location :	1st FL = 147-B	Received:	01/20/2025 @ 11:21
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 11:58
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4950434	Test Start :	01/14/2025 @ 11:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:33
Location :	1st FL = 148	Received:	01/20/2025 @ 11:21
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 13:38
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4950470	Test Start :	01/14/2025 @ 11:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:33
Location :	1st FL = 149-F	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 14:02
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4950187	Test Start :	01/14/2025 @ 11:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:34
Location :	1st FL = 149-E	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 13:38
Error for Measurement is:	$\pm$ 0.4 pCi/L		

Canister ID# :	4950163	Test Start :	01/14/2025 @ 11:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:35
Location :	1st FL = 149-G	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 14:53
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4950452	Test Start :	01/14/2025 @ 11:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:35
Location :	1st FL = 149-D	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 11:58



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4950485	Test Start :	01/14/2025 @ 11:46
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:36
Location :	1st FL = 149-C	Received:	01/20/2025 @ 11:21
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 10:29
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950458	Test Start :	01/14/2025 @ 11:47
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:37
Location :	1st FL = 149-B	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 12:12
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	4950081	Test Start :	01/14/2025 @ 11:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:37
Location :	1st FL = 149-J	Received:	01/20/2025 @ 11:21
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 12:46
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950514	Test Start :	01/14/2025 @ 11:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:38
Location :	1st FL = 149	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 14:35
Error for Measurement is: ±	0.9 pCi/L		

Canister ID# :	4950396	Test Start :	01/14/2025 @ 11:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:43
Location :	1st FL=Cafeteria-L/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 14:35
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950427	Test Start :	01/14/2025 @ 11:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:43
Location :	1st FL=Cafeteria-L/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 13:00



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Average of Side by Side Canisters 0.3 pCi/L

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4950489	Test Start :	01/14/2025 @ 11:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:43
Location :	1st FL=Cafeteria-R	Received:	01/20/2025 @ 11:20
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 13:37
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	4950438	Test Start :	01/14/2025 @ 11:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:46
Location :	1st FL = 159	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 15:07
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	4950087	Test Start :	01/14/2025 @ 11:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:45
Location :	1st FL = 161-J	Received:	01/20/2025 @ 11:20
Radon Level :	1.0 pCi/L	Analyzed:	01/20/2025 @ 14:17
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950497	Test Start :	01/14/2025 @ 11:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:48
Location :	1st FL=General Storage	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 12:22
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950448	Test Start :	01/14/2025 @ 11:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:49
Location :	1st FL=Maint. Off.	Received:	01/20/2025 @ 11:20
Radon Level :	0.9 pCi/L	Analyzed:	01/20/2025 @ 12:07
Error for Measurement is: ±	0.3 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201





Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.

Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# :	4959668	Test Start :	01/14/2025 @ 12:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:54
Location :	1st FL = 154	Received:	01/20/2025 @ 11:21
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 13:11
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4949792	Test Start :	01/14/2025 @ 12:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:55
Location :	1st FL = 157	Received:	01/20/2025 @ 11:20
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 14:02
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4950453	Test Start :	01/14/2025 @ 12:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:56
Location :	1st FL = 157-B	Received:	01/20/2025 @ 11:20
Radon Level :	1.1 pCi/L	Analyzed:	01/20/2025 @ 12:20
Error for Measurement is:	$\pm$ 0.4 pCi/L		

Canister ID# :	4950447	Test Start :	01/14/2025 @ 12:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:57
Location :	1st FL = 157-C	Received:	01/20/2025 @ 11:21
Radon Level :	0.6 pCi/L	Analyzed:	01/21/2025 @ 10:32
Error for Measurement is:	$\pm$ 0.4 pCi/L		

Canister ID# :	4950474	Test Start :	01/14/2025 @ 12:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:57
Location :	1st FL = 157-D	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 14:40
Error for Measurement is:	$\pm$ 0.3 pCi/L		

Canister ID# :	4959470	Test Start :	01/14/2025 @ 12:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:58
Location :	1st FL = 157-E	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 14:32



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.

Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# :	4959677	Test Start :	01/14/2025 @ 12:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 12:59
Location :	1st FL = 157-F	Received:	01/20/2025 @ 11:20
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 12:07
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4959656	Test Start :	01/14/2025 @ 12:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:00
Location :	1st FL = 100-C	Received:	01/20/2025 @ 11:20
Radon Level :	0.6 pCi/L	Analyzed:	01/20/2025 @ 14:17
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4959698	Test Start :	01/14/2025 @ 12:20
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:00
Location :	1st FL = 100-D	Received:	01/20/2025 @ 11:21
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 12:49
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4959690	Test Start :	01/14/2025 @ 12:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:01
Location :	1st FL = 157-G	Received:	01/20/2025 @ 11:20
Radon Level :	0.9 pCi/L	Analyzed:	01/20/2025 @ 12:22
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4959148	Test Start :	01/14/2025 @ 12:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:01
Location :	1st FL = 166-B	Received:	01/20/2025 @ 11:21
Radon Level :	1.0 pCi/L	Analyzed:	01/20/2025 @ 16:18
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4949789	Test Start :	01/14/2025 @ 12:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:15
Location :	1st FL = S-4 Storage	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 13:00



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.

Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# :	4950431	Test Start :	01/14/2025 @ 12:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:02
Location :	1st FL = 168	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/20/2025 @ 13:37
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950510	Test Start :	01/14/2025 @ 12:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:03
Location :	1st FL = 166	Received:	01/20/2025 @ 11:21
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 13:00
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4959695	Test Start :	01/14/2025 @ 12:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:03
Location :	1st FL = 167	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/21/2025 @ 10:32
Error for Measurement is: $\pm$	0.4 pCi/L		

Canister ID# :	4950425	Test Start :	01/14/2025 @ 12:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:04
Location :	1st FL = 165	Received:	01/20/2025 @ 11:21
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 12:22
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4950531	Test Start :	01/14/2025 @ 12:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:05
Location :	1st FL = 164	Received:	01/20/2025 @ 11:21
Radon Level :	0.2 pCi/L	Analyzed:	01/21/2025 @ 10:32
Error for Measurement is: $\pm$	0.3 pCi/L		

Canister ID# :	4950515	Test Start :	01/14/2025 @ 12:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:06
Location :	1st FL = 169	Received:	01/20/2025 @ 11:20
Radon Level :	0.4 pCi/L	Analyzed:	01/20/2025 @ 14:02



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.  
Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4950141	Test Start :	01/14/2025 @ 12:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:06
Location :	1st FL = 169-A	Received:	01/20/2025 @ 11:20
Radon Level :	0.7 pCi/L	Analyzed:	01/20/2025 @ 13:23
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4949775	Test Start :	01/14/2025 @ 12:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:07
Location :	2nd FL = 201/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.5 pCi/L	Analyzed:	01/20/2025 @ 12:20
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950147	Test Start :	01/14/2025 @ 12:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:07
Location :	2nd FL = 201/DP	Received:	01/20/2025 @ 11:20
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 13:23

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: ± 0.3 pCi/L

Canister ID# :	4949008	Test Start :	01/14/2025 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:08
Location :	2nd FL = 207	Received:	01/20/2025 @ 11:20
Radon Level :	0.3 pCi/L	Analyzed:	01/20/2025 @ 14:20
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	4950420	Test Start :	01/14/2025 @ 12:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/16/2025 @ 13:08
Location :	2nd FL = 207/BL	Received:	01/20/2025 @ 11:21
Radon Level :	0.1 pCi/L	Analyzed:	01/20/2025 @ 12:13
Error for Measurement is: ±	0.2 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 01/20/2025

Ms. Felicia Filarski  
ECS MID-ATLANTIC, LLC  
4004 Hunterstand Court  
Suite 102  
Charlottesville, VA 22911-

Client: John Adams E.S./ACPS Early Childhood Ctr.

Test Location: 5651 Rayburn Avenue  
Alexandria, VA 22311-

Individual Canister Results

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201