

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Liquid Scintillation
NRPP Device Code 8088
NRSB Device Code 12193

Laboratory Report for:

Property Tested: Project # 47:11652-X

ECS Mid-Atlantic
14026 Thunderbolt Place Suite 100
Chantilly VA 20151

ACPS Transportation Department
3540 Wheeler Avenue
Alexandria VA 22304


Log Number	Device Number	Test Exposure	Duration	Area Tested	Result pCi/L
8672347	5167118	01/15/2025 12:26 pm	01/17/2025 12:46 pm	Bldg. Aux Building First Flr Break Rm Field Blank	< 0.4
8672348	5167119	01/15/2025 12:26 pm	01/17/2025 12:46 pm	Bldg. Aux Building First Flr Break Rm Dup	< 0.4
8672349	5167120	01/15/2025 12:26 pm	01/17/2025 12:46 pm	Bldg. Aux Building First Flr Break Rm	< 0.4
8672350	5167121	01/15/2025 12:22 pm	01/17/2025 12:44 pm	Bldg. Main First Flr 1st Floor Office	< 0.4
8672351	5167122	01/15/2025 12:15 pm	01/17/2025 12:40 pm	Building Main Basement Break Room	0.4
8672352	5167123	01/15/2025 12:17 pm	01/17/2025 12:41 pm	Building Main Basement Office 4	< 0.4
8672353	5167124	01/15/2025 12:17 pm	01/17/2025 12:41 pm	Bldg Main Basement Office 4 Blank	< 0.4
8672354	5167125	01/15/2025 12:19 pm	01/17/2025 12:42 pm	Building Main Basement Office 3	< 0.4
8672355	5167126	01/15/2025 12:19 pm	01/17/2025 12:42 pm	Bldg Main Basement Office 3 Dup	0.6
8672356	5167127	01/15/2025 12:20 pm	01/17/2025 12:42 pm	Building Main Basement Office 2	0.4
8672357	5167128	01/15/2025 12:21 pm	01/17/2025 12:42 pm	Bldg Main Basement Office 1 Rm 2	0.4

Comment: Confidential: Release results to EHS only.

Test Performed By: Placed: Catherine Bourne 17SS012 Retrieved: Catherine Bourne 17SS012

Distributed by: Environmental Hazards Services

Date Received: 01/22/2025 Date Logged: 01/22/2025 Date Analyzed: 01/23/2025 Date Reported: 01/23/2025

Report Reviewed By: 

Report Approved By: 

Disclaimer:

Shawn Price, Director of Laboratory Operations, AccuStar Labs

The counting uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Laboratory personnel were not involved in the placement or retrieval of the samples. Analytical results relate to the samples as received by the laboratory. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NELAC NY 11769
NRPP 101193 AL
NRSB ARL0017

EPA Method #402-R-92-004
Liquid Scintillation
NRPP Device Code 8088
NRSB Device Code 12193

Laboratory Report for:

Property Tested: Project # 47:11652-X

ECS Mid-Atlantic
14026 Thunderbolt Place Suite 100
Chantilly VA 20151

ACPS Transportation Department
3540 Wheeler Avenue
Alexandria VA 22304


Log Number	Device Number	Test	Exposure	Duration	Area Tested	Result pCi/L
8672358	5167129	01/15/2025	12:21 pm	01/17/2025 12:42 pm	Bldg Main Basement Office 1 Rm 1	0.4

Comment: Confidential: Release results to EHS only.

Test Performed By: Placed: Catherine Bourne 17SS012 Retrieved: Catherine Bourne 17SS012

Distributed by: Environmental Hazards Services

Date Received: 01/22/2025 Date Logged: 01/22/2025 Date Analyzed: 01/23/2025 Date Reported: 01/23/2025

Report Reviewed By: 

Report Approved By: 

Disclaimer:

Shawn Price, Director of Laboratory Operations, AccuStar Labs

The counting uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Laboratory personnel were not involved in the placement or retrieval of the samples. Analytical results relate to the samples as received by the laboratory. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.