

Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Tuesday, March 4, 2025
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78020.

First Draw samples flushed by Martel on November 26, 2024 sampled by Martel on November 27, 2024.

Project Identification: MD HB 270

School: McDonough HS

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 1	MHS-1-FC	11/27/2024 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 2	MHS-2-FC	11/27/2024 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 3	MHS-3-DF	11/27/2024 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 4	MHS-4-DF	11/27/2024 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.94	ug/l*	EPA .200.8	2	02/19/2025 18:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 5	MHS-5-DF	11/27/2024 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 6	MHS-6-DF	11/27/2024 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:23 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 7	MHS-7-DF-C	11/27/2024 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:26 BJ

MARTEL NO. 78020 8 CLIENT SAMPLE IDENTIFICATION MHS-8-BF-C Sample Date/Time 11/27/2024 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:28 BJ

MARTEL NO. 78020 9 CLIENT SAMPLE IDENTIFICATION MHS-9-C-FC Sample Date/Time 11/27/2024 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:31 BJ

MARTEL NO. 78020 10 CLIENT SAMPLE IDENTIFICATION MHS-10-C-FC-B Sample Date/Time 11/27/2024 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:38 BJ

MARTEL NO. 78020 11 CLIENT SAMPLE IDENTIFICATION MHS-11-C-FC Sample Date/Time 11/27/2024 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:45 BJ

MARTEL NO. 78020 12 CLIENT SAMPLE IDENTIFICATION MHS-12-C-FC-B Sample Date/Time 11/27/2024 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:48 BJ

MARTEL NO. 78020 13 CLIENT SAMPLE IDENTIFICATION MHS-13-DF Sample Date/Time 11/27/2024 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:50 BJ

MARTEL NO. 78020 14 CLIENT SAMPLE IDENTIFICATION MHS-14-DF-C Sample Date/Time 11/27/2024 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 15	MHS-15-BF-C	11/27/2024 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:55 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 16	MHS-16-DF	11/27/2024 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 18:57 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 17	MHS-17-DF-C	11/27/2024 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:00 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 18	MHS-18-BF-C	11/27/2024 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 19	MHS-19-C-FC	11/27/2024 06:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:05 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 20	MHS-20-C-FC-B	11/27/2024 06:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 21	MHS-21-DF	11/27/2024 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:19 BJ

MARTEL NO. 78020 22 CLIENT SAMPLE IDENTIFICATION MHS-22-DF-C Sample Date/Time 11/27/2024 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:22 BJ

MARTEL NO. 78020 23 CLIENT SAMPLE IDENTIFICATION MHS-23-BF-C Sample Date/Time 11/27/2024 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:24 BJ

MARTEL NO. 78020 24 CLIENT SAMPLE IDENTIFICATION MHS-24-DF Sample Date/Time 11/27/2024 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:27 BJ

MARTEL NO. 78020 25 CLIENT SAMPLE IDENTIFICATION MHS-25-DF-C Sample Date/Time 11/27/2024 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:29 BJ

MARTEL NO. 78020 26 CLIENT SAMPLE IDENTIFICATION MHS-26-BF-C Sample Date/Time 11/27/2024 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:32 BJ

MARTEL NO. 78020 27 CLIENT SAMPLE IDENTIFICATION MHS-27-DF Sample Date/Time 11/27/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:34 BJ

MARTEL NO. 78020 28 CLIENT SAMPLE IDENTIFICATION MHS-28-DF Sample Date/Time 11/27/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.25	ug/l	EPA .200.8	2	02/19/2025 19:36 BJ

MARTEL NO. 78020 29 MHS-29-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:39 BJ

MARTEL NO. 78020 30 MHS-30-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 19:46 BJ

MARTEL NO. 78020 31 MHS-31-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.92	ug/l	EPA .200.8	2	02/19/2025 19:54 BJ

MARTEL NO. 78020 32 MHS-32-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.47	ug/l	EPA .200.8	2	02/19/2025 19:56 BJ

MARTEL NO. 78020 33 MHS-33-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.93	ug/l	EPA .200.8	2	02/19/2025 19:59 BJ

MARTEL NO. 78020 35 MHS-35-DF-C CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:01 BJ

MARTEL NO. 78020 36 MHS-36-BF-C CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/27/2024 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:04 BJ

MARTEL NO. 78020 37 CLIENT SAMPLE IDENTIFICATION MHS-37-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:06 BJ

MARTEL NO. 78020 38 CLIENT SAMPLE IDENTIFICATION MHS-38-KK Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:08 BJ

MARTEL NO. 78020 39 CLIENT SAMPLE IDENTIFICATION MHS-39-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.57	ug/l	EPA .200.8	2	02/19/2025 20:11 BJ

MARTEL NO. 78020 40 CLIENT SAMPLE IDENTIFICATION MHS-40-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.77	ug/l	EPA .200.8	2	02/19/2025 20:13 BJ

MARTEL NO. 78020 41 CLIENT SAMPLE IDENTIFICATION MHS-41-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.62	ug/l	EPA .200.8	2	02/19/2025 20:23 BJ

MARTEL NO. 78020 42 CLIENT SAMPLE IDENTIFICATION MHS-42-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.15	ug/l	EPA .200.8	2	02/19/2025 20:28 BJ

MARTEL NO. 78020 43 CLIENT SAMPLE IDENTIFICATION MHS-43-IM Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:30 BJ

MARTEL NO. 78020 44 CLIENT SAMPLE IDENTIFICATION MHS-44-FC Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.19	ug/l	EPA .200.8	2	02/19/2025 20:33 BJ

MARTEL NO. 78020 45 CLIENT SAMPLE IDENTIFICATION MHS-45-DF Sample Date/Time 11/27/2024 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.61	ug/l*	EPA .200.8	2	02/19/2025 20:35 BJ

MARTEL NO. 78020 46 CLIENT SAMPLE IDENTIFICATION MHS-46-C-FC Sample Date/Time 11/27/2024 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:38 BJ

MARTEL NO. 78020 47 CLIENT SAMPLE IDENTIFICATION MHS-47-C-FC-B Sample Date/Time 11/27/2024 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:40 BJ

MARTEL NO. 78020 48 CLIENT SAMPLE IDENTIFICATION MHS-48-DF Sample Date/Time 11/27/2024 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:43 BJ

MARTEL NO. 78020 49 CLIENT SAMPLE IDENTIFICATION MHS-49-DF Sample Date/Time 11/27/2024 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.12	ug/l*	EPA .200.8	2	02/19/2025 20:45 BJ

MARTEL NO. 78020 50 CLIENT SAMPLE IDENTIFICATION MHS-50-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.15	ug/l	EPA .200.8	2	02/19/2025 20:48 BJ

MARTEL NO. 78020 51 CLIENT SAMPLE IDENTIFICATION MHS-51-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 20:55 BJ

MARTEL NO. 78020 52 CLIENT SAMPLE IDENTIFICATION MHS-52-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.41	ug/l	EPA .200.8	2	02/19/2025 21:02 BJ

MARTEL NO. 78020 53 CLIENT SAMPLE IDENTIFICATION MHS-53-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.20	ug/l*	EPA .200.8	2	02/19/2025 21:05 BJ

MARTEL NO. 78020 54 CLIENT SAMPLE IDENTIFICATION MHS-54-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:07 BJ

MARTEL NO. 78020 55 CLIENT SAMPLE IDENTIFICATION MHS-55-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:10 BJ

MARTEL NO. 78020 56 CLIENT SAMPLE IDENTIFICATION MHS-56-FC Sample Date/Time 11/27/2024 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.73	ug/l*	EPA .200.8	2	02/19/2025 21:12 BJ

MARTEL NO. 78020 57 CLIENT SAMPLE IDENTIFICATION MHS-57-DF-C Sample Date/Time 11/27/2024 06:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:15 BJ

MARTEL NO. 78020 58 CLIENT SAMPLE IDENTIFICATION MHS-58-BF-C Sample Date/Time 11/27/2024 06:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:17 BJ

MARTEL NO. 78020 59 CLIENT SAMPLE IDENTIFICATION MHS-59-DF Sample Date/Time 11/27/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:20 BJ

MARTEL NO. 78020 60 CLIENT SAMPLE IDENTIFICATION MHS-60-DF-C Sample Date/Time 11/27/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:22 BJ

MARTEL NO. 78020 61 CLIENT SAMPLE IDENTIFICATION MHS-61-BF-C Sample Date/Time 11/27/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:32 BJ

MARTEL NO. 78020 62 CLIENT SAMPLE IDENTIFICATION MHS-62-DF Sample Date/Time 11/27/2024 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.12	ug/l	EPA .200.8	2	02/19/2025 21:37 BJ

MARTEL NO. 78020 63 CLIENT SAMPLE IDENTIFICATION MHS-63-DF Sample Date/Time 11/27/2024 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:39 BJ

MARTEL NO. 78020 64 CLIENT SAMPLE IDENTIFICATION MHS-64-DF Sample Date/Time 11/27/2024 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:42 BJ

MARTEL NO. 78020	65	MHS-65-DF	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 06:33
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:44 BJ

MARTEL NO. 78020	66	MHS-66-DF	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 06:36
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:46 BJ

MARTEL NO. 78020	67	MHS-67-DF	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 06:36
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:49 BJ

MARTEL NO. 78020	68	MHS-68-DF	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 06:36
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:51 BJ

MARTEL NO. 78020	69	MHS-69-IM	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 06:12
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:54 BJ

MARTEL NO. 78020	70	MHS-70-DF	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 05:55
---------------------	----	-----------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 21:56 BJ

MARTEL NO. 78020	71	MHS-71-DF-C	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time 11/27/2024 05:55
---------------------	----	-------------	------------------------------	--	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:04 BJ

MARTEL NO. 78020 72 CLIENT SAMPLE IDENTIFICATION MHS-72-BF-C Sample Date/Time 11/27/2024 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:11 BJ

MARTEL NO. 78020 19F CLIENT SAMPLE IDENTIFICATION MHS-19F-C-FC FLUSH Sample Date/Time 11/27/2024 07:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:14 BJ

MARTEL NO. 78020 20F CLIENT SAMPLE IDENTIFICATION MHS-20F-C-FC FLUSH Sample Date/Time 11/27/2024 07:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:16 BJ

MARTEL NO. 78020 38F CLIENT SAMPLE IDENTIFICATION MHS-38F-KK FLUSH Sample Date/Time 11/27/2024 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:19 BJ

MARTEL NO. 78020 39F CLIENT SAMPLE IDENTIFICATION MHS-39F-FC FLUSH Sample Date/Time 11/27/2024 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:21 BJ

MARTEL NO. 78020 40F CLIENT SAMPLE IDENTIFICATION MHS-40F-FC FLUSH Sample Date/Time 11/27/2024 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:24 BJ

MARTEL NO. 78020 41F CLIENT SAMPLE IDENTIFICATION MHS-41F-FC FLUSH Sample Date/Time 11/27/2024 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:26 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 42F	MHS-42F-FC FLUSH	11/27/2024 06:57			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:28 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 44F	MHS-44F-FC FLUSH	11/27/2024 06:57			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:31 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 50F	MHS-50F-FC FLUSH	11/27/2024 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 51F	MHS-51F-FC FLUSH	11/27/2024 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 52F	MHS-52F-FC FLUSH	11/27/2024 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 53F	MHS-53F-FC FLUSH	11/27/2024 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78020 54F	MHS-54F-FC FLUSH	11/27/2024 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:56 BJ

MARTEL NO. 78020	55F	CLIENT SAMPLE IDENTIFICATION MHS-55F-FC FLUSH	Sample Date/Time 11/27/2024 06:44
---------------------	-----	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 22:58 BJ

MARTEL NO. 78020	56F	CLIENT SAMPLE IDENTIFICATION MHS-56F-FC FLUSH	Sample Date/Time 11/27/2024 06:44
---------------------	-----	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/19/2025 23:01 BJ

MARTEL Chain of Custody Record

Martel Laboratories (US) Inc. 1025 Cromwell Bridge Rd. Baltimore, MD 21286. (410) 825-7790. FAX (410) 821-1054. email: martel@martelabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/27/24 5:34am End Date/Time: 11/27/24 7:02am

Sampler/Relinquished By: Norverson Simms Clark Received at Martel by: _____ Date/Time: 11/27/24

55- Maurice J. McDonough HS
First Draw

7165 Marshall Corner Road Pomfret, MD 20675

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78020

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubble, Water Fountain, Canteen, Ice Machine, Hot Dish)	Outlet Res. Code	Room/Location	Consumption C or H2	Flush	Sample Time
							Flush Date	
1	1	MHS-1-FC	Sink	FC	Rm A010 Faculty Work Room	C	11/26	5:34
2	2	MHS-2-FC	Sink	FC	Rm A027 Guidance Room	C	11/26	5:37
3	3	MHS-3-DF	water fountain - Left	DF	Corridor	C	11/26	5:37
4	4	MHS-4-DF	water fountain - Center	DF	Corridor	C	11/26	5:37
5	5	MHS-5-DF	water fountain - Right	DF	Corridor	C	11/26	5:37
6	6	MHS-6-DF	Water Fountain - High	DF	Corridor	C	11/26	5:37 5:44
7	7	MHS-7-DF-C	Water Fountain - Low	DF-C	Corridor	C	11/26	5:44
8	8	MHS-8-BF-C	Bottle Filler	BF-C	Corridor	C	11/26	5:44
9	9	MHS-9-C-FC	Sink	C-FC	Rm 159 Chorus	C	11/26	6:02
10	10	MHS-10-C-FC-B	Bubbler	C-FC-B	Rm 159 Chorus	C	11/26	6:02
11	11	MHS-11-C-FC	Sink	C-FC	Rm 163.5 Storage - Band	C	11/26	5:39
12	12	MHS-12-C-FC-B	Bubbler	C-FC-B	Rm 163.5 Storage - Band	C	11/26	5:39
13	13	MHS-13-DF	Water Fountain - High	DF	Corridor (Left)	C	11/26	5:42
14	14	MHS-14-DF-C	Water Fountain - Low	DF-C	Corridor (Left)	C	11/26	5:42
15	15	MHS-15-BF-C	Bottle Filler	BF-C	Corridor (Left)	C	11/26	5:42
16	16	MHS-16-DF	Water Fountain - High	DF	Corridor (Right)	C	11/26	5:42
17	17	MHS-17-DF-C	Water Fountain - Low	DF-C	Corridor (Right)	C	11/26	5:42
18	18	MHS-18-BF-C	Bottle Filler	BF-C	Corridor (Right)	C	11/26	5:42
19	19	MHS-19-C-FC	Sink	C-FC	Rm 181 Nurse	C	11/26	6:04
20	20	MHS-20-C-FC-B	Bubbler	C-FC-B	Rm 181 Nurse	C	11/26	6:04
21	21	MHS-21-DF	Water Fountain - High	DF	Corridor	C	11/26	5:50
22	22	MHS-22-DF-C	Water Fountain - Low	DF-C	Corridor	C	11/26	5:50
23	23	MHS-23-BF-C	Bottle Filler	BF-C	Corridor	C	11/26	5:50
24	24	MHS-24-DF	Water Fountain - High	DF	Corridor	C	11/26	5:50

55- Maurice J. McDonough HS

First Draw

7165 Marshall Corner Road Pomfret, MD 20675

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

							Flush	Martel NO: 78020
25	25	MHS-25-DF-C	Water Fountain - Low	DF-C	Corridor	C	11/26	5:50
26	26	MHS-26-BF-C	Bottle Filler	BF-C	Corridor	C	11/26	5:50
27	27	MHS-27-DF	water fountain - Left	DF	Corridor	C	11/26	6:00
28	28	MHS-28-DF	water fountain - Right	DF	Corridor	C	11/26	6:00
29	29	MHS-29-DF	water fountain - Left	DF	Corridor	C	11/26	6:00
30	30	MHS-30-DF	water fountain - Right	DF	Corridor	C	11/26	6:00
31	31	MHS-31-FC	Sink	FC	Teachers Lounge	C	11/26	6:06
32	32	MHS-32-DF	water fountain - Left	DF	Café	C	11/26	6:07
33	33	MHS-33-DF	water fountain - Right	DF	Café	C	11/26	6:07
34	34	MHS-34-DF	Water Fountain - High	DF	Corridor	C	NO SAMP	NO SAMP
35	35	MHS-35-DF-C	Water Fountain - Low	DF-C	Corridor	C	11/26	6:09
36	36	MHS-36-BF-C	Bottle Filler	BF-C	Corridor	C	11/26	6:09
37	37	MHS-37-FC	Island sink next to 3 comp sink	FC	Kitchen	C	11/26	6:18
38	38	MHS-38-KK	Kettle	KK	Kitchen	C	11/26	6:18
39	39	MHS-39-FC	Left fixture on 3 comp sink	FC	Kitchen	C	11/26	6:18
40	40	MHS-40-FC	Right fixture on 3 comp sink	FC	Kitchen	C	11/26	6:18
41	41	MHS-41-FC	Island sink	FC	Kitchen	C	11/26	6:18
42	42	MHS-42-FC	Island sink near ice maker	FC	Kitchen	C	11/26	6:18
43	43	MHS-43-IM	Ice Machine	IM	Kitchen	C	11/26	6:18
44	44	MHS-44-FC	2 comp sink	FC	Kitchen	C	11/26	6:18
45	45	MHS-45-DF	Water fountain	DF	Kitchen	C	11/26	6:18
46	46	MHS-46-C-FC	Sink	C-FC	LH-1B/ child care	C	11/26	6:20
47	47	MHS-47-C-FC-B	Bubbler	C-FC-B	LH-1B/ child care	C	11/26	6:20
48	48	MHS-48-DF	water fountain - Left	DF	Corridor	C	11/26	6:22
49	49	MHS-49-DF	water fountain - Right	DF	Corridor	C	11/26	6:22
50	50	MHS-50-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
51	51	MHS-51-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
52	52	MHS-52-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
53	53	MHS-53-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
54	54	MHS-54-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
55	55	MHS-55-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25
56	56	MHS-56-FC	sink - See map	FC	FCS-1/ home ec	C	11/26	6:25

55- Maurice J. McDonough HS

First Draw

7165 Marshall Corner Road Pomfret, MD 20675

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

							Flush	Martel NO: 78020
57	57	MHS-57-DF-C	Bottle Filler	DF-C	Corridor - next to ROTC	C	11/26	6:28
58	58	MHS-58-BF-C	water fountain	BF-C	FCS-1/ ROTC	C	11/26	6:28
59	59	MHS-59-DF	water fountain - Left	DF	Corridor	C	11/26	6:29
60	60	MHS-60-DF-C	water fountain - Right	DF-C	Corridor	C	11/26	6:29
61	61	MHS-61-BF-C	Bottle Filler - Right	BF-C	Corridor	C	11/26	6:29
62	62	MHS-62-DF	water fountain - Left	DF	Corridor - (2nd Floor)	C	11/26	6:32
63	63	MHS-63-DF	water fountain - Right	DF	Corridor - (2nd Floor)	C	11/26	6:32
64	64	MHS-64-DF	water fountain - Left	DF	Corridor - (2nd Floor)	C	11/26	6:33
65	65	MHS-65-DF	water fountain - Right	DF	Corridor - (2nd Floor)	C	11/26	6:33
66	66	MHS-66-DF	water fountain	DF	Media center - (2nd Floor)	C	11/26	6:36
67	67	MHS-67-DF	water fountain - Left	DF	Coorridor - (2nd Floor)	C	11/26	6:36
68	68	MHS-68-DF	water fountain - Right	DF	Coorridor - (2nd Floor)	C	11/26	6:36
69	69	MHS-69-IM	Ice Machine	IM	training room - (Basement)	C	11/26	6:12
70	70	MHS-70-DF	Water Fountain - High	DF	Corridor - (Basement)	C	11/26	5:55
71	71	MHS-71-DF-C	Water Fountain - Low	DF-C	Corridor - (Basement)	C	11/26	5:55
72	72	MHS-72-BF-C	Bottle Filler	BF-C	Corridor - (Basement)	C	11/26	5:55
73	73	MHS-73-HB	Hose bib	HB	Outside concession stand see map	C		
74	74	MHS-74-FC	2 comp sink	FC	Outside concession stand see map	C		
75	75	MHS-75-IM	Ice Machine	IM	Outside concession stand see map	C		
76	76	MHS-76-SP	Spigot	SP	Outside upper behind the North, behind the water meter compartment	C		
77	19F	MHS-19F-C-FC	Sink	C-FC	Rm 181 Nurse	C		FLUSH 7:02
78	20F	MHS-20F-C-FC-B	Bubbler	C-FC-B	Rm 181 Nurse	C		FLUSH 7:02
79	38F	MHS-38F-KK	Kettle	KK	Kitchen	C		FLUSH 6:57
80	39F	MHS-39F-FC	Left fixture on 3 comp sink	FC	Kitchen	C		FLUSH 6:57
81	40F	MHS-40F-FC	Right fixture on 3 comp sink	FC	Kitchen	C		FLUSH 6:57
82	41F	MHS-41F-FC	Island sink	FC	Kitchen	C		FLUSH 6:57
83	42F	MHS-42F-FC	Island sink near ice maker	FC	Kitchen	C		FLUSH 6:57
84	44F	MHS-44F-FC	2 comp sink	FC	Kitchen	C		FLUSH 6:57
85	45F	MHS-45F-DF	Water fountain	DF	Kitchen	C		FLUSH 6:57
86	50F	MHS-50F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44
87	51F	MHS-51F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44
88	52F	MHS-52F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44

55- Maurice J. McDonough HS

First Draw

7165 Marshall Corner Road Pomfret, MD 20675

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

							Flush	Martel NO:
89	S3F	MHS-53F-FC	sink - See map	FC	FCS-1/ home ec	C		78020
90	S4F	MHS-54F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44
91	S5F	MHS-55F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44
92	S6F	MHS-56F-FC	sink - See map	FC	FCS-1/ home ec	C		FLUSH 6:44

P 18