



# KINGSWAY REGIONAL SCHOOL DISTRICT

*Committed to Excellence*

*Mr. Jason Schimpf  
School Business Administrator*

*Dr. James J. Lavender  
Superintendent of Schools*

*Ms. Patricia Calandro  
Assistant Superintendent*

February 2025

The Kingsway Regional School District is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for the Kingsway Middle School drinking water locations was performed in February 2025. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15 micrograms per Liter ( $\mu\text{g/L}$ ). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for, water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet.

A summary of each location above the action level, as well as the short-term response, is found below:

## Kingsway Regional Middle School

SAMPLE LOCATION	FIRST DRAW RESULT	SHORT TERM RESPONSE
Kettle Filler – Kitchen	22.5 $\mu\text{g/L}$	Taken out of service