



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email: info@envirovisionconsultants.com
NJ DON JENA Lic. # 1097

CLIENT: Scotch Plains – Fanwood School District Project No. 24-130
PROJECT: Lead (Pb) in Water Sampling McGinn Elementary School
ADDRESS: 1100 Roosevelt Ave, Scotch Plains, NJ 07076
FIELD TECHNICIAN(S) Jordan Pryske
REPORT DATE: August 29, 2024

As per your request, EnviroVision Consultants, Inc. was contracted by Scotch Plains – Fanwood School District to conduct Lead (Pb) in water sampling at the McGinn Elementary School on August 8, 2024. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district was to perform the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at EMSL Analytical Inc. in Cinnaminson, New Jersey *(NJDEP# 03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Twenty-nine samples were collected from McGinn Elementary School. A blank sample was also collected and analyzed as required.

Results: Twenty-four of the twenty-nine samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water of 15 parts per billion (ppb). The action level has been further defined for compliance by the New Jersey Department of Environmental Protection Agency as an amount greater than or equal to 15.5 ug/L (1ug/L = 1ppb). When a water outlet/faucet meets or exceeds the USEPA/NJDEP threshold, EnviroVision recommends that the outlet/faucet be immediately put out of service until the system can be further evaluated and proper remedial action is achieved.



MCGINN ELEMENTARY SCHOOL – LEAD (Pb) in Water Results of Concern

Outlet ID/Sample Number	Location	Results
MG.DW.FL-1.103	Classroom 103	33.1 ug/L (ppb)
MG.DW.FL-1.131	Classroom 131	50.5 ug/L (ppb)
MG.DW.FL-1.134	Classroom 134	17.6 ug/L (ppb)
MG.DW.FL-1.136	Classroom 136	64.2 ug/L (ppb)
MG.DW.FL-1.137	Classroom 137	81.5 ug/L (ppb)

Due to the elevated levels in the above outlets, we recommend some or all of the following steps be taken at this time;

- Closure of the affected water outlet until the system can be further evaluated and proper remedial action is achieved.
- Removal and replacement with non-containing lead fixtures
- Installation of filtration systems.
- Development of a Flushing Program for those taps high in lead and turbidity (this may include automatic flushing systems).
- Contact the local water utility company to obtain information about their corrosion control procedures and how it might affect the District's control plans.
- Permanent closure of outlet(s).

Once the remedial action(s) are complete, follow up testing is required to ensure alterations/replacement to plumbing fixtures has lowered the amount of lead to acceptable levels.

I have also enclosed documents with detailed steps from the New Jersey Department of Environmental Protection regarding notifications that must be made, posting of results, and initial and long-term remedial requirements.



Page 3 (McGinn Elementary School)

Project Number 24-130

Any water outlet used for drinking, food preparation, etc. that has not been tested, must be sampled prior to being utilized and/or put back into service. If you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager Attached: Lab results, Associated data sheets,
DEP Overview of Lead in Drinking Water at School Facilities, DEP Guidance for
Selecting a Remedial Measure for Lead Removal

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MG.WL.FL-1.159ABF/Hallway By 159 / Bottle Filler Only Lims Reference ID: AC26461-01 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.7L.FL-1.115/Teachers Lounge (Room 115) Sink Lims Reference ID: AC26461-02 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	1.86		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.WL.FL-1.MPRBF/Room 111 (MPR Room) Bottle Filler Only Lims Reference ID: AC26461-03 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.WL.FL-1.112-1BF/Hallway By 112 Bottle Filler Only Lims Reference ID: AC26461-04 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.103/Room 103 / Bubblers Lims Reference ID: AC26461-05 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	33.1		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.105/Room 105 / Bubblers Lims Reference ID: AC26461-06 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	3.68		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.107/Room 107 / Bubblers Lims Reference ID: AC26461-07 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	7.11		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.108/Room 108 / Bubblers Lims Reference ID: AC26461-08 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	2.37		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.128/Room 128 / Bubblers Lims Reference ID: AC26461-09 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MG.DW.FL-1.128/Room 128 / Bubbler (Continued) Lims Reference ID: AC26461-09 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	3.50		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.116/Room 116 / Bubbler Lims Reference ID: AC26461-10 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	7.89		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.117/Room 117 / Bubbler Lims Reference ID: AC26461-11 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	7.45		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.119/Room 119 / Bubbler Lims Reference ID: AC26461-12 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	14.8		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.120/Room 120 / Bubbler Lims Reference ID: AC26461-13 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	5.65		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.121/Room 121 / Bubbler Lims Reference ID: AC26461-14 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	7.24		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.123/Room 123 / Bubbler Lims Reference ID: AC26461-15 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	10.6		1	1.00	µg/L	08/22/24 11:55	08/27/24 17:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.122/Room 122 / Bubbler Lims Reference ID: AC26461-16 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	4.75		1	1.00	µg/L	08/22/24 11:59	08/27/24 17:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.WL.FL-1.142ABF/Hall By 142A / Bottle Filler Only Lims Reference ID: AC26461-17 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:01	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: MG.WL.FL-1.142ABF/Hall By 142A / Bottle
Filler Only (Continued)

Lims Reference ID: AC26461-17 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals (Continued)

Sample: MG.DW.FL-1.130/Room 130 / Bubbler

Lims Reference ID: AC26461-18 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	7.36	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:03	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.131/Room 131 / Bubbler

Lims Reference ID: AC26461-19 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	50.5	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:05	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.133/Room 133 / Bubbler

Lims Reference ID: AC26461-20 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	14.0	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:06	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.134/Room 134 / Bubbler

Lims Reference ID: AC26461-21 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	17.6	1	1.00	µg/L	08/22/24 16:52	08/27/24 17:36	JW1	EPA 200.8 (Dig)/EPA 200.8
------	------	---	------	------	----------------	----------------	-----	---------------------------

Sample: MG.DW.FL-1.136/Room 136 / Bubbler

Lims Reference ID: AC26461-22 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	64.2	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:12	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.137/Room 137 / Bubbler

Lims Reference ID: AC26461-23 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	81.5	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:14	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.148/Room 148 / Bubbler

Lims Reference ID: AC26461-24 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	1.09	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:16	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: MG.DW.FL-1.149/Room 149 / Bubbler

Lims Reference ID: AC26461-25 Matrix: Drinking Water

Sampled: 08/08/24 00:00:00

Metals

Lead	ND	1	1.00	µg/L	08/22/24 11:59	08/27/24 18:18	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MG.DW.FL-1.150/Room 150 / Bubbler Lims Reference ID: AC26461-26 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	1.63		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.151/Room 151 / Bubbler Lims Reference ID: AC26461-27 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	1.39		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.152/Room 152 / Bubbler Lims Reference ID: AC26461-28 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	1.10		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.DW.FL-1.152A/Room 152 / Bubbler Lims Reference ID: AC26461-29 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MG.bLANK/Blank Lims Reference ID: AC26461-30 Matrix: Drinking Water Sampled: 08/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/22/24 11:59	08/27/24 18:35	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2024
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2024
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2024
California ELAP	California Water Boards	1877	06/30/2024
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2024

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012426461**LIMS Reference ID:** AC26461**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Scotch Plains - McGinn Elementary School

Customer PO:**EMSL Sales Rep:**

Gary Perlmutter

Received:

08/09/2024 09:00

Reported:

08/28/2024 16:56


Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
E	Result is beyond calibration range. This value is estimated.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



20-21 Wagaraw Road -- Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT Scotch Plains Board of Education

PROJECT Scotch Plains - McGinn Elementary School

TECH Jordan Prysko

ADDRESS

ADDRESS

SAMPLING DATE

TECH

512 Cedar Street, Scotch Plains, NJ 07076

1100 Roosevelt Ave, Scotch Plains, NJ 07076

Jordan Prysko

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
MB-WC-FL-1.159ABF	8/8/24 0847	Hallway by 159	Bottle Filler Only (New)
MB-TL-FL-1.115	8/8/24 0850	Teachers Lounge (Room 115)	Sink
MB-WC-FL-1.102-106F	8/8/24 0852	Room 111 (In PR Room)	Bottle Filler Only (New)
MB-WC-FL-1.112-106F	8/8/24 0854	Hallway by 112	Bottle Filler Only (Foundations Capped)
MB-DW-FL-1.103	8/8/24 1130	Room 103	Bubbler
MB-DW-FL-1.105	8/8/24 1133	Room 105	Bubbler
MB-DW-FL-1.107	8/8/24 1135	Room 107	Bubbler
MB-DW-FL-1.108	8/8/24 1137	Room 108	Bubbler
MB-DW-FL-1.108	8/8/24 1140	Room 108	Bubbler
MB-DW-FL-1.116	8/8/24 1143	Room 116	Bubbler

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
J. Prysko 8/8/24	Mary Sadler	08/08/24 1:10pm
	W. Sadler	8-8-24 1940

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 DAYS / WEEKS


EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY
SUBMITTED TO:

LAB ORDER #

Enviro

Monday 8/09/24 9am



20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

26461

CLIENT	Scotch Plains Board of Education	ADDRESS	512 Cedar Street, Scotch Plains, NJ 07076
PROJECT	Scotch Plains - McGinn Elementary School	ADDRESS	1100 Roosevelt Ave, Scotch Plains, NJ 07076
TECH	Jordan Prysko	SAMPLING DATE	8/8/24
		TECH	Jordan Prysko

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
MB.Dw.FL-1.117	8/8/24 1144	Room 117	Bubbler
MB.Dw.FL-1.119	8/8/24 1147	Room 119	Bubbler
MB.Dw.FL-1.120	8/8/24 1150	Room 120	Bubbler
MB.Dw.FL-1.121	8/8/24 1152	Room 121	Bubbler
MB.Dw.FL-1.123	8/8/24 1155	Room 123	Bubbler
MB.Dw.FL-1.128	8/8/24 1156	Room 122	Bubbler
MB.Dw.FL-1.130	8/8/24 1158	Hall by 142A	Bottle Filler Only (Fountains Capped)
MB.Dw.FL-1.132	8/8/24 1200	Room 130	Bubbler
MB.Dw.FL-1.131	8/8/24 1201	Room 131	Bubbler
MB.Dw.FL-1.133	8/8/24 1203	Room 133	Bubbler
MB.Dw.FL-1.134	8/8/24 1205	Room 134	Bubbler
MB.Dw.FL-1.136	8/8/24 1207	Room 136	Bubbler
MB.Dw.FL-1.137	8/8/24 1210	Room 137	Bubbler
MB.Dw.FL-1.148	8/8/24 1213	Room 148	Bubbler
MB.Dw.FL-1.149	8/8/24 1215	Room 149	Bubbler
MB.Dw.FL-1.150	8/8/24 1221	Room 150	Bubbler
MB.Dw.FL-1.151	8/8/24 1225	Room 151	Bubbler
MB.Dw.FL-1.152	8/8/24 1227	Room 152	Bubbler



PROJECT	Scotch Plains – McGinn Elementary School
---------	--

TECH	Jordan Prysko
------	---------------

CLIENT | Scotch Plains Board of Education

PROJECT	Scotch Plains – McGinn Elementary School
---------	--

TECH	Jordan Prysko
------	---------------

ADDRESS

ADDRESS

SAMPLING DATE

512 Cedar Street, Scotch Plains, NJ 07076

1100 Roosevelt Ave, Scotch Plains, NJ 07076

TECH	Jordan Prysko
------	---------------

LEAD IN DRINKING WATER DATA SHEET

[illegible]