

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 12/11/2024	CLIENT/CLIENT ADDRESS Environmental Testing & Inspection 15784 Martin Street NW Andover, MN 55304	SCHOOL/ADDRESS Lincoln Elementary/ECFE Glencoe-Silver Lake Public Schools
REPORT #: 24-14648		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 11/25/2024 at 13:20	TEMP OF SAMPLE UPON RECEIPT: 19 °C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---	---------------------------------------	--

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	Action Level*	RESULT
24-14648	Lead	Early Childhood - DF South	11/23/2024	13:20	12/9/2024	13:10	SM3113B-93	5 µg/L	<2.00 µg/L
24-14649	Lead	Early Childhood- DF North	11/23/2024	13:22	12/9/2024	13:28	SM3113B-93	5 µg/L	<2.00 µg/L
24-14650	Lead	Gymnasium - BF	11/23/2024	13:26	12/9/2024	14:05	SM3113B-93	5 µg/L	<2.00 µg/L
24-14651	Lead	Room 217 - DF	11/23/2024	13:34	12/9/2024	14:11	SM3113B-93	5 µg/L	6.02 µg/L
24-14652	Lead	Room 215 - DF	11/23/2024	13:40	12/9/2024	14:17	SM3113B-93	5 µg/L	<2.00 µg/L
24-14653	Lead	Room 214 - DF	11/23/2024	13:45	12/9/2024	14:23	SM3113B-93	5 µg/L	<2.00 µg/L
24-14654	Lead	Room 207 - DF	11/23/2024	13:50	12/9/2024	14:29	SM3113B-93	5 µg/L	<2.00 µg/L
24-14655	Lead	2nd Floor Hall - BF South	11/23/2024	13:55	12/9/2024	14:35	SM3113B-93	5 µg/L	<2.00 µg/L
24-14656	Lead	2nd Floor Hall - BF North	11/23/2024	13:58	12/9/2024	14:41	SM3113B-93	5 µg/L	<2.00 µg/L
24-14657	Lead	Room 212 - DF	11/23/2024	14:00	12/9/2024	14:47	SM3113B-93	5 µg/L	<2.00 µg/L
24-14658	Lead	Room 210 - DF	11/23/2024	14:05	12/9/2024	14:53	SM3113B-93	5 µg/L	<2.00 µg/L
24-14659	Lead	Room 209 - DF	11/23/2024	14:06	12/10/2024	11:16	SM3113B-93	5 µg/L	<2.00 µg/L
24-14660	Lead	Room 153 - DF	11/23/2024	14:15	12/10/2024	11:22	SM3113B-93	5 µg/L	<2.00 µg/L
24-14661	Lead	Room 155 - DF	11/23/2024	14:18	12/10/2024	11:28	SM3113B-93	5 µg/L	<2.00 µg/L
24-14662	Lead	1st Floor Hall - BF North	11/23/2024	14:20	12/10/2024	11:34	SM3113B-93	5 µg/L	<2.00 µg/L
24-14663	Lead	1st Floor Hall - BF South	11/23/2024	14:24	12/10/2024	11:41	SM3113B-93	5 µg/L	<2.00 µg/L
24-14664	Lead	Room 150 - DF	11/23/2024	14:27	12/10/2024	11:47	SM3113B-93	5 µg/L	<2.00 µg/L
24-14665	Lead	Room 149 - DF	11/23/2024	14:30	12/10/2024	12:05	SM3113B-93	5 µg/L	<2.00 µg/L
24-14666	Lead	Room 156 - DF	11/23/2024	14:35	12/10/2024	12:23	SM3113B-93	5 µg/L	2.11 µg/L
24-14667	Lead	Room 158 - DF	11/23/2024	14:40	12/10/2024	12:29	SM3113B-93	5 µg/L	<2.00 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

DF = Drinking Fountain, BF = Bottle Filler
Samples preserved on 11/26/2024 at 14:00.

APPROVED BY:



Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.