

# Drinking Water Laboratory Test Report

## CLIENT INFORMATION

REPORT ISSUE DATE:

12/11/2024

REPORT #:

24-14668

CLIENT/CLIENT ADDRESS

Environmental Testing & Inspection  
15784 Martin Street NW  
Andover, MN 55304

SCHOOL/ADDRESS

Senior High School  
Glencoe-Silver Lake Public Schools

## SAMPLE INFORMATION

RECEIPT DATE/TIME:

11/25/2024 at 13:20

TEMP OF SAMPLE UPON RECEIPT:

19 °C

COLLECTED BY:

☐ TCWC

☒ CLIENT

☐ Other


LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	Action Level*	RESULT
24-14668	Lead	Girl's Swim Locker Room - DF	11/23/2024	15:30	12/10/2024	12:35	SM3113B-93	5 µg/L	<2.00 µg/L
24-14669	Lead	Lobby - BF	11/23/2024	15:33	12/10/2024	12:41	SM3113B-93	5 µg/L	<2.00 µg/L
24-14670	Lead	Front Office Restroom Hall - BF	11/23/2024	15:40	12/10/2024	12:47	SM3113B-93	5 µg/L	<2.00 µg/L
24-14671	Lead	Room 123 Hall - BF	11/23/2024	15:45	12/10/2024	12:53	SM3113B-93	5 µg/L	<2.00 µg/L
24-14672	Lead	Nurse's Office Hall - DF	11/23/2024	15:46	12/10/2024	12:59	SM3113B-93	5 µg/L	<2.00 µg/L

\*The action level is determined by MN Statute 121A.335.

## NOTES

DF = Drinking Fountain, BF = Bottle Filler  
Samples preserved on 11/26/2024 at 14:00.

APPROVED BY:



Frances Turner - Laboratory Director

## Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.