



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
info@twincitywaterclinic.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:

12/11/2024

REPORT #:

24-14681

CLIENT/CLIENT ADDRESS

Environmental Testing & Inspection
15784 Martin Street NW
Andover, MN 55304

SCHOOL/ADDRESS

Lakeside Elementary - Silver Lake & Field House
Glencoe-Silver Lake Public Schools

SAMPLE INFORMATION

RECEIPT DATE/TIME:

11/25/2024 at 13:20

TEMP OF SAMPLE UPON RECEIPT:

19 °C

COLLECTED BY:

☐ TCWC

☒ CLIENT

☐ Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	Action Level*	RESULT
24-14681	Lead	Media Center Hall - BF	11/24/2024	12:10	12/10/2024	12:21	SM3113B-93	5 µg/L	<2.00 µg/L
24-14682	Lead	Room 31 - Hall BF	11/24/2024	12:12	12/10/2024	12:27	SM3113B-93	5 µg/L	<2.00 µg/L
24-14683	Lead	Gymnasium Hall - BF	11/24/2024	12:15	12/10/2024	12:33	SM3113B-93	5 µg/L	<2.00 µg/L
24-14684	Lead	Band Room Hall - BF	11/24/2024	12:17	12/10/2024	12:39	SM3113B-93	5 µg/L	<2.00 µg/L
24-14685	Lead	Multi-Purpose Hall - DF	11/24/2024	12:20	12/10/2024	12:57	SM3113B-93	5 µg/L	<2.00 µg/L
24-14686	Lead	Multi-Purpose - BF	11/24/2024	12:22	12/10/2024	13:16	SM3113B-93	5 µg/L	<2.00 µg/L
24-14687	Lead	Kitchen Faucet - Cooking	11/24/2024	12:25	12/10/2024	13:22	SM3113B-93	5 µg/L	<2.00 µg/L
24-14688	Lead	Boy's Locker Room Hall - DF	11/24/2024	12:26	12/10/2024	13:28	SM3113B-93	5 µg/L	<2.00 µg/L
24-14689	Lead	Field House #1	11/23/2024	15:15	12/10/2024	13:33	SM3113B-93	5 µg/L	<2.00 µg/L
24-14690	Lead	Field House #2	11/23/2024	15:18	12/10/2024	13:39	SM3113B-93	5 µg/L	<2.00 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

DF = Drinking Fountain, BF = Bottle Filler
Samples preserved on 11/26/2024 at 14:00.

APPROVED BY:

Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.