



617 13th Ave S.,
Hopkins, MN 55343
(952) 935-3556
info@twincitywaterclinic.com

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 12/11/2024	CLIENT/CLIENT ADDRESS Environmental Testing & Inspection 15784 Martin Street NW Andover, MN 55304	SCHOOL/ADDRESS Junior High Glencoe-Silver Lake Public Schools
REPORT #: 24-14673		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 11/25/2024 at 13:20	TEMP OF SAMPLE UPON RECEIPT: 19 °C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---	---------------------------------------	--

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	Action Level*	RESULT
24-14673	Lead	Kitchen Faucet - Cooking South	11/23/2024	14:50	12/10/2024	13:05	SM3113B-93	5 µg/L	<2.00 µg/L
24-14674	Lead	Kitchen Faucet - Cooking North	11/23/2024	14:52	12/10/2024	13:11	SM3113B-93	5 µg/L	<2.00 µg/L
++24-14675	Lead	Cafeteria - BF West	11/23/2024	14:57	12/10/2024	11:33	SM3113B-93	5 µg/L	<2.00 µg/L
24-14676	Lead	Cafeteria - BF East	11/23/2024	14:58	12/10/2024	11:51	SM3113B-93	5 µg/L	<2.00 µg/L
24-14677	Lead	Gymnasium - DF West	11/23/2024	15:00	12/10/2024	11:57	SM3113B-93	5 µg/L	<2.00 µg/L
24-14678	Lead	Gymnasium - DF East	11/23/2024	15:05	12/10/2024	12:03	SM3113B-93	5 µg/L	<2.00 µg/L
24-14679	Lead	Boy's Locker Room - BF	11/23/2024	15:10	12/10/2024	12:09	SM3113B-93	5 µg/L	<2.00 µg/L
24-14680	Lead	Girl's Locker Room - BF	11/23/2024	15:12	12/10/2024	12:15	SM3113B-93	5 µg/L	<2.00 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

DF = Drinking Fountain, BF = Bottle Filler
Samples preserved on 11/26/2024 at 14:00.

++Matrix spike and matrix spike duplicate were low and therefore did not meet method criteria. Although method criteria was not met, the result for the sample is valid and reportable as TCWC's SOP was followed.

APPROVED BY:

Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.