June 3, 2024

Steve Aldrich
Liberty School District
801 Kent Street
Liberty, Missouri 64068

**Project: Limited Lead in Drinking Water Testing**
**Address: 600 West Kansas Street, Liberty, Missouri 64068**

Mr. Steve Aldrich

On April 1, 2024 and April 30, 2024, Bradly Young of Axiom Service Professionals (ASP), conducted lead in drinking water sampling at the above referenced address. Inspector certification is provided in Appendix A. A total of 174 samples were collected from various potential drinking water outlets including sources used for drinking, cooking, or cleaning of cooking and eating utensils throughout the building.

**Drinking Water Standards**

The use of lead solder and other lead-containing materials as defined in the EPA Safe Drinking Water Act in connecting household plumbing to public water supplies was prohibited as of 1986. The act established the definition of “lead free” to be less than 8% as a weighted average across wetted surfaces of a pipe, pipe fitting, plumbing fitting, and fixture and 0.2% lead for solder and flux. In 2011, the definition of “lead free” as it applied to wetted surfaces of a pipe, pipe fitting, and plumbing fitting and fixture was reduced from 8% to 0.25% as a weighted average. Many older structures still have lead pipe or lead-soldered plumbing internally, which may substantially increase the lead content of water at the tap. Nationwide regulations controlling the lead content of drinking-water coolers in schools went into effect in 1989.

In 1991, the EPA published the Lead and Copper Rule establishing limits on the amount of lead and copper in drinking water. This regulation can be found under 40 CFR Part 141, Subpart I. Reference: https://www.epa.gov/dwreginfo/lead-and-copper-rule

The EPA has set lead in drinking water standards as outlined below.

- For lead, the maximum contaminant level goal (MCLG) is zero. This is the levels determined to be safe by toxicological and biomedical considerations, independent of feasibility. EPA's National Primary Drinking Water Regulations for Lead establish a treatment level of **0.015 mg/L** or **15 ppb** (parts per billion) in municipal drinking water systems.

The Missouri Senate Bill 681 “Get the Lead Out of School Drinking Water Act”, passed in 2022, has set the standard summarized below.
Reference: https://www.senate.mo.gov/22info/BTS_Web/Bill.aspx?SessionType=R&BillID=71259862

- On or before January 1, 2024, each school shall conduct an inventory of all drinking water outlets and all outlets that are used for dispensing water for cooking or for cleaning cooking and eating utensils in each of the school’s buildings. A plan for testing should then be developed, prioritizing early childhood education programs and elementary schools, and made available to the public.
- The bill outlines that beginning in the 2023-2024 school year and for each subsequent school year, each school shall provide drinking water with a lead concentration below five parts per billion (**5 ppb**). Any school with greater than or equal to 5 ppb shall provide results and remediation plans to parents and staff within 7 business days of receiving results.

**Drinking Fountain Identification**

Drinking fountains throughout the school were visually assessed to determine if they matched those listed by the EPA to be lead-containing. The list of drinking fountains reported by the EPA to contain lead-lined holding tanks or solder joints is presented as Appendix B. Below is a list of drinking fountains within the school that match those reported by the EPA to be lead-containing.

| Location | Make | Model # | Serial # |
|---|---|---|---|
| None Matching | | | |

**Water Sampling Methods:**

Water samples were collected from each selected location as “first draw” and/or “flush”. First draw samples typically represent worst case sample results. A flush sample is typically collected to determine if an elevation is originating beyond the fixture in the fixture supply line or beyond. Samples were deposited into a non-preserved 250-milliliter sterile Nalgene screw top bottle. Immediately following sample collection, the samples were delivered to Keystone Laboratories located at 8857 Long Street, Lenexa, Kansas 66215. Upon arrival at the laboratory, samples were preserved through addition of nitric acid.

Keystone Laboratories is accredited through the Missouri Department of Natural Resources for analysis of lead in water.

Below is a summary of the water sampling results as reported in Appendix C by Keystone Laboratories. Results exceeding the applicable drinking water standards are shown in red text.

**April 1, 2024 Water Sampling Results:**

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-1-FD | Heritage Middle School - 001511-By Room 309-Boys | Sink Tap | First Draw | 1.4 |
| 600-2-FD | Heritage Middle School - 001513-By Room 304 | Drinking Fountain | First Draw | 0.9 |
| 600-3-FD | Heritage Middle School - 001514-By Room 301-Staff Restroom | Sink Tap | First Draw | 0.6 |
| 600-4-FD | Heritage Middle School - 001568-By Room 503 | Drinking Fountain | First Draw | 2.4 |
| 600-5-FD | Heritage Middle School - 001566-Room 505 | Sink Tap | First Draw | 6.4 |
| 600-6-FD | Heritage Middle School - 002385-Room 505 | Sink Tap | First Draw | 12.1 |
| 600-7-FD | Heritage Middle School - 001565-Room 507 | Sink Tap | First Draw | 12.8 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-8-FD | Heritage Middle School - 002386-Room 507 | Sink Tap | First Draw | 11.2 |
| 600-9-FD | Heritage Middle School - 001564-By Room 502 | Drinking Fountain | First Draw | 2.6 |
| 600-10-FD | Heritage Middle School - 001563-Room 502 | Sink Tap | First Draw | 9.4 |
| 600-11-FD | Heritage Middle School - 001562F-Room 501A | Sink Tap | First Draw | 33.5 |
| 600-12-FD | Heritage Middle School - 001562B-Room 501A | Bubbler | First Draw | 8.5 |
| 600-13-FD | Heritage Middle School - 001561-Room 501 | Sink Tap | First Draw | 45.6 |
| 600-14-FD | Heritage Middle School - 001560F-Room 202 | Sink Tap | First Draw | 8 |
| 600-15- | Heritage Middle School - 001560B-Room 202 - Out of Order | Bubbler | Not Tested | Not Sampled |
| 600-16-FD | Heritage Middle School - 001559F-Room 203 | Sink Tap | First Draw | 7.8 |
| 600-17-FD | Heritage Middle School - 001559B-Room 203 | Bubbler | First Draw | 9.6 |
| 600-18-FD | Heritage Middle School - 001556F-Room 205 | Sink Tap | First Draw | 1.7 |
| 600-19-FD | Heritage Middle School - 001556B-Room 205 | Bubbler | First Draw | 10.5 |
| 600-20-FD | Heritage Middle School - 001558/3331-By Room 206 | Drinking Fountain | First Draw | 0.6 |
| 600-21-FD | Heritage Middle School - 001558/3331F-By 206 | Bottle Filler | First Draw | 0.6 |
| 600-22-FD | Heritage Middle School - 001555F-Room 206 | Sink Tap | First Draw | 2.4 |
| 600-23-FD | Heritage Middle School - 001555B-Room 206 | Bubbler | First Draw | 2.3 |
| 600-24-FD | Heritage Middle School - 001554F-Room 207 | Sink Tap | First Draw | 7.1 |
| 600-25-FD | Heritage Middle School - 001554B-Room 207 | Bubbler | First Draw | 9.7 |
| 600-26-FD | Heritage Middle School - 001553F-Room 208 | Sink Tap | First Draw | 3.7 |
| 600-27-FD | Heritage Middle School - 001553B-Room 208 | Bubbler | First Draw | 24.3 |
| 600-28-FD | Heritage Middle School - 001551F-Room 211 | Sink Tap | First Draw | 3.9 |
| 600-29-FD | Heritage Middle School - 001551B-Room 211 | Bubbler | First Draw | 12.9 |
| 600-30-FD | Heritage Middle School - 001540-Room 212-Restroom | Sink Tap | First Draw | 0.5 |
| 600-31-FD | Heritage Middle School - 001531-Room 217 | Sink Tap | First Draw | 11.9 |
| 600-32-FD | Heritage Middle School - 001516-Room 220 | Sink Tap | First Draw | 11.8 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-33-FD | Heritage Middle School - 001515F-Room 221 | Sink Tap | First Draw | 16 |
| 600-34-FD | Heritage Middle School - 001519-Greenhouse | Sink Tap | First Draw | 2 |
| 600-35-FD | Heritage Middle School - 001547-By Room 225-Boys | Sink Tap | First Draw | 0.7 |
| 600-36-FD | Heritage Middle School - 001548-By Room 225-Boys | Sink Tap | First Draw | 1.1 |
| 600-37-FD | Heritage Middle School - 001549-By 225-Boys | Sink Tap | First Draw | 0.5 |
| 600-38- | Heritage Middle School - 001550-By 225-Boys - Out of Order | Sink Tap | Not Tested | Not Sampled |
| 600-39-FD | Heritage Middle School - 001543-By 225-Girls | Sink Tap | First Draw | 0.8 |
| 600-40-FD | Heritage Middle School - 001544-By 225-Girls | Sink Tap | First Draw | 0.5 |
| 600-41-FD | Heritage Middle School - 001545-By 225-Girls | Sink Tap | First Draw | 0.6 |
| 600-42-FD | Heritage Middle School - 001546-By 225-Girls | Sink Tap | First Draw | 1 |
| 600-43-FD | Heritage Middle School - 001542B-By 225 | Drinking Fountain | First Draw | <0.4 |
| 600-44-FD | Heritage Middle School - 001542F-By 225 | Bottle Filler | First Draw | <0.4 |
| 600-45-FD | Heritage Middle School - 001542B-By 225-Right | Drinking Fountain | First Draw | <0.4 |
| 600-46-FD | Heritage Middle School - 002378B-By Room 100 | Drinking Fountain | First Draw | 0.4 |
| 600-47-FD | Heritage Middle School - 002378F-By Room 100 | Bottle Filler | First Draw | <0.4 |
| 600-48-FD | Heritage Middle School - 001668-Lounge | Sink Tap | First Draw | <0.4 |
| 600-49-FD | Heritage Middle School - 000627-L-Lounge | Ice Machine | First Draw | <0.4 |
| 600-50-FD | Heritage Middle School - 002380-Lounge | Ice Maker/Fridge | First Draw | 0.5 |
| 600-51-FD | Heritage Middle School - 002379-Lounge | Coffee Pot | First Draw | <0.4 |
| 600-52-FD | Heritage Middle School - 001667-North of Lounge-Storage Room | Sink Tap | First Draw | <0.4 |
| 600-53-FD | Heritage Middle School - 001647-Room 105 | Sink Tap | First Draw | 4.7 |
| 600-54-FD | Heritage Middle School - 001646F-Room 107 | Sink Tap | First Draw | <0.4 |
| 600-55-FD | Heritage Middle School - 001646B-Room 107 | Bubbler | First Draw | <0.4 |
| 600-56-FD | Heritage Middle School - 001641F-Room 108 | Sink Tap | First Draw | <0.4 |
| 600-57-FD | Heritage Middle School - 001641B-Room 108 | Bubbler | First Draw | <0.4 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-58-FD | Heritage Middle School - 001642-Room 108 | Sink Tap | First Draw | <0.4 |
| 600-59-FD | Heritage Middle School - 001643-Room 108 | Sink Tap | First Draw | 0.5 |
| 600-60-FD | Heritage Middle School - 001644-Room 108 | Sink Tap | First Draw | <0.4 |
| 600-61-FD | Heritage Middle School - 001645-Room 109 | Sink Tap | First Draw | 0.5 |
| 600-62-FD | Heritage Middle School - 001637F-Room 110 | Sink Tap | First Draw | <0.4 |
| 600-63-FD | Heritage Middle School - 001637B-Room 110 | Bubbler | First Draw | <0.4 |
| 600-64-FD | Heritage Middle School - 001638-Room 110 | Sink Tap | First Draw | <0.4 |
| 600-65-FD | Heritage Middle School - 001639-Room 110 | Sink Tap | First Draw | <0.4 |
| 600-66-FD | Heritage Middle School - 001640-Room 110 | Sink Tap | First Draw | <0.4 |
| 600-67-FD | Heritage Middle School - 001631F-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-68-FD | Heritage Middle School - 001631B-Room 111 | Bubbler | First Draw | <0.4 |
| 600-69-FD | Heritage Middle School - 001632-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-70-FD | Heritage Middle School - 001633-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-71-FD | Heritage Middle School - 001634-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-72-FD | Heritage Middle School - 001635-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-73-FD | Heritage Middle School - 001636-Room 111 | Sink Tap | First Draw | <0.4 |
| 600-74-FD | Heritage Middle School - 001648F-Room 112 | Sink Tap | First Draw | <0.4 |
| 600-75-FD | Heritage Middle School - 001648B-Room 112 | Bubbler | First Draw | <0.4 |
| 600-76-FD | Heritage Middle School - 001653-By 118-Boys | Sink Tap | First Draw | <0.4 |
| 600-77-FD | Heritage Middle School - 001654-By 118-Boys | Sink Tap | First Draw | <0.4 |
| 600-78-FD | Heritage Middle School - 001655-By 118-Boys | Sink Tap | First Draw | <0.4 |
| 600-79-FD | Heritage Middle School - 001649-Room 120-Girls | Sink Tap | First Draw | <0.4 |
| 600-80-FD | Heritage Middle School - 001650-By 120-Girls | Sink Tap | First Draw | <0.4 |
| 600-81-FD | Heritage Middle School - 001651-By 120-Girls | Sink Tap | First Draw | 0.4 |
| 600-82-FD | Heritage Middle School - 002376B-By Rm 114 | Drinking Fountain | First Draw | <0.4 |
| 600-83-FD | Heritage Middle School - 002376F-By Room 114 | Bottle Filler | First Draw | <0.4 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-84-FD | Heritage Middle School - 002377-By Room 114 | Drinking Fountain | First Draw | <0.4 |
| 600-85-FD | Heritage Middle School - 001657-Gym-Northeast Corner | Drinking Fountain | First Draw | <0.4 |
| 600-86-FD | Heritage Middle School - 001658-Gym-Southwest Corner | Drinking Fountain | First Draw | <0.4 |
| 600-87-FD | Heritage Middle School - 001659-Concessions | Sink Tap | First Draw | 3.6 |
| 600-88-FD | Heritage Middle School - 001660-Gym-Concessions | Sink Tap | First Draw | 2.7 |
| 600-89-FD | Heritage Middle School - 001665-Room 117 | Sink Tap | First Draw | 1 |
| 600-90-FD | Heritage Middle School - 003318-By Room 120 | Drinking Fountain | First Draw | <0.4 |
| 600-91-FD | Heritage Middle School - 003319-By Room 120 | Drinking Fountain | First Draw | <0.4 |
| 600-92-FD | Heritage Middle School - 001663-Copy Room-Boys | Sink Tap | First Draw | 0.6 |
| 600-93-FD | Heritage Middle School - 001664-Copy Room-Girls | Sink Tap | First Draw | 0.7 |
| 600-94-FD | Heritage Middle School - 001684-By 128-Girls | Sink Tap | First Draw | 0.5 |
| 600-95-FD | Heritage Middle School - 001685-By 128-Girls | Sink Tap | First Draw | 0.7 |
| 600-96-FD | Heritage Middle School - 001686-By 128-Girls | Sink Tap | First Draw | 0.6 |
| 600-97-FD | Heritage Middle School - 001687-By 128-Girls | Sink Tap | First Draw | 1.1 |
| 600-98-FD | Heritage Middle School - 001679-By 126-Boys | Sink Tap | First Draw | 1.2 |
| 600-99-FD | Heritage Middle School - 001680-By 126-Boys | Sink Tap | First Draw | 0.6 |
| 600-100-FD | Heritage Middle School - 001681-By 126-Boys | Sink Tap | First Draw | 0.5 |
| 600-101-FD | Heritage Middle School - 001682-By 126-Boys | Sink Tap | First Draw | 0.6 |
| 600-102-FD | Heritage Middle School - 002383-By Room 400 | Sink Tap | First Draw | 0.4 |
| 600-103-FD | Heritage Middle School - 002384-By 400 | Sink Tap | First Draw | 0.5 |
| 600-104-FD | Heritage Middle School - 001676-400 Hall | Drinking Fountain | First Draw | 0.7 |
| 600-105-FD | Heritage Middle School - 001677-Room 400 | Sink Tap | First Draw | 8.2 |
| 600-106-FD | Heritage Middle School - 001675-400s Hall | Drinking Fountain | First Draw | 3.5 |
| 600-107-FD | Heritage Middle School - 002381-400 Hall-Boys | Sink Tap | First Draw | <0.4 |
| 600-108-FD | Heritage Middle School - 002382-400 Hall-Boys | Sink Tap | First Draw | 0.4 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-109-FD | Heritage Middle School - 001672-Nurse's Office | Sink Tap | First Draw | <0.4 |
| 600-110-FD | Heritage Middle School - 001671-Nurse's Office-Restroom | Sink Tap | First Draw | 0.4 |
| 600-111-FD | Heritage Middle School - 001670-Nurse's Office-Restroom | Sink Tap | First Draw | 19.1 |
| 600-112-FD | Heritage Middle School - 001601-Room 23 | Sink Tap | First Draw | <0.4 |
| 600-113-FD | Heritage Middle School - 001602-Room 23 | Sink Tap | First Draw | <0.4 |
| 600-114-FD | Heritage Middle School - 001603-Room 23 | Sink Tap | First Draw | 0.4 |
| 600-115-FD | Heritage Middle School - 001604-Room 23 | Sink Tap | First Draw | 0.4 |
| 600-116-FD | Heritage Middle School - 001605-Room 23 | Sink Tap | First Draw | 0.6 |
| 600-117-FD | Heritage Middle School - 001606-Room 23 | Sink Tap | First Draw | 0.6 |
| 600-118-FD | Heritage Middle School - 001598-Library-Work Room | Sink Tap | First Draw | <0.4 |
| 600-119-FD | Heritage Middle School - 001599-Library-Restroom | Sink Tap | First Draw | <0.4 |
| 600-120-FD | Heritage Middle School - 001597-Room 12-Wood Shop | Sink Tap | First Draw | 1.9 |
| 600-121-FD | Heritage Middle School - 001592-By Wood Shop-Girls | Sink Tap | First Draw | <0.4 |
| 600-122-FD | Heritage Middle School - 001593-By Wood Shop-Girls | Sink Tap | First Draw | 0.5 |
| 600-123-FD | Heritage Middle School - 001594-By Wood Shop-Boys | Sink Tap | First Draw | 0.6 |
| 600-124-FD | Heritage Middle School - 001595-By Wood Shop-Boys | Sink Tap | First Draw | <0.4 |
| 600-125-FD | Heritage Middle School - 002371-By Wood Shop | Drinking Fountain | First Draw | <0.4 |
| 600-126-FD | Heritage Middle School - 002372-By Wood Shop | Drinking Fountain | First Draw | 0.5 |
| 600-127-FD | Heritage Middle School - 001608-Locker Room-Girls | Sink Tap | First Draw | 0.5 |
| 600-128-FD | Heritage Middle School - 001609-Locker Room-Girls | Sink Tap | First Draw | 0.5 |
| 600-129-FD | Heritage Middle School - 001610-Locker Room-Girls | Sink Tap | First Draw | <0.4 |
| 600-130-FD | Heritage Middle School - 001611-Locker Room-Girls | Sink Tap | First Draw | 0.4 |
| 600-131-FD | Heritage Middle School - 001612-Locker Room-Girls | Sink Tap | First Draw | <0.4 |
| 600-132-FD | Heritage Middle School - 001613-Locker Room-Girls-Office | Sink Tap | First Draw | 0.4 |
| 600-133-FD | Heritage Middle School - 002373-Weight Room | Drinking Fountain | First Draw | 0.7 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-134-FD | Heritage Middle School - 001614-Weight Room | Drinking Fountain | First Draw | <0.4 |
| 600-135-FD | Heritage Middle School - 001616-Weight Room-Restroom | Sink Tap | First Draw | <0.4 |
| 600-136-FD | Heritage Middle School - 002374-Exercise Room | Drinking Fountain | First Draw | <0.4 |
| 600-137-FD | Heritage Middle School - 002375-Exercise Room | Bottle Filler | First Draw | 1.6 |
| 600-138-FD | Heritage Middle School - 001617-Boys Lockers-Office | Sink Tap | First Draw | 1.3 |
| 600-139-FD | Heritage Middle School - 001618-Locker Room-Boys | Bubbler | First Draw | 0.7 |
| 600-140-FD | Heritage Middle School - 001619-Locker Room-Boys | Sink Tap | First Draw | 0.4 |
| 600-141-FD | Heritage Middle School - 001620-Locker Room-Boys | Sink Tap | First Draw | 0.7 |
| 600-142-FD | Heritage Middle School - 001621-Locker Room-Boys | Sink Tap | First Draw | 0.4 |
| 600-143-FD | Heritage Middle School - 001581-By Lunch Room-Girls | Sink Tap | First Draw | <0.4 |
| 600-144-FD | Heritage Middle School - 001582-By Lunch Room-Girls | Sink Tap | First Draw | <0.4 |
| 600-145-FD | Heritage Middle School - 001583-By Lunch Room-Girls | Sink Tap | First Draw | 0.6 |
| 600-146-FD | Heritage Middle School - 001584-By Lunch Room-Girls | Sink Tap | First Draw | 0.5 |
| 600-147-FD | Heritage Middle School - 003317-By Lunch Room-Girls | Sink Tap | First Draw | 1.7 |
| 600-148-FD | Heritage Middle School - 001585-By Lunch Room-Boys | Sink Tap | First Draw | <0.4 |
| 600-149-FD | Heritage Middle School - 001586-By Lunch Room-Boys | Sink Tap | First Draw | 0.5 |
| 600-150-FD | Heritage Middle School - 001587-By Lunch Room-Boys | Sink Tap | First Draw | 1.2 |
| 600-151-FD | Heritage Middle School - 001588-By Lunch Room-Boys | Sink Tap | First Draw | 6.6 |
| 600-152-FD | Heritage Middle School - 003316-By Lunch Room-Boys | Sink Tap | First Draw | 3.5 |
| 600-153-FD | Heritage Middle School - 001590B-By Lunch Room | Drinking Fountain | First Draw | <0.4 |
| 600-154-FD | Heritage Middle School - 001590F-By Lunch Room | Bottle Filler | First Draw | <0.4 |
| 600-155-FD | Heritage Middle School - 001590-By Lunch Room | Drinking Fountain | First Draw | <0.4 |
| 600-156-FD | Heritage Middle School - 000625-L-Kitchen | Ice Machine | First Draw | 0.6 |
| 600-157-FD | Heritage Middle School - 000468-L-Kitchen | Sink Tap | First Draw | 0.8 |
| 600-158-FD | Heritage Middle School - 001569-Kitchen | Sink Tap | First Draw | 4.9 |

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-159-FD | Heritage Middle School - 001570-Kitchen | Sink Tap | First Draw | 5.3 |
| 600-160-FD | Heritage Middle School - 001571-Kitchen | Sink Tap | First Draw | <0.4 |
| 600-161-FD | Heritage Middle School - 000815-L-Kitchen | Tilt Skillet | First Draw | 0.9 |
| 600-162-FD | Heritage Middle School - 001752-Kitchen | Sink Tap | First Draw | 0.6 |
| 600-163-FD | Heritage Middle School - 001573-Kitchen | Sink Tap | First Draw | 0.8 |
| 600-164-FD | Heritage Middle School - 001575-Kitchen | Sink Tap | First Draw | 1.7 |
| 600-165-FD | Heritage Middle School - 001576-Kitchen | Sink Tap | First Draw | <0.4 |
| 600-166-FD | Heritage Middle School - 001577-Kitchen | Sink Tap | First Draw | <0.4 |
| 600-167-FD | Heritage Middle School - 001578-Kitchen | Sink Tap | First Draw | 0.4 |
| 600-168-FD | Heritage Middle School - 001579-Kitchen | Sink Tap | First Draw | 0.4 |
| 600-169-FD | Heritage Middle School - 001580-Kitchen | Sink Tap | First Draw | 2 |
| 600-170-FD | Heritage Middle School - 004530-Kitchen | Sink Tap | First Draw | <0.4 |
| 600-171-FD | Heritage Middle School - 004531-Kitchen | Sink Tap | First Draw | 1.8 |
| 600-172-FD | Heritage Middle School - 004532-Kitchen | Sink Tap | First Draw | 2.5 |
| 600-173-FD | Heritage Middle School - 004533-Kitchen | Sink Tap | First Draw | 0.8 |
| 600-174-FD | Heritage Middle School - 001574-Kitchen-Restroom | Sink Tap | First Draw | <0.4 |

**April 30, 2024 Water Sampling Results:**

| Sample # | Location | Source Under Test | Test Type | Lead Result (ppb) |
|---|---|---|---|---|
| 600-15-FD | Heritage Middle School - 001560B-Room 202 | Bubbler | First Draw | 16.0 |
| 600-38-FD | Heritage Middle School - 001550-By Room 225-Boys-Far Left | Sink Tap | First Draw | 1.2 |

Photos of the sampling locations are provided in Appendix D. A diagram containing identifiers on the outlets tested is provided in Appendix E.

**Short-Term Control Measures**

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Take immediate steps to prevent use from the failed source(s).
- Shut-off problem outlets
- Post “Not for Drinking/Cooking” at Problem Outlets. If initial sample results from an outlet(s) exceed the remediation trigger level, but are not routinely used for human ingestion (e.g., handwashing), clear signage can be posted to notify people that the outlet is not to be used for drinking or cooking until the problem is resolved.
- Consider performing follow-up flush testing in order to attempt to identify what component within the system is the source of the elevated lead concentration. This testing will assist to pinpoint where lead is getting into drinking water (i.e., fixtures versus interior plumbing) so that appropriate corrective measures can be taken.
- Shut-off or disconnection of problem outlets can provide a permanent solution. If the outlet is frequently used, this likely is not a practical long-term solution.
- Provide point-of-use (POU) filters at problem taps. Filters need routine maintenance (e.g., cartridge filter units need to be replaced periodically) to remain effective.

**Permanent Control Measures**

- Per the State of Missouri Senate Bills Nos. 681 & 662, a remediation plan should be developed and executed.
- Replacement of Problem Outlets and any identified upstream plumbing components (e.g., valves, leaded solder) to permanently address the problem. EPA's revised March 2015 guidance, How to Identify Lead-Free Certification Marks for Drinking Water System & Plumbing Products, can be a useful resource selecting leadfree plumbing.
- Provide point-of-use filters (POU) at problem taps as a long-term or permanent control measure. When doing this, facilities should be sure to create maintenance schedules and identify a point of contact to be in charge of making sure they are properly maintained.
- Reconfigure Plumbing. Ongoing renovation of school or childcare buildings may provide an opportunity to modify the plumbing system to redirect water supplied for drinking or cooking to bypass sources of lead contamination. Before undertaking such an alternative, be certain that you have properly identified all of the sources of lead contamination in drinking water.
- Remove and replace any drinking water coolers or drinking water outlets that the United States Environmental Protection Agency has determined are not lead-free under the federal Lead Contamination Control Act of 1988, as amended; except the school shall not be required to replace those drinking water outlets or water coolers that tested in accordance with state regulations and have been determined to be dispensing drinking water with a lead concentration less than five (5) part per billion (ppb); however, such drinking water outlet or water cooler shall be subject to all testing requirements and shall not be excluded from testing under subsection 10 of the Missouri Senate Bills Nos. 681 & 662, Section 160.077.
- Consider filtration of incoming water at the point of entry (POE) to the building.

**Required Communication**

- Contact staff and parents via written notification within seven (7) business days after receiving the test result.
- The notification shall include at least:
- The test results and a summary that explains such results;
- A description of any remedial steps taken; and
- A description of general health effects of lead contamination and community specific resources; and
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.
- Submit such annual testing results to the Missouri Department of Health and Senior Services (DHSS).
- Before August 1, 2024, or the first day on which students will be present in the building, whichever is later, and annually thereafter, each school shall conduct testing for lead by first-draw and follow-up flush samples of a random sampling of at least twenty-five percent (25%) of remediated drinking water outlets until all remediated sources have been tested as recommended by the 2018 version of the United States Environmental Protection Agency's "Training, Testing, and Taking Action" program. The testing shall be conducted and the results analyzed for both types of tests by an entity or entities approved by the department.
- Any measures taken to remediate any elevated lead levels identified must be recorded and documented.

**General Recommendations**

- Retesting of all potential cooking and drinking water sources is required five (5) years from previous testing completed.
- If the condition changes or significant alterations to existing plumbing is undertaken, consider performing additional lead in drinking water sampling.
- Ensure that the plumbing system is not used as an electrical ground.
- If equipment is added that could affect water pH, alkalinity, or hardness, consider performing lead in drinking water sampling.

Any work resulting from this report should be conducted in accordance with the EPA Safe Drinking Water Act, Missouri SB 681 & 662, HUD Lead Regulations 24 CFR 35, EPA Lead Regulations 40 CFR 745, and Consumer Product Safety Commission document #5056.

If you have any questions concerning this report, please contact me at 816-678-7894.

Sincerely,



Jeff Hurst
Axiom Service Professionals LLC
jeffh@axiomservicepros.com

**Limitations Drinking Water Testing**

The presence or absence of lead and copper (if collected) in drinking water applies only to the test locations on the date of the field visit and it should be understood that conditions may change due to deterioration, pH, alkalinity, hardness, use levels, or maintenance. The results noted within this report were accurate at the time of the evaluation and in no way reflect the conditions at the property before or after the date of the evaluation. No other environmental concerns or conditions were addressed during this evaluation.

# Appendix A
# Certifications

# STATE OF MISSOURI
# DEPARTMENT OF HEALTH AND SENIOR SERVICES

## LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

**Bradly A. Young**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Inspector**
Category of License

| | |
|---|---|
| Issuance Date: | **10/4/2023** |
| Expiration Date: | **10/4/2025** |
| License Number: | **211004-300006201** |

Paula F. Nickelson
Director
Department of Health and Senior Services

*Lead Licensing Program*, PO Box 570, Jefferson City, MO 65102

# STATE OF MISSOURI
# DEPARTMENT OF HEALTH AND SENIOR SERVICES

## LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

# Jeffrey A. Hurst

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**
Category of License

Issuance Date: **8/1/2022**
Expiration Date: **8/1/2024**
License Number: **000801-200166567**




Paula F. Nickelson
Acting Director
t of Health and Senior Services

son City, MO 65102

# Appendix B
# EPA Listed Lead Containing Drinking Fountains

**Table C-1**
**Water Coolers With Other Lead Components**

**EBCO Manufacturing**

- All pressure bubbler water coolers with shipping dates from 1962 through 1977 have a bubbler valve containing lead. The units contain a single, 50-50 tin-lead solder joint on the bubbler valve. Model numbers for coolers in this category are not available.

- The following models of pressure bubbler coolers produced from 1978 through 1981 contain one 50-50 tin-lead solder joint each.

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| CP3 | DP15W | DPM8 | 7P | 13P | DPM8H | DP15M | DP3R | DP8A |
| DP16M | DP5S | C10E | PX-10 | DP7S | DP13SM | DP7M | DP7MH | DP7WD |
| WTC10 | DP13M-60 | DP14M | CP10-50 | CP5 | CP5M | DP15MW | DP3R | DP14S |
| DP20-50 | DP7SM | DP10X | DP13A | DP13A-50 | EP10F | DP5M | DP10F | CP3H |
| CP3-50 | DP13M | DP3RH | DP5F | CP3M | EP5F | 13PL | DP8AH | DP13S |
| CP10 | DP20 | DP12N | DP7WM | DP14A-50/60 | | | | |

**Halsey Taylor**

- Lead solder was used in these models of water coolers manufactured between 1978 and the last week of 1987:

| | | | |
|---|---|---|---|
| WMA-1 | SCWT/SCWT-A | SWA-1 | DC/DHC-1 |
| S3/5/10D | BFC-4F/7F/4FS/7FS | S300/500/100D | |

- The following coolers manufactured for Haws Drinking Faucet Company (Haws) by Halsey Taylor from November 1984 through December 18, 1987 are not lead-free because they contain 2 tin-lead solder joints. The model designations for these units are as follows:

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| HC8WT | HC14F | HC6W | HWC7D | HC8WTH | HC14FH | HC8W | HC2F | HC14WT |
| HC14FL | HC14W | HC2FH | HC14WTH | HC8FL | HC4F | HC5F | HC14WL | HCBF7D |
| HC4FH | HC10F | HC16WT | HCBF7HO | HC8F | HC8FH | HC4W | HWC7 | |

**Table C-2**
**Halsey Taylor Water Coolers With Lead-Lined Tanks**

- The following six model numbers have one or more units in the model series with lead-lined tanks:

WM8A WT8A GC10ACR GC10A GC5A RWM13A

- The following models and serial numbers contain lead-lined tanks:

| | | |
|---|---|---|
| WM14A Serial No. 843034 | WM14A Serial No. 843006 | WT11A Serial No. 222650 |
| WT21A Serial No. 64309550 | WT21A Serial No. 64309542 | LL14A Serial No. 64346908 |



PO Box 47166 Kansas City, MO 64188 • 816-678-7894 • www.axiomservicepros.com

# Appendix C
# Laboratory Analytical Report

MICROBAC®

# Microbac Laboratories, Inc., Lenexa

## CERTIFICATE OF ANALYSIS

## 3HD0079

**AXIOM Service Professionals**

Jeff Hurst
PO Box 47166
Kansas City, MO 64188

**Project Name: 600 West Kansas Street**

Project / PO Number: 600 West Kansas Street
Received: 04/05/2024
Reported: 04/25/2024

### Analytical Testing Parameters

**Client Sample ID:** 600-1-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-01
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0232 | JAR |

**Client Sample ID:** 600-2-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-02
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.9** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0235 | JAR |

**Client Sample ID:** 600-3-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-03
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0238 | JAR |

**Client Sample ID:** 600-4-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-04
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:33

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0241 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-5-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-05
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **6.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0244 | JAR |

**Client Sample ID:** 600-6-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-06
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **12.1** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0253 | JAR |

**Client Sample ID:** 600-7-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-07
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **12.8** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0308 | JAR |

**Client Sample ID:** 600-8-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-08
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **11.2** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0311 | JAR |

**Client Sample ID:** 600-9-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-09
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0314 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-10-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-10
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **9.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0317 | JAR |

**Client Sample ID:** 600-11-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-11
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **33.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0320 | JAR |

**Client Sample ID:** 600-12-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-12
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **8.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0323 | JAR |

**Client Sample ID:** 600-13-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-13
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:36

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **45.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0326 | JAR |

**Client Sample ID:** 600-14-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-14
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **8.0** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0329 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-16-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-15
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **7.8** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0332 | JAR |

**Client Sample ID:** 600-17-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-16
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **9.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0341 | JAR |

**Client Sample ID:** 600-18-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-17
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.7** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0344 | JAR |

**Client Sample ID:** 600-19-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-18
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:39

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **10.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0347 | JAR |

**Client Sample ID:** 600-20-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-19
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0350 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-21-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-20
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0353 | JAR |

**Client Sample ID:** 600-22-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-21
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0356 | JAR |

**Client Sample ID:** 600-23-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-22
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.3** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0359 | JAR |

**Client Sample ID:** 600-24-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-23
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **7.1** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0402 | JAR |

**Client Sample ID:** 600-25-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-24
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **9.7** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0405 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-26-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-25
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **3.7** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0408 | JAR |

**Client Sample ID:** 600-27-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-26
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:42

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **24.3** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0417 | JAR |

**Client Sample ID:** 600-28-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-27
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **3.9** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0426 | JAR |

**Client Sample ID:** 600-29-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-28
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **12.9** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0435 | JAR |

**Client Sample ID:** 600-30-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-29
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0438 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-31-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-30
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **11.9** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0441 | JAR |

**Client Sample ID:** 600-32-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-31
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **11.8** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0444 | JAR |

**Client Sample ID:** 600-33-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-32
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **16.0** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0453 | JAR |

**Client Sample ID:** 600-34-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-33
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.0** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0456 | JAR |

**Client Sample ID:** 600-35-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-34
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0459 | JAR |

**Client Sample ID:** 600-36-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-35
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.1** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0502 | JAR |

**Client Sample ID:** 600-37-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-36
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:48

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0505 | JAR |

**Client Sample ID:** 600-39-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-37
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.8** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0508 | JAR |

**Client Sample ID:** 600-40-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-38
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0511 | JAR |

**Client Sample ID:** 600-41-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-39
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:49

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0514 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 660-42-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-40
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.0** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0517 | JAR |

**Client Sample ID:** 600-43-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-41
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0520 | JAR |

**Client Sample ID:** 600-44-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-42
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0529 | JAR |

**Client Sample ID:** 600-45-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-43
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:50

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0532 | JAR |

**Client Sample ID:** 600-46-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-44
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0535 | JAR |

**Client Sample ID:** 600-47-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-45
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0538 | JAR |

**Client Sample ID:** 600-48-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-46
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0541 | JAR |

**Client Sample ID:** 600-49-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-47
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0544 | JAR |

**Client Sample ID:** 600-50-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-48
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0553 | JAR |

**Client Sample ID:** 600-51-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-49
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:56

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0608 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-52-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-50
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:56

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0611 | JAR |

**Client Sample ID:** 600-53-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-51
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **4.7** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0614 | JAR |

**Client Sample ID:** 600-54-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-52
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0617 | JAR |

**Client Sample ID:** 600-55-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-53
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0620 | JAR |

**Client Sample ID:** 600-56-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-54
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0623 | JAR |

**Client Sample ID:** 600-57-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-55
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0626 | JAR |

**Client Sample ID:** 600-58-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-56
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0629 | JAR |

**Client Sample ID:** 600-59-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-57
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 22:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0632 | JAR |

**Client Sample ID:** 600-60-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-58
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:00

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/23/24 1056 | 04/24/24 0641 | JAR |

**Client Sample ID:** 600-61-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-59
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:00

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1411 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-62-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-60 | **Collection Date:** | 04/01/2024 23:00 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1420 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-63-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-61 | **Collection Date:** | 04/01/2024 23:00 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1423 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-64-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-62 | **Collection Date:** | 04/01/2024 23:01 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1426 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-65-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-63 | **Collection Date:** | 04/01/2024 23:01 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1435 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-66-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-64 | **Collection Date:** | 04/01/2024 23:01 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1437 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-67-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-65
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1440 | JAR |

**Client Sample ID:** 600-68-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-66
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1443 | JAR |

**Client Sample ID:** 600-69-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-67
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1446 | JAR |

**Client Sample ID:** 600-70-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-68
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:02

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1449 | JAR |

**Client Sample ID:** 600-71-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-69
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:03

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1452 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-72-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-70 | **Collection Date:** | 04/01/2024 23:03 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1455 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-73-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-71 | **Collection Date:** | 04/01/2024 23:03 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1458 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-74-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-72 | **Collection Date:** | 04/01/2024 23:04 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1501 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-75-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-73 | **Collection Date:** | 04/01/2024 23:04 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1510 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-76-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-74 | **Collection Date:** | 04/01/2024 23:06 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1513 | JAR |

**Client Sample ID:** 600-77-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-75
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1516 | JAR |

**Client Sample ID:** 600-78-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-76
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:06

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1519 | JAR |

**Client Sample ID:** 600-79-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-77
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1522 | JAR |

**Client Sample ID:** 600-80-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-78
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1525 | JAR |

**Client Sample ID:** 600-81-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-79
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:07

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1534 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-82-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-80
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:08

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1549 | JAR |

**Client Sample ID:** 600-83-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-81
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:08

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1552 | JAR |

**Client Sample ID:** 600-84-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-82
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:08

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1555 | JAR |

**Client Sample ID:** 600-85-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-83
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1558 | JAR |

**Client Sample ID:** 600-86-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-84
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1601 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-87-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-85
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **3.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1604 | JAR |

**Client Sample ID:** 600-88-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-86
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:09

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1607 | JAR |

**Client Sample ID:** 600-89-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-87
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:10

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.0** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1610 | JAR |

**Client Sample ID:** 600-90-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-88
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1613 | JAR |

**Client Sample ID:** 600-91-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-89
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:11

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1622 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-92-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-90 | **Collection Date:** | 04/01/2024 23:12 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1625 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-93-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-91 | **Collection Date:** | 04/01/2024 23:12 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1628 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-94-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-92 | **Collection Date:** | 04/01/2024 23:14 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1631 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-95-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-93 | **Collection Date:** | 04/01/2024 23:14 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1634 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-96-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-94 | **Collection Date:** | 04/01/2024 23:14 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1637 | JAR |

**Client Sample ID:** 600-97-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-95
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:14

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.1** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1640 | JAR |

**Client Sample ID:** 600-98-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-96
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.2** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1643 | JAR |

**Client Sample ID:** 600-99-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-97
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1646 | JAR |

**Client Sample ID:** 600-100-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-98
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1649 | JAR |

**Client Sample ID:** 600-101-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-99
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:15

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1704 | JAR |

**Client Sample ID:** 600-102-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AA
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1713 | JAR |

**Client Sample ID:** 600-103-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AB
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1716 | JAR |

**Client Sample ID:** 600-104-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AC
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:18

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1719 | JAR |

**Client Sample ID:** 600-105-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AD
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:19

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **8.2** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1722 | JAR |

**Client Sample ID:** 600-106-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AE
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **3.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1725 | JAR |

**Client Sample ID:** 600-107-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AF
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1733 | JAR |

**Client Sample ID:** 600-108-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AG
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:20

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1736 | JAR |

**Client Sample ID:** 600-109-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AH
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:22

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1739 | JAR |

**Client Sample ID:** 600-110-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AI
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:22

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1742 | JAR |

**Client Sample ID:** 600-111-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AJ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:22

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **19.1** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1745 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-112-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AK
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1748 | JAR |

**Client Sample ID:** 600-113-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AL
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1751 | JAR |

**Client Sample ID:** 600-114-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AM
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1754 | JAR |

**Client Sample ID:** 600-115-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AN
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:25

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1757 | JAR |

**Client Sample ID:** 600-116-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AO
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:26

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1800 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-117-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AP
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:26

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1809 | JAR |

**Client Sample ID:** 600-118-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AQ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:27

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1812 | JAR |

**Client Sample ID:** 600-119-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AR
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:28

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1815 | JAR |

**Client Sample ID:** 600-120-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AS
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.9** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1818 | JAR |

**Client Sample ID:** 600-121-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AT
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:30

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1827 | JAR |

**Client Sample ID:** 600-122-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AU
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1836 | JAR |

**Client Sample ID:** 600-123-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AV
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1845 | JAR |

**Client Sample ID:** 600-124-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AW
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:31

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1848 | JAR |

**Client Sample ID:** 600-125-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AX
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1851 | JAR |

**Client Sample ID:** 600-126-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AY
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:32

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1854 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-127-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-AZ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1857 | JAR |

**Client Sample ID:** 600-128-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BA
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:34

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1900 | JAR |

**Client Sample ID:** 600-129-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BB
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1903 | JAR |

**Client Sample ID:** 600-130-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BC
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1906 | JAR |

**Client Sample ID:** 600-131-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BD
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1909 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-132-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BE
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:35

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1912 | JAR |

**Client Sample ID:** 600-133-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BF
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1921 | JAR |

**Client Sample ID:** 600-134-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BG
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1924 | JAR |

**Client Sample ID:** 600-135-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BH
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:37

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1927 | JAR |

**Client Sample ID:** 600-136-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BI
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1930 | JAR |

**Client Sample ID:** 600-137-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BJ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1933 | JAR |

**Client Sample ID:** 600-138-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BK
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:38

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.3** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1936 | JAR |

**Client Sample ID:** 600-139-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BL
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1939 | JAR |

**Client Sample ID:** 600-140-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BM
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1942 | JAR |

**Client Sample ID:** 600-141-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BN
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:40

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 1957 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-142-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BO
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:41

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2006 | JAR |

**Client Sample ID:** 600-143-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BP
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2009 | JAR |

**Client Sample ID:** 600-144-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BQ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2012 | JAR |

**Client Sample ID:** 600-145-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BR
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2015 | JAR |

**Client Sample ID:** 600-146-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BS
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:44

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2018 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-147-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BT
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2021 | JAR |

**Client Sample ID:** 600-148-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BU
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2024 | JAR |

**Client Sample ID:** 600-149-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BV
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:45

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2033 | JAR |

**Client Sample ID:** 600-150-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BW
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.2** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2036 | JAR |

**Client Sample ID:** 600-151-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BX
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **6.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2039 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-152-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BY
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:46

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **3.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2042 | JAR |

**Client Sample ID:** 600-153-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-BZ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2045 | JAR |

**Client Sample ID:** 600-154-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CA
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2048 | JAR |

**Client Sample ID:** 600-155-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CB
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:47

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2051 | JAR |

**Client Sample ID:** 600-156-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CC
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2054 | JAR |

**Client Sample ID:** 600-157-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CD
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.8** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2057 | JAR |

**Client Sample ID:** 600-158-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CE
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **4.9** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2100 | JAR |

**Client Sample ID:** 600-159-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CF
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:53

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **5.3** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2109 | JAR |

**Client Sample ID:** 600-160-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CG
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2112 | JAR |

**Client Sample ID:** 600-161-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CH
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.9** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2121 | JAR |

CERTIFICATE OF ANALYSIS

3HD0079

**Client Sample ID:** 600-162-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CI
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.6** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2130 | JAR |

**Client Sample ID:** 600-163-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CJ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:55

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.8** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2134 | JAR |

**Client Sample ID:** 600-164-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CK
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:56

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.7** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2137 | JAR |

**Client Sample ID:** 600-165-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CL
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:56

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2145 | JAR |

**Client Sample ID:** 600-166-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CM
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:56

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2149 | JAR |

**Client Sample ID:** 600-167-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CN
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:57

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2152 | JAR |

**Client Sample ID:** 600-168-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CO
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:57

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.4** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2155 | JAR |

**Client Sample ID:** 600-169-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CP
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.0** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2158 | JAR |

**Client Sample ID:** 600-170-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CQ
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:58

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2201 | JAR |

**Client Sample ID:** 600-171-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HD0079-CR
**Collected By:** Young, Bradly
**Collection Date:** 04/01/2024 23:59

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.8** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2204 | JAR |

# CERTIFICATE OF ANALYSIS

## 3HD0079

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-172-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-CS | **Collection Date:** | 04/01/2024 23:59 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **2.5** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2207 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-173-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-CT | **Collection Date:** | 04/01/2024 23:59 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **0.8** | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2210 | JAR |

| | | | |
|---|---|---|---|
| **Client Sample ID:** | 600-174-FD | | |
| **Sample Matrix:** | Drinking Water | **Collected By:** | Young, Bradly |
| **Lab Sample ID:** | 3HD0079-CU | **Collection Date:** | 04/01/2024 |

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | <0.4 | 0.4 | ppb | 2 | | 04/24/24 1155 | 04/24/24 2213 | JAR |

**Definitions**

**RL:** Reporting Limit

**Report Comments**

**Reviewed and Approved By:**



Sue Thompson
Client Services Manager
04/25/24 13:35

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.* ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

3HD0079 AXIOM Service Professionals
04/25/24 17:00 Carolyn Jackson DW
Lead Analysis $26
600 West Kansas Street A = N S

**Cooler ID:** BOX
**Custody Seal:** —
**IR Gun #** 8
**Delivered By:** UPS / Fed Ex / Spee Dee / Mail
Walk-in / Via / Courier / Other:_____
**Packing material:** Bubble/ Foam/ Paper/Other

**DW Coding Verified:**_____

**DW Data to SDWIS:** ☐

**Sample Receipt Discrepancies:** O No O Yes (if Yes, see detail below)

| | |
|---|---|
| O Container Problems: | O COC Problems |
| O Label Absent | O Chain of Custody not present |
| O Incorrect Containers for tests indicated | O Chain of Custody not present: Info obtained from PO or Letter |
| O Insufficient amount of sample for tests indicated | O COC missing time sampled, time obtained from sample container. |
| O Broken or leaking containers: _____ | O COC missing date sampled, date obtained from sample container |
| O Air bubbles in VOA vials:_____ | O Sample excluded from COC:_____ |
| O Analyses outside of hold: _____ | O Sample listed on COC not received: _____ |
| | O Sample description on container different from COC: _____ |

Detailed Description/comments: 3 boxes 15.2°, & 15.4° & 14.7°

Client contacted regarding cooler/sample receipt conditions: Yes / No Contacted by_____Date/Time:_____

Who was contacted:_____Remarks: See Comments on Element WO page



3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | Bradly Young | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC 15.2/15.4/14.7 | |
| 600-1-FD | 4/1/2024 | 22:30 | Heritage Middle School - Sink Tap - 001511-By Room 309-Boys | 1 | Wt | Grab | X | | | | | | | | 01 |
| 600-2-FD | 4/1/2024 | 22:30 | Heritage Middle School - Drinking Fountain - 001513-By Room 304 | 1 | Wt | Grab | X | | | | | | | | 02 |
| 600-3-FD | 4/1/2024 | 22:31 | Heritage Middle School - Sink Tap - 001514-By Room 301-Staff Bathroom | 1 | Wt | Grab | X | | | | | | | | 03 |
| 600-4-FD | 4/1/2024 | 22:33 | Heritage Middle School - Drinking Fountain - 001568-By Room 503 | 1 | Wt | Grab | X | | | | | | | | 04 |
| 600-5-FD | 4/1/2024 | 22:34 | Heritage Middle School - Sink Tap - 001566-Room 505 | 1 | Wt | Grab | X | | | | | | | | 05 |
| 600-6-FD | 4/1/2024 | 22:34 | Heritage Middle School - Sink Tap - 002385-Room 505 | 1 | Wt | Grab | X | | | | | | | | 06 |
| 600-7-FD | 4/1/2024 | 22:35 | Heritage Middle School - Sink Tap - 001565-Room 507 | 1 | Wt | Grab | X | | | | | | | | 07 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | | 4/16/24 | | |
| | Time: | | Sara Thompson | Time: | | |
| | | | | 10:00 | | |

3HD0079

AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| ___ | 600 E. 17th St. S<br>Newton, IA 50208<br>Phone: 641-792-8451 | ___ | 3012 Ansborough Ave<br>Waterloo, IA 50701<br>Phone: 319-235-4440 | X | 835 S St. Paul<br>Kansas City, KS 66105<br>Phone: 913-321-7856 | ___ | 205 E Van Buren St<br>Centerville, IA 52544<br>Phone: 641-437-7023 |

| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-8-FD | 4/1/2024 | 22:35 | Heritage Middle School - Sink Tap - 002386-Room 507 | 1 | Wt | Grab | X | | | | | | | | 08 |
| 600-9-FD | 4/1/2024 | 22:35 | Heritage Middle School - Drinking Fountain - 001564-By Room 502 | 1 | Wt | Grab | X | | | | | | | | 09 |
| 600-10-FD | 4/1/2024 | 22:36 | Heritage Middle School - Sink Tap - 001563-Room 502 | 1 | Wt | Grab | X | | | | | | | | 10 |
| 600-11-FD | 4/1/2024 | 22:36 | Heritage Middle School - Sink Tap - 001562F-Room 501A | 1 | Wt | Grab | X | | | | | | | | 11 |
| 600-12-FD | 4/1/2024 | 22:36 | Heritage Middle School - Bubbler - 001562B-Room 501A | 1 | Wt | Grab | X | | | | | | | | 12 |
| 600-13-FD | 4/1/2024 | 22:36 | Heritage Middle School - Sink Tap - 001561-Room 501 | 1 | Wt | Grab | X | | | | | | | | 13 |
| 600-14-FD | 4/1/2024 | 22:38 | Heritage Middle School - Sink Tap - 001560F-Room 202 | 1 | Wt | Grab | X | | | | | | | | 14 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | Sue Thompson | 4/5/24 | | |
| | Time: | | | Time: | | |
| | | | | 1600 | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| ___ | 600 E. 17th St. S<br>Newton, IA 50208<br>Phone: 641-792-8451 | ___ | 3012 Ansborough Ave<br>Waterloo, IA 50701<br>Phone: 319-235-4440 | X | 835 S St. Paul<br>Kansas City, KS 66105<br>Phone: 913-321-7856 | ___ | 205 E Van Buren St<br>Centerville, IA 52544<br>Phone: 641-437-7023 |

| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: | 3HD0079 |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-16-FD | 4/1/2024 | 22:38 | Heritage Middle School - Sink Tap - 001559F-Room 203 | 1 | Wt | Grab | X | | | | | | | | 15 |
| 600-17-FD | 4/1/2024 | 22:38 | Heritage Middle School - Bubbler - 001559B-Room 203 | 1 | Wt | Grab | X | | | | | | | | 16 |
| 600-18-FD | 4/1/2024 | 22:39 | Heritage Middle School - Sink Tap - 001556F-Room 205 | 1 | Wt | Grab | X | | | | | | | | 17 |
| 600-19-FD | 4/1/2024 | 22:39 | Heritage Middle School - Bubbler - 001556B-Room 205 | 1 | Wt | Grab | X | | | | | | | | 18 |
| 600-20-FD | 4/1/2024 | 22:40 | Heritage Middle School - Drinking Fountain - 001558/3331-By Room 206 | 1 | Wt | Grab | X | | | | | | | | 19 |
| 600-21-FD | 4/1/2024 | 22:40 | Heritage Middle School - Bottle Filler - 001558/3331F-By 206 | 1 | Wt | Grab | X | | | | | | | | 20 |
| 600-22-FD | 4/1/2024 | 22:41 | Heritage Middle School - Sink Tap - 001555F-Room 206 | 1 | Wt | Grab | X | | | | | | | | 21 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 1000 | |
| | Time: | | | | | |

3HD0079

AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-23-FD | 4/1/2024 | 22:40 | Heritage Middle School - Bubbler - 001555B- Room 206 | 1 | Wt | Grab | X | | | | | | | | 22 |
| 600-24-FD | 4/1/2024 | 22:41 | Heritage Middle School - Sink Tap - 001554F- Room 207 | 1 | Wt | Grab | X | | | | | | | | 23 |
| 600-25-FD | 4/1/2024 | 22:41 | Heritage Middle School - Bubbler - 001554B- Room 207 | 1 | Wt | Grab | X | | | | | | | | 24 |
| 600-26-FD | 4/1/2024 | 22:42 | Heritage Middle School - Sink Tap - 001553F- Room 208 | 1 | Wt | Grab | X | | | | | | | | 25 |
| 600-27-FD | 4/1/2024 | 22:42 | Heritage Middle School - Bubbler - 001553B- Room 208 | 1 | Wt | Grab | X | | | | | | | | 26 |
| 600-28-FD | 4/1/2024 | 22:44 | Heritage Middle School - Sink Tap - 001551F- Room 211 | 1 | Wt | Grab | X | | | | | | | | 27 |
| 600-29-FD | 4/1/2024 | 22:44 | Heritage Middle School - Bubbler - 001551B- Room 211 | 1 | Wt | Grab | X | | | | | | | | 28 |

LAB USE ONLY
Wk Order #: 3HD0079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | |
| | | | Sue Thompson | Time: 1000 | |
| | Time: | | | | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | LAB USE ONLY: Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-30-FD | 4/1/2024 | 22:45 | Heritage Middle School - Sink Tap - 001540-Room 212-Bathroom | 1 | Wt | Grab | X | | | | | | | | 29 |
| 600-31-FD | 4/1/2024 | 22:46 | Heritage Middle School - Sink Tap - 001531-Room 217 | 1 | Wt | Grab | X | | | | | | | | 30 |
| 600-32-FD | 4/1/2024 | 22:46 | Heritage Middle School - Sink Tap - 001516-Room 220 | 1 | Wt | Grab | X | | | | | | | | 31 |
| 600-33-FD | 4/1/2024 | 22:46 | Heritage Middle School - Sink Tap - 001515F-Room 221 | 1 | Wt | Grab | X | | | | | | | | 32 |
| 600-34-FD | 4/1/2024 | 22:47 | Heritage Middle School - Sink Tap - 001519-Greenhouse | 1 | Wt | Grab | X | | | | | | | | 33 |
| 600-35-FD | 4/1/2024 | 22:47 | Heritage Middle School - Sink Tap - 001547-By Room 225-Boys | 1 | Wt | Grab | X | | | | | | | | 34 |
| 600-36-FD | 4/1/2024 | 22:47 | Heritage Middle School - Sink Tap - 001548-By Room 225-Boys | 1 | Wt | Grab | X | | | | | | | | 35 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 1000 | |
| | Time: | | | | | |

3HD0079

AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| ___ | 600 E. 17th St. S<br>Newton, IA 50208<br>Phone: 641-792-8451 | ___ | 3012 Ansborough Ave<br>Waterloo, IA 50701<br>Phone: 319-235-4440 | X | 835 S St. Paul<br>Kansas City, KS 66105<br>Phone: 913-321-7856 | ___ | 205 E Van Buren St<br>Centerville, IA 52544<br>Phone: 641-437-7023 |

| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | LAB USE ONLY: Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD00079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-37-FD | 4/1/2024 | 22:48 | Heritage Middle School - Sink Tap - 001549-By 225-Boys | 1 | Wt | Grab | X | | | | | | | | 36 |
| 600-39-FD | 4/1/2024 | 22:49 | Heritage Middle School - Sink Tap - 001543-By 225-Girls | 1 | Wt | Grab | X | | | | | | | | 37 |
| 600-40-FD | 4/1/2024 | 22:49 | Heritage Middle School - Sink Tap - 001544-By 225-Girls | 1 | Wt | Grab | X | | | | | | | | 38 |
| 600-41-FD | 4/1/2024 | 22:49 | Heritage Middle School - Sink Tap - 001545-By 225-Girls | 1 | Wt | Grab | X | | | | | | | | 39 |
| 600-42-FD | 4/1/2024 | 22:50 | Heritage Middle School - Sink Tap - 001546-By 225-Girls | 1 | Wt | Grab | X | | | | | | | | 40 |
| 600-43-FD | 4/1/2024 | 22:50 | Heritage Middle School - Drinking Fountain - 001542B-By 225 | 1 | Wt | Grab | X | | | | | | | | 41 |
| 600-44-FD | 4/1/2024 | 22:50 | Heritage Middle School - Bottle Filler - 001542F-By 225 | 1 | Wt | Grab | X | | | | | | | | 42 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | Sue Thompson | 4/5/24 | | |
| | Time: | | | Time: | | |
| | | | | 1000 | | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD00079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-45-FD | 4/1/2024 | 22:50 | Heritage Middle School - Drinking Fountain - 001542B-By 225-Right | 1 | Wt | Grab | X | | | | | | | | 43 |
| 600-46-FD | 4/1/2024 | 22:54 | Heritage Middle School - Drinking Fountain - 002378B-By Room 100 | 1 | Wt | Grab | X | | | | | | | | 44 |
| 600-47-FD | 4/1/2024 | 22:54 | Heritage Middle School - Bottle Filler - 002378F-By Room 100 | 1 | Wt | Grab | X | | | | | | | | 45 |
| 600-48-FD | 4/1/2024 | 22:55 | Heritage Middle School - Sink Tap - 001668-Lounge | 1 | Wt | Grab | X | | | | | | | | 46 |
| 600-49-FD | 4/1/2024 | 22:55 | Heritage Middle School - Ice Machine - 000627-L-Lounge | 1 | Wt | Grab | X | | | | | | | | 47 |
| 600-50-FD | 4/1/2024 | 22:55 | Heritage Middle School - Ice Maker/Fridge - 002380-Lounge | 1 | Wt | Grab | X | | | | | | | | 48 |
| 600-51-FD | 4/1/2024 | 22:56 | Heritage Middle School - Coffee Pot - 002379-Lounge | 1 | Wt | Grab | X | | | | | | | | 49 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | | 4/5/24 | | |
| | Time: | | Sue Thompson | Time: | | |
| | | | | 1000 | | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | LAB USE ONLY: Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-52-FD | 4/1/2024 | 22:56 | Heritage Middle School - Sink Tap - 001667-North of Lounge-Storage Room | 1 | Wt | Grab | X | | | | | | | | S0 |
| 600-53-FD | 4/1/2024 | 22:58 | Heritage Middle School - Sink Tap - 001647-Room 105 | 1 | Wt | Grab | X | | | | | | | | S1 |
| 600-54-FD | 4/1/2024 | 22:58 | Heritage Middle School - Sink Tap - 001646F-Room 107 | 1 | Wt | Grab | X | | | | | | | | S2 |
| 600-55-FD | 4/1/2024 | 22:58 | Heritage Middle School - Bubbler - 001646B-Room 107 | 1 | Wt | Grab | X | | | | | | | | S3 |
| 600-56-FD | 4/1/2024 | 22:59 | Heritage Middle School - Sink Tap - 001641F-Room 108 | 1 | Wt | Grab | X | | | | | | | | S4 |
| 600-57-FD | 4/1/2024 | 22:59 | Heritage Middle School - Bubbler - 001641B-Room 108 | 1 | Wt | Grab | X | | | | | | | | S5 |
| 600-58-FD | 4/1/2024 | 22:59 | Heritage Middle School - Sink Tap - 001642-Room 108 | 1 | Wt | Grab | X | | | | | | | | S10 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | | 4/5/24 | | |
| | Time: | | Sue Thompson | Time: | | |
| | | | | 1000 | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-59-FD | 4/1/2024 | 22:59 | Heritage Middle School - Sink Tap - 001643-Room 108 | 1 | Wt | Grab | X | | | | | | | | 57 |
| 600-60-FD | 4/1/2024 | 23:00 | Heritage Middle School - Sink Tap - 001644-Room 108 | 1 | Wt | Grab | X | | | | | | | | 58 |
| 600-61-FD | 4/1/2024 | 23:00 | Heritage Middle School - Sink Tap - 001645-Room 109 | 1 | Wt | Grab | X | | | | | | | | 59 |
| 600-62-FD | 4/1/2024 | 23:00 | Heritage Middle School - Sink Tap - 001637F-Room 110 | 1 | Qt | Grab | X | | | | | | | | 60 |
| 600-63-FD | 4/1/2024 | 23:00 | Heritage Middle School - Bubbler - 001637B-Room 110 | 1 | Wt | Grab | X | | | | | | | | 61 |
| 600-64-FD | 4/1/2024 | 23:01 | Heritage Middle School - Sink Tap - 001638-Room 110 | 1 | Qt | Grab | X | | | | | | | | 62 |
| 600-65-FD | 4/1/2024 | 23:01 | Heritage Middle School - Sink Tap - 001639-Room 110 | 1 | Wt | Grab | X | | | | | | | | 63 |

LAB USE ONLY
Wk Order #: 3HD0079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | |
| | | | Sue Thompson | Time: 1000 | |
| | Time: | | | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

___ 3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

___ 205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-66-FD | 4/1/2024 | 23:01 | Heritage Middle School - Sink Tap - 001640-Room 110 | 1 | Wt | Grab | X | | | | | | | | 64 |
| 600-67-FD | 4/1/2024 | 23:02 | Heritage Middle School - Sink Tap - 001631F-Room 111 | 1 | Wt | Grab | X | | | | | | | | 65 |
| 600-68-FD | 4/1/2024 | 23:02 | Heritage Middle School - Bubbler - 001631B-Room 111 | 1 | Wt | Grab | X | | | | | | | | 66 |
| 600-69-FD | 4/1/2024 | 23:02 | Heritage Middle School - Sink Tap - 001632-Room 111 | 1 | Wt | Grab | X | | | | | | | | 67 |
| 600-70-FD | 4/1/2024 | 23:02 | Heritage Middle School - Sink Tap - 001633-Room 111 | 1 | Wt | Grab | X | | | | | | | | 68 |
| 600-71-FD | 4/1/2024 | 23:03 | Heritage Middle School - Sink Tap - 001634-Room 111 | 1 | Wt | Grab | X | | | | | | | | 69 |
| 600-72-FD | 4/1/2024 | 23:03 | Heritage Middle School - Sink Tap - 001635-Room 111 | 1 | Wt | Grab | X | | | | | | | | 70 |

LAB USE ONLY
Wk Order #: 3HD0079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | |
| | | | Sue Thompson | Time: 1000 | |
| | Time: | | | | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-73-FD | 4/1/2024 | 23:03 | Heritage Middle School - Sink Tap - 001636-Room 111 | 1 | Wt | Grab | X | | | | | | | | 71 |
| 600-74-FD | 4/1/2024 | 23:04 | Heritage Middle School - Sink Tap - 001648F-Room 112 | 1 | Wt | Grab | X | | | | | | | | 72 |
| 600-75-FD | 4/1/2024 | 23:04 | Heritage Middle School - Bubbler - 001648B-Room 112 | 1 | Wt | Grab | X | | | | | | | | 73 |
| 600-76-FD | 4/1/2024 | 23:06 | Heritage Middle School - Sink Tap - 001653-By 118-Boys | 1 | Wt | Grab | X | | | | | | | | 74 |
| 600-77-FD | 4/1/2024 | 23:06 | Heritage Middle School - Sink Tap - 001654-By 118-Boys | 1 | Wt | Grab | X | | | | | | | | 75 |
| 600-78-FD | 4/1/2024 | 23:06 | Heritage Middle School - Sink Tap - 001655-By 118-Boys | 1 | Wt | Grab | X | | | | | | | | 76 |
| 600-79-FD | 4/1/2024 | 23:07 | Heritage Middle School - Sink Tap - 001649-Room 120-Girls | 1 | Wt | Grab | X | | | | | | | | 77 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 0000 | |
| | Time: | | | | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

___ 3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

___ 205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | LAB USE ONLY: Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD00079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-80-FD | 4/1/2024 | 23:07 | Heritage Middle School - Sink Tap - 001650-By 120-Girls | 1 | Wt | Grab | X | | | | | | | | 78 |
| 600-81-FD | 4/1/2024 | 23:07 | Heritage Middle School - Sink Tap - 001651-By 120-Girls | 1 | Wt | Grab | X | | | | | | | | 79 |
| 600-82-FD | 4/1/2024 | 23:08 | Heritage Middle School - Drinking Fountain - 002376B-By Rm 114 | 1 | Wt | Grab | X | | | | | | | | 80 |
| 600-83-FD | 4/1/2024 | 23:08 | Heritage Middle School - Bottle Filler - 002376F-By Room 114 | 1 | Wt | Grab | X | | | | | | | | 81 |
| 600-84-FD | 4/1/2024 | 23:08 | Heritage Middle School - Drinking Fountain - 002377-By Room 114 | 1 | Wt | Grab | X | | | | | | | | 82 |
| 600-85-FD | 4/1/2024 | 23:09 | Heritage Middle School - Drinking Fountain - 001657-Gym-NE Corner | 1 | Wt | Grab | X | | | | | | | | 83 |
| 600-86-FD | 4/1/2024 | 23:09 | Heritage Middle School - Drinking Fountain - 001658-Gym-SW Corner | 1 | Qt | Grab | X | | | | | | | | 84 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | |
| | | | Sara Thompson | Time: 1000 | |
| | Time: | | | | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

___ 3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

___ 205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-87-FD | 4/1/2024 | 23:09 | Heritage Middle School - Sink Tap - 001659-Concessions | 1 | Wt | Grab | X | | | | | | | | 85 |
| 600-88-FD | 4/1/2024 | 23:09 | Heritage Middle School - Sink Tap - 001660-Gym-Concessions | 1 | Wt | Grab | X | | | | | | | | 86 |
| 600-89-FD | 4/1/2024 | 23:10 | Heritage Middle School - Sink Tap - 001665-Room 117 | 1 | Wt | Grab | X | | | | | | | | 87 |
| 600-90-FD | 4/1/2024 | 23:11 | Heritage Middle School - Drinking Fountain - 003318-By Room 120 | 1 | Wt | Grab | X | | | | | | | | 88 |
| 600-91-FD | 4/1/2024 | 23:11 | Heritage Middle School - Drinking Fountain - 003319-By Room 120 | 1 | Wt | Grab | X | | | | | | | | 89 |
| 600-92-FD | 4/1/2024 | 23:12 | Heritage Middle School - Sink Tap - 001663-Copy Room-Boys | 1 | Wt | Grab | X | | | | | | | | 90 |
| 600-93-FD | 4/1/2024 | 23:12 | Heritage Middle School - Sink Tap - 001664-Copy Room-Girls | 1 | Wt | Grab | X | | | | | | | | 91 |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 1000 | |
| | Time: | | | | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-94-FD | 4/1/2024 | 23:14 | Heritage Middle School - Sink Tap - 001684-By 128-Girls | 1 | Wt | Grab | X | | | | | | | | 92 |
| 600-95-FD | 4/1/2024 | 23:14 | Heritage Middle School - Sink Tap - 001685-By 128-Girls | 1 | Wt | Grab | X | | | | | | | | 93 |
| 600-96-FD | 4/1/2024 | 23:14 | Heritage Middle School - Sink Tap - 001686-By 128-Girls | 1 | Wt | Grab | X | | | | | | | | 94 |
| 600-97-FD | 4/1/2024 | 23:14 | Heritage Middle School - Sink Tap - 001687-By 128-Girls | 1 | Wt | Grab | X | | | | | | | | 95 |
| 600-98-FD | 4/1/2024 | 23:15 | Heritage Middle School - Sink Tap - 001679-By 126-Boys | 1 | Wt | Grab | X | | | | | | | | 96 |
| 600-99-FD | 4/1/2024 | 23:15 | Heritage Middle School - Sink Tap - 001680-By 126-Boys | 1 | Wt | Grab | X | | | | | | | | 97 |
| 600-100-FD | 4/1/2024 | 23:15 | Heritage Middle School - Sink Tap - 001681-By 126-Boys | 1 | Wt | Grab | X | | | | | | | | 98 |

LAB USE ONLY
Wk Order #: 3HD0079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | |
| | | | Sue Thompson | 4/5/24 | |
| | Time: | | | Time: | |
| | | | | 0000 | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD00079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-101-FD | 4/1/2024 | 23:16 | Heritage Middle School - Sink Tap - 001682-By 126-Boys | 1 | Wt | Grab | X | | | | | | | | 99 |
| 600-102-FD | 4/1/2024 | 23:18 | Heritage Middle School - Sink Tap - 002383-By Room 400 | 1 | Wt | Grab | X | | | | | | | | AA |
| 600-103-FD | 4/1/2024 | 23:18 | Heritage Middle School - Sink Tap - 002384-By 400 | 1 | Wt | Grab | X | | | | | | | | AB |
| 600-104-FD | 4/1/2024 | 23:18 | Heritage Middle School - Drinking Fountain - 001676-400 Hall | 1 | Wt | Grab | X | | | | | | | | AC |
| 600-105-FD | 4/1/2024 | 23:19 | Heritage Middle School - Sink Tap - 001677-Room 400 | 1 | Wt | Grab | X | | | | | | | | AD |
| 600-106-FD | 4/1/2024 | 23:20 | Heritage Middle School - Drinking Fountain - 001675-400s Hall | 1 | Wt | Grab | X | | | | | | | | AE |
| 600-107-FD | 4/1/2024 | 23:20 | Heritage Middle School - Sink Tap - 002381-400 Hall-Boys | 1 | Wt | Grab | X | | | | | | | | AF |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | |
| | | | Sue Thompson | 4/5/24 | |
| | Time: | | | Time: | |
| | | | | 1000 | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-108-FD | 4/1/2024 | 23:20 | Heritage Middle School - Sink Tap - 002382-400 Hall-Boys | 1 | Wt | Grab | X | | | | | | | | AG |
| 600-109-FD | 4/1/2024 | 23:22 | Heritage Middle School - Sink Tap - 001672-Nurse Office | 1 | Wt | Grab | X | | | | | | | | AH |
| 600-110-FD | 4/1/2024 | 23:22 | Heritage Middle School - Sink Tap - 001671-Nurse Office-Bathroom | 1 | Wt | Grab | X | | | | | | | | AI |
| 600-111-FD | 4/1/2024 | 23:22 | Heritage Middle School - Sink Tap - 001670-Nurse Office-Bathroom | 1 | Wt | Grab | X | | | | | | | | AJ |
| 600-112-FD | 4/1/2024 | 23:25 | Heritage Middle School - Sink Tap - 001601-Room 23 | 1 | Wt | Grab | X | | | | | | | | AK |
| 600-113-FD | 4/1/2024 | 23:25 | Heritage Middle School - Sink Tap - 001602-Room 23 | 1 | Wt | Grab | X | | | | | | | | AL |
| 600-114-FD | 4/1/2024 | 23:25 | Heritage Middle School - Sink Tap - 001603-Room 23 | 1 | Wt | Grab | X | | | | | | | | AM |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 1000 | |
| | Time: | | | | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-115-FD | 4/1/2024 | 23:25 | Heritage Middle School - Sink Tap - 001604-Room 23 | 1 | Wt | Grab | X | | | | | | | | AN |
| 600-116-FD | 4/1/2024 | 23:26 | Heritage Middle School - Sink Tap - 001605-Room 23 | 1 | Wt | Grab | X | | | | | | | | AO |
| 600-117-FD | 4/1/2024 | 23:26 | Heritage Middle School - Sink Tap - 001606-Room 23 | 1 | Wt | Grab | X | | | | | | | | AP |
| 600-118-FD | 4/1/2024 | 23:27 | Heritage Middle School - Sink Tap - 001598-Library-Work Room | 1 | Wt | Grab | X | | | | | | | | AQ |
| 600-119-FD | 4/1/2024 | 23:28 | Heritage Middle School - Sink Tap - 001599-Library-Bathroom | 1 | Wt | Grab | X | | | | | | | | AR |
| 600-120-FD | 4/1/2024 | 23:30 | Heritage Middle School - Sink Tap - 001597-Room 12-Wood Shop | 1 | Wt | Grab | X | | | | | | | | AS |
| 600-121-FD | 4/1/2024 | 23:30 | Heritage Middle School - Sink Tap - 001592-By Wood Shop-Girls | 1 | Wt | Grab | X | | | | | | | | AT |

LAB USE ONLY
Wk Order #: 3HD00079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | |
| | | | Sue Thompson | 4/5/24 | |
| | Time: | | | Time: | |
| | | | | 1000 | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-122-FD | 4/1/2024 | 23:31 | Heritage Middle School - Sink Tap - 001593-By Wood Shop-Girls | 1 | Wt | Grab | X | | | | | | | | AU |
| 600-123-FD | 4/1/2024 | 23:31 | Heritage Middle School - Sink Tap - 001594-By Wood Shop-Boys | 1 | Wt | Grab | X | | | | | | | | AV |
| 600-124-FD | 4/1/2024 | 23:31 | Heritage Middle School - Sink Tap - 001595-By Wood Shop-Boys | 1 | Wt | Grab | X | | | | | | | | AW |
| 600-125-FD | 4/1/2024 | 23:32 | Heritage Middle School - Drinking Fountain - 002371-By Wood Shop | 1 | Wt | Grab | X | | | | | | | | AX |
| 600-126-FD | 4/1/2024 | 23:32 | Heritage Middle School - Drinking Fountain - 002372-By Wood Shop | 1 | Wt | Grab | X | | | | | | | | AY |
| 600-127-FD | 4/1/2024 | 23:34 | Heritage Middle School - Sink Tap - 001608-Locker Room-Girls | 1 | Wt | Grab | X | | | | | | | | AZ |
| 600-128-FD | 4/1/2024 | 23:34 | Heritage Middle School - Sink Tap - 001609-Locker Room-Girls | 1 | Wt | Grab | X | | | | | | | | BA |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | | |
| | | | Sara Thompson | Time: 1000 | | |
| | Time: | | | | | |

3HD0079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-129-FD | 4/1/2024 | 23:35 | Heritage Middle School - Sink Tap - 001610-Locker Room-Girls | 1 | Wt | Grab | X | | | | | | | | BB |
| 600-130-FD | 4/1/2024 | 23:35 | Heritage Middle School - Sink Tap - 001611-Locker Room-Girls | 1 | Wt | Grab | X | | | | | | | | BC |
| 600-131-FD | 4/1/2024 | 23:35 | Heritage Middle School - Sink Tap - 001612-Locker Room-Girls | 1 | Wt | Grab | X | | | | | | | | BD |
| 600-132-FD | 4/1/2024 | 23:35 | Heritage Middle School - Sink Tap - 001613-Locker Room-Girls-Office | 1 | Wt | Grab | X | | | | | | | | BE |
| 600-133-FD | 4/1/2024 | 23:37 | Heritage Middle School - Drinking Fountain - 002373-Weight Room | 1 | Wt | Grab | X | | | | | | | | BF |
| 600-134-FD | 4/1/2024 | 23:37 | Heritage Middle School - Drinking Fountain - 001614-Weight Room | 1 | Wt | Grab | X | | | | | | | | BG |
| 600-135-FD | 4/1/2024 | 23:37 | Heritage Middle School - Sink Tap - 001616-Weight Room-Bathroom | 1 | Wt | Grab | X | | | | | | | | BH |

LAB USE ONLY
Wk Order #: 3HD0079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | |
| | | | Sue Thompson | 4/5/24 | |
| | Time: | | | Time: | |
| | | | | 1000 | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-136-FD | 4/1/2024 | 23:38 | Heritage Middle School - Drinking Fountain - 002374-Exercise Room | 1 | Wt | Grab | X | | | | | | | | BI |
| 600-137-FD | 4/1/2024 | 23:38 | Heritage Middle School - Bottle Filler - 002375-Exercise Room | 1 | Wt | Grab | X | | | | | | | | BJ |
| 600-138-FD | 4/1/2024 | 23:38 | Heritage Middle School - Sink Tap - 001617-Boys Lockers-Office | 1 | Wt | Grab | X | | | | | | | | BK |
| 600-139-FD | 4/1/2024 | 23:40 | Heritage Middle School - Bubbler - 001618-Locker Room-Boys | 1 | Wt | Grab | X | | | | | | | | BL |
| 600-140-FD | 4/1/2024 | 23:40 | Heritage Middle School - Sink Tap - 001619-Locker Room-Boys | 1 | Wt | Grab | X | | | | | | | | BM |
| 600-141-FD | 4/1/2024 | 23:40 | Heritage Middle School - Sink Tap - 001620-Locker Room-Boys | 1 | Wt | Grab | X | | | | | | | | BN |
| 600-142-FD | 4/1/2024 | 23:41 | Heritage Middle School - Sink Tap - 001621-Locker Room-Boys | 1 | Qt | Grab | X | | | | | | | | BO |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | Remarks: |
|---|---|---|---|---|---|
| | | | | | |
| | Time: | | | Time: | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | |
| | | | Sue Thompson | Time: 1000 | |
| | Time: | | | | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

___ 3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

___ 205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD0079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-143-FD | 4/1/2024 | 23:44 | Heritage Middle School - Sink Tap - 001581-By Lunch Room-Girls | 1 | Wt | Grab | X | | | | | | | | BP |
| 600-144-FD | 4/1/2024 | 23:44 | Heritage Middle School - Sink Tap - 001582-By Lunch Room-Girls | 1 | Wt | Grab | X | | | | | | | | BQ |
| 600-145-FD | 4/1/2024 | 23:44 | Heritage Middle School - Sink Tap - 001583-By Lunch Room-Girls | 1 | Wt | Grab | X | | | | | | | | BR |
| 600-146-FD | 4/1/2024 | 23:44 | Heritage Middle School - Sink Tap - 001584-By Lunch Room-Girls | 1 | Wt | Grab | X | | | | | | | | BS |
| 600-147-FD | 4/1/2024 | 23:45 | Heritage Middle School - Sink Tap - 003317-By Lunch Room-Girls | 1 | Wt | Grab | X | | | | | | | | BT |
| 600-148-FD | 4/1/2024 | 23:45 | Heritage Middle School - Sink Tap - 001585-By Lunch Room-Boys | 1 | Wt | Grab | X | | | | | | | | BU |
| 600-149-FD | 4/1/2024 | 23:45 | Heritage Middle School - Sink Tap - 001586-By Lunch Room-Boys | 1 | Wt | Grab | X | | | | | | | | BV |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: 4/5/24 | | |
| | | | Sue Thompson | Time: 1000 | | |
| | Time: | | | | | |

3 H D 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: 3HD00079 | |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-150-FD | 4/1/2024 | 23:46 | Heritage Middle School - Sink Tap - 001587-By Lunch Room-Boys | 1 | Wt | Grab | X | | | | | | | | BW |
| 600-151-FD | 4/1/2024 | 23:46 | Heritage Middle School - Sink Tap - 001588-By Lunch Room-Boys | 1 | Wt | Grab | X | | | | | | | | BX |
| 600-152-FD | 4/1/2024 | 23:46 | Heritage Middle School - Sink Tap - 003316-By Lunch Room-Boys | 1 | Wt | Grab | X | | | | | | | | BY |
| 600-153-FD | 4/1/2024 | 23:47 | Heritage Middle School - Drinking Fountain - 001590B-By Lunch Room | 1 | Wt | Grab | X | | | | | | | | BZ |
| 600-154-FD | 4/1/2024 | 23:47 | Heritage Middle School - Bottle Filler - 001590F-By Lunch Room | 1 | Wt | Grab | X | | | | | | | | CA |
| 600-155-FD | 4/1/2024 | 23:47 | Heritage Middle School - Drinking Fountain - 001590-By Lunch Room | 1 | Wt | Grab | X | | | | | | | | CB |
| 600-156-FD | 4/1/2024 | 23:52 | Heritage Middle School - Ice Machine - 000625-L-Kitchen | 1 | Wt | Grab | X | | | | | | | | CC |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | Sue Thompson | 4/5/24 | | |
| | Time: | | | Time: | | |
| | | | | 1000 | | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-157-FD | 4/1/2024 | 23:52 | Heritage Middle School - Sink Tap - 000468-L-Kitchen | 1 | Wt | Grab | X | | | | | | | | CD |
| 600-158-FD | 4/1/2024 | 23:52 | Heritage Middle School - Sink Tap - 001569-Kitchen | 1 | Wt | Grab | X | | | | | | | | CE |
| 600-159-FD | 4/1/2024 | 23:53 | Heritage Middle School - Sink Tap - 001570-Kitchen | 1 | Wt | Grab | X | | | | | | | | CF |
| 600-160-FD | 4/1/2024 | 23:54 | Heritage Middle School - Sink Tap - 001571-Kitchen | 1 | Wt | Grab | X | | | | | | | | CG |
| 600-161-FD | 4/1/2024 | 23:55 | Heritage Middle School - Tilt Skillet - 000815-L-Kitchen | 1 | Wt | Grab | X | | | | | | | | CH |
| 600-162-FD | 4/1/2024 | 23:55 | Heritage Middle School - Sink Tap - 001752-Kitchen | 1 | Wt | Grab | X | | | | | | | | CI |
| 600-163-FD | 4/1/2024 | 23:55 | Heritage Middle School - Sink Tap - 001573-Kitchen | 1 | Wt | Grab | X | | | | | | | | CJ |

LAB USE ONLY
Wk Order #: 3HD00079
Short Hold:
Rush:
Temp: oC

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | Sara Thompson | 4/5/24 | | |
| | Time: | | | Time: | | |
| | | | | 1000 | | |

3 H D 0 0 0 7 9
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: | 3HD00079 |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-164-FD | 4/1/2024 | 23:56 | Heritage Middle School - Sink Tap - 001575-Kitchen | 1 | Wt | Grab | X | | | | | | | | CK |
| 600-165-FD | 4/1/2024 | 23:56 | Heritage Middle School - Sink Tap - 001576-Kitchen | 1 | Wt | Grab | X | | | | | | | | CL |
| 600-166-FD | 4/1/2024 | 23:56 | Heritage Middle School - Sink Tap - 001577-Kitchen | 1 | Wt | Grab | X | | | | | | | | CM |
| 600-167-FD | 4/1/2024 | 23:57 | Heritage Middle School - Sink Tap - 001578-Kitchen | 1 | Wt | Grab | X | | | | | | | | CN |
| 600-168-FD | 4/1/2024 | 23:57 | Heritage Middle School - Sink Tap - 001579-Kitchen | 1 | Wt | Grab | X | | | | | | | | CO |
| 600-169-FD | 4/1/2024 | 23:58 | Heritage Middle School - Sink Tap - 001580-Kitchen | 1 | Qt | Grab | X | | | | | | | | CP |
| 600-170-FD | 4/1/2024 | 23:58 | Heritage Middle School - Sink Tap - 004530-Kitchen | 1 | Wt | Grab | X | | | | | | | | CQ |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 4/5/24 | |
| | | | Sue Thompson | Time: | 1000 | |
| | Time: | | | | | |

3HD00079
AXIOM Service Professionals
PM: Carolyn Jackson

Keystone LABORATORIES
A Microbac Company


600 E. 17th St. S
Newton, IA 50208
Phone: 641-792-8451

3012 Ansborough Ave
Waterloo, IA 50701
Phone: 319-235-4440

X 835 S St. Paul
Kansas City, KS 66105
Phone: 913-321-7856

205 E Van Buren St
Centerville, IA 52544
Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | Wk Order #: | 3HD0079 |
| | | | | | | | | | | | | | | Short Hold: | |
| | | | | | | | | | | | | | | Rush: | |
| | | | | | | | | | | | | | | Temp: oC | |
| 600-171-FD | 4/1/2024 | 23:59 | Heritage Middle School - Sink Tap - 004531- Kitchen | 1 | Wt | Grab | X | | | | | | | | CR |
| 600-172-FD | 4/1/2024 | 23:59 | Heritage Middle School - Sink Tap - 004532- Kitchen | 1 | Wt | Grab | X | | | | | | | | CS |
| 600-173-FD | 4/1/2024 | 23:59 | Heritage Middle School - Sink Tap - 004533- Kitchen | 1 | Wt | Grab | X | | | | | | | | CT |
| 600-174-FD | 4/1/2024 | 00:00 | Heritage Middle School - Sink Tap - 001574- Kitchen-Bathroom | 1 | Wt | Grab | X | | | | | | | | CU |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | | | | | | |
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | |
| | | | Sue Thompson | 4/5/24 | | |
| | Time: | | | Time: | | |
| | | | | 1600 | | |

3HD0079

AXIOM Service Professionals

PM: Carolyn Jackson

MICROBAC®

# Microbac Laboratories, Inc., Lenexa

## CERTIFICATE OF ANALYSIS

## 3HE0032

**AXIOM Service Professionals**

Jeff Hurst
PO Box 47166
Kansas City, MO 64188

**Project Name: Heritage Middle School**

Project / PO Number: Heritage Middle School
Received: 05/02/2024
Reported: 05/10/2024

**Work Order Special Information**

Young, Bradly
Heritage Middle School

**Analytical Testing Parameters**

**Client Sample ID:** 600-15-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HE0032-01
**Collected By:** Young, Bradly
**Collection Date:** 04/30/2024 22:52

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **16.0** | 0.4 | ppb | 2 | | 05/07/24 1516 | 05/09/24 0247 | RVV |

**Client Sample ID:** 600-38-FD
**Sample Matrix:** Drinking Water
**Lab Sample ID:** 3HE0032-02
**Collected By:** Young, Bradly
**Collection Date:** 04/30/2024 22:54

Analyses Performed by: Microbac Laboratories, Inc., Newton

| Determination of Total Metals | Result | RL | Units | DF | Note | Prepared | Analyzed | Analyst |
|---|---|---|---|---|---|---|---|---|
| **200.8** | | | | | | | | |
| Lead, total | **1.2** | 0.4 | ppb | 2 | | 05/07/24 1516 | 05/09/24 0253 | RVV |

**Definitions**

**RL:** Reporting Limit

**Report Comments**

**Reviewed and Approved By:**



Carolyn Jackson
Project Manager
carolyn.jackson@microbac.com
05/10/24 13:18

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.* ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Keystone LABORATORIES
A Microbac Company


___ 600 E. 17th St. S, Newton, IA 50208, Phone: 641-792-8451
___ 3012 Ansborough Ave, Waterloo, IA 50701, Phone: 319-235-4440
X 835 S St. Paul, Kansas City, KS 66105, Phone: 913-321-7856
___ 205 E Van Buren St, Centerville, IA 52544, Phone: 641-437-7023


| PRINT OR TYPE INFO BELOW: | | REPORT TO: | | BILL TO: | |
|---|---|---|---|---|---|
| SAMPLER: | Bradly Young | NAME: | Jeff Hurst | NAME: | Jeff Hurst |
| SITE NAME: | | CO. NAME: | | CO. NAME: | |
| ADDRESS: | 600 West Kansas Street | ADRESS: | PO Box 47166 | ADDRESS: | PO Box 47166 |
| CITY/ST/ZIP: | Liberty, Missouri 64068 | CITY/ST/ZIP: | Kansas City, Missouri 64188 | CITY/ST/ZIP: | Kansas City, Missouri 64188 |
| PHONE: | 816-522-2275 | PHONE: | 816-678-7894 | PHONE: | 816-678-7894 |
| | | EMAIL: | jeffh@axiomservicepros.com | EMAIL: | jeffh@axiomservicepros.com |

| CLIENT SAMPLE # | DATE | TIME | | # OF CONTAINERS | MATRIX | GRAB/COMPOSITE | ANALYSES REQUIRED: Lead | | | | | | | LAB USE ONLY: Sample Condition | Sample # |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 600-15-FD | 4/30/2024 | 22:52 | Heritage Middle - Bubbler - 001560B-Room 202 | 1 | Wt | Grab | X | | | | | | | | 3HE0032-01 |
| 600-38-FD | 4/30/2024 | 22:54 | Heritage Middle - Sink Tap - 001550-By Room 225-Boys-Far Left | 1 | Wt | Grab | X | | | | | | | | -02 |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |

LAB USE ONLY
Wk Order #: 3HE0032
Short Hold:
Rush:
Temp: oC 20.0

3HE0032
AXIOM Service Professionals
PM: Carolyn Jackson

| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | | Remarks: |
|---|---|---|---|---|---|---|
| | Time: | | | Time: | | |
| Relinquied by: (Signature) | Date: | | Received by: (Signature) | Date: | 05/02/24 | |
| | Time: | | Carolyn Jackson | Time: | 12:00 | |

# Appendix D
# Photo Log




4/1/2024 - 600-1 - Heritage Middle School - 001511-By Room 309-Boys





4/1/2024 - 600-2 - Heritage Middle School - 001513-By Room 304



4/1/2024 - 600-3 - Heritage Middle School - 001514-By Room 301-Staff Restroom





4/1/2024 - 600-4 - Heritage Middle School - 001568-By Room 503




4/1/2024 - 600-5 - Heritage Middle School - 001566-Room 505



4/1/2024 - 600-6 - Heritage Middle School - 002385-Room 505





4/1/2024 - 600-7 - Heritage Middle School - 001565-Room 507




4/1/2024 - 600-8 - Heritage Middle School - 002386-Room 507



4/1/2024 - 600-9 - Heritage Middle School - 001564-By Room 502



4/1/2024 - 600-10 - Heritage Middle School - 001563-Room 502



4/1/2024 - 600-11 - Heritage Middle School - 001562F-Room 501A



4/1/2024 - 600-12 - Heritage Middle School - 001562B-Room 501A



4/1/2024 - 600-13 - Heritage Middle School - 001561-Room 501




4/1/2024 - 600-14 - Heritage Middle School - 001560F-Room 202




4/1/2024 - 600-15 - Heritage Middle School - 001560B-Room 202 - Out of Order



4/1/2024 - 600-16 - Heritage Middle School - 001559F-Room 203




4/1/2024 - 600-17 - Heritage Middle School - 001559B-Room 203




4/1/2024 - 600-18 - Heritage Middle School - 001556F-Room 205



4/1/2024 - 600-19 - Heritage Middle School - 001556B-Room 205




4/1/2024 - 600-20 - Heritage Middle School - 001558/3331-By Room 206




4/1/2024 - 600-21 - Heritage Middle School - 001558/3331F-By 206



4/1/2024 - 600-22 - Heritage Middle School - 001555F-Room 206




4/1/2024 - 600-23 - Heritage Middle School - 001555B-Room 206





4/1/2024 - 600-24 - Heritage Middle School - 001554F-Room 207



4/1/2024 - 600-25 - Heritage Middle School - 001554B-Room 207



4/1/2024 - 600-26 - Heritage Middle School - 001553F-Room 208



4/1/2024 - 600-27 - Heritage Middle School - 001553B-Room 208




4/1/2024 - 600-28 - Heritage Middle School - 001551F-Room 211



4/1/2024 - 600-29 - Heritage Middle School - 001551B-Room 211




4/1/2024 - 600-30 - Heritage Middle School - 001540-Room 212-Restroom




4/1/2024 - 600-31 - Heritage Middle School - 001531-Room 217





4/1/2024 - 600-32 - Heritage Middle School - 001516-Room 220




4/1/2024 - 600-33 - Heritage Middle School - 001515F-Room 221




4/1/2024 - 600-34 - Heritage Middle School - 001519-Greenhouse



4/1/2024 - 600-35 - Heritage Middle School - 001547-By Room 225-Boys



4/1/2024 - 600-36 - Heritage Middle School - 001548-By Room 225-Boys




4/1/2024 - 600-37 - Heritage Middle School - 001549-By 225-Boys



4/1/2024 - 600-38 - Heritage Middle School - 001550-By 225-Boys - Out of Order



4/1/2024 - 600-39 - Heritage Middle School - 001543-By 225-Girls



4/1/2024 - 600-40 - Heritage Middle School - 001544-By 225-Girls



4/1/2024 - 600-41 - Heritage Middle School - 001545-By 225-Girls



4/1/2024 - 600-42 - Heritage Middle School - 001546-By 225-Girls




4/1/2024 - 600-43 - Heritage Middle School - 001542B-By 225




4/1/2024 - 600-44 - Heritage Middle School - 001542F-By 225




4/1/2024 - 600-45 - Heritage Middle School - 001542B-By 225-Right




4/1/2024 - 600-46 - Heritage Middle School - 002378B-By Room 100





4/1/2024 - 600-47 - Heritage Middle School - 002378F-By Room 100



4/1/2024 - 600-48 - Heritage Middle School - 001668-Lounge



4/1/2024 - 600-49 - Heritage Middle School - 000627-L-Lounge



4/1/2024 - 600-50 - Heritage Middle School - 002380-Lounge




4/1/2024 - 600-51 - Heritage Middle School - 002379-Lounge



4/1/2024 - 600-52 - Heritage Middle School - 001667-North of Lounge-Storage Room



4/1/2024 - 600-53 - Heritage Middle School - 001647-Room 105




4/1/2024 - 600-54 - Heritage Middle School - 001646F-Room 107




4/1/2024 - 600-55 - Heritage Middle School - 001646B-Room 107




4/1/2024 - 600-56 - Heritage Middle School - 001641F-Room 108





4/1/2024 - 600-57 - Heritage Middle School - 001641B-Room 108




4/1/2024 - 600-58 - Heritage Middle School - 001642-Room 108



4/1/2024 - 600-59 - Heritage Middle School - 001643-Room 108




4/1/2024 - 600-60 - Heritage Middle School - 001644-Room 108



4/1/2024 - 600-61 - Heritage Middle School - 001645-Room 109




4/1/2024 - 600-62 - Heritage Middle School - 001637F-Room 110



4/1/2024 - 600-63 - Heritage Middle School - 001637B-Room 110



4/1/2024 - 600-64 - Heritage Middle School - 001638-Room 110




4/1/2024 - 600-65 - Heritage Middle School - 001639-Room 110



4/1/2024 - 600-66 - Heritage Middle School - 001640-Room 110



4/1/2024 - 600-67 - Heritage Middle School - 001631F-Room 111



4/1/2024 - 600-68 - Heritage Middle School - 001631B-Room 111




4/1/2024 - 600-69 - Heritage Middle School - 001632-Room 111



4/1/2024 - 600-70 - Heritage Middle School - 001633-Room 111



4/1/2024 - 600-71 - Heritage Middle School - 001634-Room 111



4/1/2024 - 600-72 - Heritage Middle School - 001635-Room 111





4/1/2024 - 600-73 - Heritage Middle School - 001636-Room 111




4/1/2024 - 600-74 - Heritage Middle School - 001648F-Room 112




4/1/2024 - 600-75 - Heritage Middle School - 001648B-Room 112



4/1/2024 - 600-76 - Heritage Middle School - 001653-By 118-Boys



4/1/2024 - 600-77 - Heritage Middle School - 001654-By 118-Boys



4/1/2024 - 600-78 - Heritage Middle School - 001655-By 118-Boys



4/1/2024 - 600-79 - Heritage Middle School - 001649-Room 120-Girls





4/1/2024 - 600-80 - Heritage Middle School - 001650-By 120-Girls



4/1/2024 - 600-81 - Heritage Middle School - 001651-By 120-Girls




4/1/2024 - 600-82 - Heritage Middle School - 002376B-By Rm 114




4/1/2024 - 600-83 - Heritage Middle School - 002376F-By Room 114




4/1/2024 - 600-84 - Heritage Middle School - 002377-By Room 114



4/1/2024 - 600-85 - Heritage Middle School - 001657-Gym-Northeast Corner



4/1/2024 - 600-86 - Heritage Middle School - 001658-Gym-Southwest Corner



4/1/2024 - 600-87 - Heritage Middle School - 001659-Concessions




4/1/2024 - 600-88 - Heritage Middle School - 001660-Gym-Concessions



4/1/2024 - 600-89 - Heritage Middle School - 001665-Room 117



4/1/2024 - 600-90 - Heritage Middle School - 003318-By Room 120



4/1/2024 - 600-91 - Heritage Middle School - 003319-By Room 120



4/1/2024 - 600-92 - Heritage Middle School - 001663-Copy Room-Boys



4/1/2024 - 600-93 - Heritage Middle School - 001664-Copy Room-Girls



4/1/2024 - 600-94 - Heritage Middle School - 001684-By 128-Girls




4/1/2024 - 600-95 - Heritage Middle School - 001685-By 128-Girls



4/1/2024 - 600-96 - Heritage Middle School - 001686-By 128-Girls



4/1/2024 - 600-97 - Heritage Middle School - 001687-By 128-Girls



4/1/2024 - 600-98 - Heritage Middle School - 001679-By 126-Boys




4/1/2024 - 600-99 - Heritage Middle School - 001680-By 126-Boys



4/1/2024 - 600-100 - Heritage Middle School - 001681-By 126-Boys



4/1/2024 - 600-101 - Heritage Middle School - 001682-By 126-Boys



4/1/2024 - 600-102 - Heritage Middle School - 002383-By Room 400




4/1/2024 - 600-103 - Heritage Middle School - 002384-By 400



4/1/2024 - 600-104 - Heritage Middle School - 001676-400 Hall



4/1/2024 - 600-105 - Heritage Middle School - 001677-Room 400



4/1/2024 - 600-106 - Heritage Middle School - 001675-400s Hall



4/1/2024 - 600-107 - Heritage Middle School - 002381-400 Hall-Boys



4/1/2024 - 600-108 - Heritage Middle School - 002382-400 Hall-Boys




4/1/2024 - 600-109 - Heritage Middle School - 001672-Nurse's Office




4/1/2024 - 600-110 - Heritage Middle School - 001671-Nurse's Office-Restroom



4/1/2024 - 600-111 - Heritage Middle School - 001670-Nurse's Office-Restroom



4/1/2024 - 600-112 - Heritage Middle School - 001601-Room 23



4/1/2024 - 600-113 - Heritage Middle School - 001602-Room 23



4/1/2024 - 600-114 - Heritage Middle School - 001603-Room 23



4/1/2024 - 600-115 - Heritage Middle School - 001604-Room 23



4/1/2024 - 600-116 - Heritage Middle School - 001605-Room 23



4/1/2024 - 600-117 - Heritage Middle School - 001606-Room 23



4/1/2024 - 600-118 - Heritage Middle School - 001598-Library-Work Room



4/1/2024 - 600-119 - Heritage Middle School - 001599-Library-Restroom



4/1/2024 - 600-120 - Heritage Middle School - 001597-Room 12-Wood Shop




4/1/2024 - 600-121 - Heritage Middle School - 001592-By Wood Shop-Girls



4/1/2024 - 600-122 - Heritage Middle School - 001593-By Wood Shop-Girls



4/1/2024 - 600-123 - Heritage Middle School - 001594-By Wood Shop-Boys



4/1/2024 - 600-124 - Heritage Middle School - 001595-By Wood Shop-Boys




4/1/2024 - 600-125 - Heritage Middle School - 002371-By Wood Shop




4/1/2024 - 600-126 - Heritage Middle School - 002372-By Wood Shop



4/1/2024 - 600-127 - Heritage Middle School - 001608-Locker Room-Girls



4/1/2024 - 600-128 - Heritage Middle School - 001609-Locker Room-Girls




4/1/2024 - 600-129 - Heritage Middle School - 001610-Locker Room-Girls



4/1/2024 - 600-130 - Heritage Middle School - 001611-Locker Room-Girls



4/1/2024 - 600-131 - Heritage Middle School - 001612-Locker Room-Girls



4/1/2024 - 600-132 - Heritage Middle School - 001613-Locker Room-Girls-Office




4/1/2024 - 600-133 - Heritage Middle School - 002373-Weight Room



4/1/2024 - 600-134 - Heritage Middle School - 001614-Weight Room



4/1/2024 - 600-135 - Heritage Middle School - 001616-Weight Room-Restroom




4/1/2024 - 600-136 - Heritage Middle School - 002374-Exercise Room




4/1/2024 - 600-137 - Heritage Middle School - 002375-Exercise Room



4/1/2024 - 600-138 - Heritage Middle School - 001617-Boys Lockers-Office



4/1/2024 - 600-139 - Heritage Middle School - 001618-Locker Room-Boys



4/1/2024 - 600-140 - Heritage Middle School - 001619-Locker Room-Boys



4/1/2024 - 600-141 - Heritage Middle School - 001620-Locker Room-Boys




4/1/2024 - 600-142 - Heritage Middle School - 001621-Locker Room-Boys




4/1/2024 - 600-143 - Heritage Middle School - 001581-By Lunch Room-Girls



4/1/2024 - 600-144 - Heritage Middle School - 001582-By Lunch Room-Girls




4/1/2024 - 600-145 - Heritage Middle School - 001583-By Lunch Room-Girls




4/1/2024 - 600-146 - Heritage Middle School - 001584-By Lunch Room-Girls



4/1/2024 - 600-147 - Heritage Middle School - 003317-By Lunch Room-Girls



4/1/2024 - 600-148 - Heritage Middle School - 001585-By Lunch Room-Boys



4/1/2024 - 600-149 - Heritage Middle School - 001586-By Lunch Room-Boys



4/1/2024 - 600-150 - Heritage Middle School - 001587-By Lunch Room-Boys



4/1/2024 - 600-151 - Heritage Middle School - 001588-By Lunch Room-Boys



4/1/2024 - 600-152 - Heritage Middle School - 003316-By Lunch Room-Boys




4/1/2024 - 600-153 - Heritage Middle School - 001590B-By Lunch Room




4/1/2024 - 600-154 - Heritage Middle School - 001590F-By Lunch Room




4/1/2024 - 600-155 - Heritage Middle School - 001590-By Lunch Room



4/1/2024 - 600-156 - Heritage Middle School - 000625-L-Kitchen



4/1/2024 - 600-157 - Heritage Middle School - 000468-L-Kitchen



4/1/2024 - 600-158 - Heritage Middle School - 001569-Kitchen



4/1/2024 - 600-159 - Heritage Middle School - 001570-Kitchen



4/1/2024 - 600-160 - Heritage Middle School - 001571-Kitchen



4/1/2024 - 600-161 - Heritage Middle School - 000815-L-Kitchen



4/1/2024 - 600-162 - Heritage Middle School - 001752-Kitchen



4/1/2024 - 600-163 - Heritage Middle School - 001573-Kitchen




4/1/2024 - 600-164 - Heritage Middle School - 001575-Kitchen



4/1/2024 - 600-165 - Heritage Middle School - 001576-Kitchen



4/1/2024 - 600-166 - Heritage Middle School - 001577-Kitchen



4/1/2024 - 600-167 - Heritage Middle School - 001578-Kitchen



4/1/2024 - 600-168 - Heritage Middle School - 001579-Kitchen



4/1/2024 - 600-169 - Heritage Middle School - 001580-Kitchen




4/1/2024 - 600-170 - Heritage Middle School - 004530-Kitchen



4/1/2024 - 600-171 - Heritage Middle School - 004531-Kitchen



4/1/2024 - 600-172 - Heritage Middle School - 004532-Kitchen



4/1/2024 - 600-173 - Heritage Middle School - 004533-Kitchen




4/1/2024 - 600-174 - Heritage Middle School - 001574-Kitchen-Restroom




4/30/2024 - 600-15 - Heritage Middle School - 001560B-Room 202




4/30/2024 - 600-38 - Heritage Middle School - 001550-By Room 225-Boys-Far Left

# Appendix E
# Source Identification Diagram

**ASP was provided sample locations by**
**Liberty School District**

Heritage Middle School - Third Floor
600 West Kansas
Liberty, MO 64068
P: 816.736.5380









*Map Design by: Curt Laven*
*Last Updated: 05/17/2023*

Heritage Middle School - Second Floor
600 West Kansas
Liberty, MO 64068
P: 816.736.5380




*Map Design by: Curt Laven*
*Last Updated: 05/17/2023*

Heritage Middle School -1st Floor
600 West Kansas
Liberty, MO 64068
P: 816.736.5380




W
S
N
E


*Map Design by: Curt Laven*

*Last Updated: 05/17/2023*

Liberty PUBLIC SCHOOLS
Empowering Excellence

# Heritage Middle School - Ground Floor

600 West Kansas
Liberty, MO 64068
P: 816.736.5380




W
S N
E

Map Design by: Curt Laven
Last Updated: 05/17/2023