

March 7, 2025

Zach Nannestad Douglas County School District 2812 N. Highway 85 Castle Rock, CO 80109

**Re:** Halftime Help Stadium

3270 Redstone Park Circle, Highlands Ranch, CO 80129

**Radon Sampling Assessment** 

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Halftime Help Statium, located at 3270 Redstone Park Circle, in Highlands Ranch, Colorado.

Nine (9) AirChek radon test kits were placed on March 3, 2025, and were retrieved on March 5, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Robert A. Woellner

Founder/Industrial Hygienist

NEHA: NRPP Certification #105324RT

CEO

Attachment: Laboratory Report

## Radon test result report for: HALFTIME HELP STADIUM MAIN

Kit #	Room Id	Started		Ended	pCi/L	Analyzed
11550921	LARGE CONCESSION NORTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.7	2025-03-06
11550914	LARGE CONCESSION SOUTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.7	2025-03-06
11550913	PRESS BOX	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.6	2025-03-06
11550919	SMALL CONCESSION NORTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	< 0.3	2025-03-06
11550911	SMALL CONCESSION SOUTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.8	2025-03-06
11550915	TICKET NORTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	< 0.3	2025-03-06
11550922	TICKET NORTH BLANK	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	< 0.3	2025-03-06
11550916	TICKET NORTH DUPLICATE	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.5	2025-03-06
11550912	TICKET SOUTH	2025-03-03 @	10:00 am	2025-03-05 @ 11:00 am	0.6	2025-03-06

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498