



March 7, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: East Transportation
17801 Plaza Drive, Parker, CO 80134
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at East Transportation, located at 17801 Plaza Drive, in Parker, Colorado.

Nine (9) AirChek radon test kits were placed on March 3, 2025, and were retrieved on March 5, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

March 6, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**EAST TRANSPORTATION
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11550925	AREA MANAGER	2025-03-03 @ 11:00 am	2025-03-05 @ 11:00 am	0.7	2025-03-06
11550918	BREAK ROOM	2025-03-03 @ 11:00 am	2025-03-05 @ 11:00 am	0.6	2025-03-06
11550926	CLASSROOM 1	2025-03-03 @ 11:00 am	2025-03-05 @ 12:00 pm	1.7	2025-03-06
11550928	CLASSROOM 1 BLANK	2025-03-03 @ 11:00 am	2025-03-05 @ 12:00 pm	< 0.3	2025-03-06
11550927	CLASSROOM 1 DUPLICATE	2025-03-03 @ 11:00 am	2025-03-05 @ 12:00 pm	1.6	2025-03-06
11550917	DISPATCH	2025-03-03 @ 11:00 am	2025-03-05 @ 11:00 am	1.0	2025-03-06
11550923	MANGER ADMIN	2025-03-03 @ 11:00 am	2025-03-05 @ 11:00 am	1.1	2025-03-06
11550920	SCHEDULER OFFICE	2025-03-03 @ 11:00 am	2025-03-05 @ 12:00 pm	0.9	2025-03-06
11550924	SUPERVISOR OFFICE	2025-03-03 @ 11:00 am	2025-03-05 @ 11:00 am	1.0	2025-03-06

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498