

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling: 6/13/2024	10/16/2024	11/8/2024	12/18/2024	2/4/2025
Samples Taken By: Keith Hull	Ken Retell	Ken Retell	Ken Retell	Ken Retell
Samples Taken By: Ken Retell	Mike Collins			

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Turnpike Elementary School
BLDG ADDRESS:	55 New Turnpike Rd. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information								
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Results from 6/13/2024 ug/L	Results from 10/16/2024 ug/L	Results from 11/08/2024 ug/L	Results from 12/18/2024 ug/L	Results from 2/4/2025 ug/L	Remediation
140	TES-02-DW-P-140	202	Water fountain			X	3.5					
141	TES-02-CF-P-141	206	Sink faucet			X	2.5					
142	TES-02-DW-P-142	206	Water fountain			X	2.4					
143	TES-02-CF-P-143	205	Sink faucet			X	7.8	6.5	7.6	6.8	<1.0	New Faucet, supply lines. Filter
144	TES-02-DW-P-144	205	Water fountain			X	2.9					
145	TES-01-FS-P-145	DO coffee Bar 1st floor	Sink faucet			X	<1.0					
146	TES-02-FS-P-146	Do Break rm	Sink faucet			X	<1.0					
147	TES-01-HC1-P-147	Main office entrance	Hose connection			X	3.5					
148	TES-01-HC2-P-148	Outside near 116	Hose connection			X	10.9	2.7				Flush
149	TES-01-HC3-P-149	Outside near 160	Hose connection			X	<1.0					
150	TES-01-HC4-P-150	Outside near 164	Hose connection			X	1.6					
151	TES-01-HC5-P-151	Outside near 165	Hose connection			X	6.2	<1.0				Flush
152	TES-01-HC6-P-152	Outside near 161	Hose connection			X	1.8					
153	TES-01-HC7-P-153	Outside near Gym corridor entrance	Hose connection			X	25.3	7.7	6.6			Signage in place
153A	TES-02-CF-P-153A	223	Sink faucet			X	15.8	<1.0				New source, Filter
153B	TES-02-DW-P-153B	223	Water fountain			X	13.4	2				New supply lines, filter, aerator. Tee for sink Faucet, filter

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy NY 12182
Client Rep:	Bob Schongar

Date of Sampling: 6/13/2024	10/16/2024	11/8/2024	12/18/2024	2/4/2025
Samples Taken By: Keith Hull	Ken Retell	Ken Retell	Ken Retell	Ken Retell
Samples Taken By: Ken Retell	Mike Collins			

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Turnpike Elementary School
BLDG ADDRESS:	55 New Turnpike Rd. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information								
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct . Date	First Draw	Result from 6/13/2024 ug/L	Result from 10/16/2024 ug/L	Result from 11/08/2024 ug/L	Result from 12/18/2024 ug/L	Result from 2/4/2025 ug/L	Remediation
69	TES-01-DW-P-69	Corridor by 110	Water fountain			X	2.3					
70	TES-01-FS-P-70	107 Faculty room	Sink faucet			X	1.5					
71	TES-01-CF-P-71	108	Sink faucet			X	2.1					
72	TES-01-DW-P-72	108	Water fountain			X	2.4					
73	TES-01-CF-P-73	109	Sink faucet			X	1.3					
74	TES-01-DW-P-74	109	Water fountain			X	<1.0					
75	TES-01-CF-P-75	110	Sink faucet			X	2.7					
76	TES-01-DW-P-76	110	Water fountain			X	9.9	<1.0				New- supply line, aerator, filter
77	TES-01-NS1-P-77	112	Sink faucet 1			X	5.5	7.9	<1.0			New aerator, Filter
78	TES-01-NS2-P-78	112	Sink faucet 2			X	7.1	3.6				New aerator, Flush
79	TES-01-CF-P-79	116	Sink faucet			X	2.1					
80	TES-01-DW-P-80	116	Water fountain			X	1.4					
81	TES-01-CF-P-81	117	Sink faucet			X	1.9					
82	TES-01-DW-P-82	117	Water fountain			X	<1.0					
83	TES-01-CF-P-83	118	Sink faucet			X	2.4					
84	TES-01-DW-P-84	118	Water fountain			X	1.2					
85	TES-01-CF-P-85	119	Sink faucet			X	1.4					
86	TES-01-DW-P-86	119	Water fountain			X	1.4					
87	TES-01-CF-P-87	120	Sink faucet			X	1.5					
88	TES-01-DW-P-88	120	Water fountain			X	1.5					
89	TES-01-CF-P-89	121	Sink faucet			X	1.4					
90	TES-01-DW-P-90	121	Water fountain			X	<1.0					
91	TES-01-CF-P-91	125	Sink faucet			X	<1.0					
92	TES-01-DW-P-92	125	Water fountain			X	<1.0					
93	TES-01-DW-P-93	Corridor near 130	Water fountain			X	5.5	3				Flush

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: Pace Analytical	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling: 6/13/2024	10/16/2024	11/8/2024	12/18/2024	2/4/2025
Samples Taken By: Keith Hull	Ken Retell	Ken Retell	Ken Retell	Ken Retell
Samples Taken By: Ken Retell	Mike Collins			

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Turnpike Elementary School
BLDG ADDRESS:	55 New Turnpike Rd. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information								
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct . Date	First Draw	Results from 6/13/2024 ug/L	Results from 10/16/2024 ug/L	Results from 11/08/2024 ug/L	Results from 12/18/2024 ug/L	Results from 2/4/2025 ug/L	Remediation
94	TES-01-CF-P-94	126	Sink faucet			X	4.1					
95	TES-01-DW-P-95	126	Water fountain			X	1.1					
96	TES-01-NF-P-96	Health suite	Sink faucet			X	<1.0					
97	TES-01-NF-P-97	Nurse exam Rm	Sink faucet			X	<1.0					
98	TES-01-DW-P-98	Corridor near 160	Water fountain			X	<1.0					
99	TES-01-DW-P-99	Corridor near 160	Bottle filler			X	<1.0					
100	TES-01-KF-P-100	Kitchen	Prep sink			X	<1.0					
101	TES-01-KF1-P-101	Kitchen	3 bay sink 1			X	1.7					
102	TES-01-KF2-P-102	Kitchen	3 bay sink 2			X	1.7					
103	TES-01-KF3-P-103	Kitchen	Hand sink				No Test Mixing Valve					
104	TES-01-DW-P-104	Cafeteria	Water fountain			X	<1.0					
105	TES-01-DW-P-105	Cafeteria	Bottle filler			X	<1.0					
106	TES-01-DW-P-106	Corridor by DO entrance	Water fountain			X	<1.0					
107	TES-01-DW-P-107	Corridor by DO entrance	Bottle filler			X	<1.0					
108	TES-01-DW-P-108	Old Cafeteria/OT PT	Water fountain			X	<1.0					
109	TES-02-DW-P-109	Corridor next to bathrooms by 232	Water fountain			X	36.6	<1.0				New filter, supply lines, Flush
110	TES-02-CF-P-110	231	Sink faucet			X	6.5	<1.0				New filter, supply lines, aerator, Tee in for fountain
111	TES-02-DW-P-111	231	Water fountain			X	7.4	<1.0				New supply source
112	TES-02-DW-P-112	230	Sink faucet			X	14.4	<1.0				New filter, supply lines, aerator
113	TES-02-DW-P-113	230	Water fountain			X	6.3	<1.0				New filter, supply lines, aerator
114	TES-02-DW-P-114	229	Sink faucet			X	9.8	<1.0				New filter, supply lines, aerator
115	TES-02-DW-P-115	229	Water fountain			X	11.8	<1.0				New supply source
116	TES-02-DW-P-116	Corridor outside 223	Water fountain			X	5.5	<1.0				Flush
117	TES-02-DW-P-117	Corridor near 262	Water fountain			X	<1.0					
118	TES-02-DW-P-118	Corridor near 262	Bottle filler			X	<1.0					

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling: 6/13/2024	10/16/2024	11/8/2024	12/18/2024	2/4/2025
Samples Taken By: Keith Hull	Ken Retell	Ken Retell	Ken Retell	Ken Retell
Samples Taken By: Ken Retell	Mike Collins			

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Turnpike Elementary School
BLDG ADDRESS:	55 New Turnpike Rd. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information								
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct . Date	First Draw	Results from 6/13/2024 ug/L	Results from 10/16/2024 ug/L	Results from 11/08/2024 ug/L	Results from 12/18/2024 ug/L	Results from 2/4/2025 ug/L	Remediation
119	TES-02-CF-P-119	228	Sink faucet			X	1					
120	TES-02-DW-P-120	228	Water fountain			X	5.3	17.6	<1.0			New filter, supply lines, Filter
121	TES-02-CF-P-121	227	Sink faucet			X	5.4	<1.0				New faucet, supply lines, tee for fountain
122	TES-02-DW-P-122	227	Water fountain			X	9	<1.0				New source
123	TES-02-CF-P-123	224	Sink faucet			X	3.6					
124	TES-02-DW-P-124	224	Water fountain			X	4.4					
125	TES-02-CF-P-125	226	Sink faucet			X	5.7	3.1				New faucet, supply lines. Flush
126	TES-02-DW-P-126	226	Water fountain			X	5.5	3.6				New supply lines, aerator. Flush
127	TES-02-CF-P-127	222	Sink faucet			X	10.1	<1.0				New source
128	TES-02-DW-P-128	222	Water fountain			X	5.4	<1.0				New filter, faucet, supply lines aerator
129	TES-02-CF-P-129	218	Sink faucet			X	6	5.2	5.9	<1.0		New faucet, supply lines. Filter
130	TES-02-DW-P-130	218	Water fountain			X	4.4					
131	TES-02-CF-P-131	221	Sink faucet			X	8.7	<1.0				New faucet, supply lines, filter, aerator. Tee for fountain
132	TES-02-DW-P-132	221	Water fountain			X	9.4	<1.0				New source
133	TES-02-CF-P-133	220	Sink faucet			X	17	<1.0				New filter, supply lines, tee for fountain
134	TES-02-DW-P-134	220	Water fountain			X	27.7	<1.0				New source
135	TES-02-DW-P-135	Corridor outside 219	Water fountain			X	3					
136	TES-02-DW-P-136	Corridor near center stairwell	Water fountain			X	3.3					
137	TES-02-CF-P-137	207	Sink faucet			X	4.5					
138	TES-02-DW-P-138	207	Water fountain			X	8	6	6.3	<1.0		New supply lines, aerator. Filter
139	TES-02-CF-P-139	202	Sink faucet			X	8.4	3.1				New source, faucet, supply line.

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	