



**Tamalpais Union High School District
Archie Williams Tennis Court Resurfacing
Project – BID #103**

Addendum No. 2

March 10, 2025

Owner:

Tamalpais Union High School District
395 Doherty Drive
Larkspur, CA 94939

This addendum shall supersede all previously issued specifications, addenda, and drawings wherein this addendum contradicts previously issued documents. All other conditions remain unchanged. The following changes, modifications, corrections, clarifications, and / or additions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and / or shown. This addendum must be acknowledged on the bid form.

Questions:

1. Regarding the foundations for the ball wall supports and basketball hoops. Do those need to be fully removed/excavated out? Or just cut and grind any steel below the surface?
Foundations for these structures can be cut and left abandoned below grade.
2. What is the drop-dead completion date for this project?
The project needs to be completed before August 15th.

3. There is a drain on the north side of the easternmost tennis court. Is this to remain?
That storm drain is existing to remain.
4. Are there any existing electrical boxes to be removed?
No, any electrical boxes that are currently existing are to remain. Any underground utility boxes should remain accessible.
5. What is the expected condition at the edge of the existing asphalt/ court surface if damaged?
Any damaged surface should be patched during the prep phase of construction.
6. There is a baseball foul pole within the court surface from the adjacent sports field. Is this to be removed?
No, the foul pole will remain.
7. Should the gate between the existing tennis courts and existing basketball court be removed?
Yes, the existing swing gate (approximately 6' tall by 10' wide) should be removed.
8. We respectfully submit for your consideration a request to approve products as an accepted substitute on Archie Williams Tennis Court Resurfacing Project:
 - i. Plexicushion Prestige
 - ii. Plexicushion plexicushionprestige2000
 - iii. Plexipave Color Card
 - iv. Plexicushion asphalt surfaces,
 - v. Plexicushion concrete surfacesAn alternate product is acceptable if it meets the requirements of the slipsheet overlay process for the repairs. The district will only accept products that meet the intent of using a slipsheet system for this project.

This Addendum consists of Two (2) pages.

End of Addendum No. 2

621 W Spain Street • Sonoma, CA 95476
707-933-0624 • Fax 707-996-8390