



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Palisades Park #9138 - Early Childhood Center, 270 1st Street, Palisades Park, NJ

**PAS Project ID :** P25-01632

**Matrix :** Drinking Water  
**Report Date :** 3/7/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-01632-01	PECC-B-S-01A	Lead	0.450 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:40	2/28/25 13:29
P25-01632-02	PECC-1-S-02A	Lead	0.690 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:45	2/28/25 13:34
P25-01632-03	PECC-1-S-03A	Lead	0.280 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:47	2/28/25 13:40
P25-01632-04	PECC-1-S-04A	Lead	0.810 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:50	2/28/25 13:55
P25-01632-05	PECC-1-S-05A	Lead	0.880 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:51	2/28/25 14:01
P25-01632-06	PECC-1-S-06A	Lead	0.850 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:54	2/28/25 14:06
P25-01632-07	PECC-1-S-07A	Lead	0.180 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:55	2/28/25 14:12
P25-01632-08	PECC-1-S-08A	Lead	0.300 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:56	2/28/25 14:17
P25-01632-09	PECC-1-S-09A	Lead	1.01	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 09:57	2/28/25 14:39
P25-01632-10	PECC-1-B-04A	Lead	0.220 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:02	2/28/25 14:45
P25-01632-11	PECC-1-B-03A	Lead	ND	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:03	2/28/25 15:00
P25-01632-12	PECC-1-S-11A	Lead	0.320 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:06	2/28/25 15:06
P25-01632-13	PECC-1-DS-01A	Lead	ND	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:07	2/28/25 15:11
P25-01632-14	PECC-1-S-10A	Lead	3.71	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:07	2/28/25 15:17
P25-01632-15	PECC-1-S-14A	Lead	4.60	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:08	2/28/25 15:22
P25-01632-16	PECC-1-S-13A	Lead	10.9	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:12	2/28/25 15:28
P25-01632-17	PECC-1-S-12A	Lead	17.4	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:12	2/28/25 15:34
P25-01632-18	PPECC-2-S-15A	Lead	0.430 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:21	2/28/25 15:39
P25-01632-19	PPECC-2-S-16A	Lead	0.350 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:22	2/28/25 16:22
P25-01632-20	PPECC-2-S-18A	Lead	1.09	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:22	2/28/25 16:28
P25-01632-21	PPECC-2-S-19A	Lead	0.640 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:24	2/28/25 16:33
P25-01632-22	PPECC-2-S-21A	Lead	0.270 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:27	2/28/25 16:39
P25-01632-23	PPECC-2-S-22A	Lead	4.06	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:28	2/28/25 16:44
P25-01632-24	PPECC-2-B-01A	Lead	ND	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:32	2/28/25 16:50
P25-01632-25	PPECC-2-B-02A	Lead	0.290 J	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:33	2/28/25 16:55
P25-01632-26	PPECC-2-18-FBA	Lead	ND	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:34	2/28/25 17:11
P25-01632-27	PECC-1-K-01A	Lead	3.32	ug/L	1.02	0.920	0.180	15.0 *	EPA 200.8	2/18/25 10:10	2/28/25 17:16

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result

\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Kelly Hogan - Quality Assurance Officer



part of  
**ALS Limited**

**CHAIN  
OF  
CUSTODY**

School Name: **Palisades Park #9138 - Early Childhood Center**  
 School Address: **270 1st Street, Palisades Park, NJ 07650**  
 Sampled By: *Caroline Poskrobko*  
 Print Name: **Caroline Poskrobko**  
 RESULTS TO: **labreports@gseconsultants.com**

Customer: **Garden State Environmental**  
 Address: **555 S. Broad St.**  
**Glen Rock, NJ 07452**  
 Phone: **(201) 652-1119 Office**

Sample ID Location	Date: 2/18/25 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
PECC-B-S-01A; Basement Faculty Room	9:40 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01632-01
PECC-1-S-02A; Room 111	9:45 AM	DW	Grab			1	250 ml Plastic	Lead	-02
PECC-1-S-03A; Room 110	9:47 AM	DW	Grab			1	250 ml Plastic	Lead	-03
PECC-1-S-04A; Nurse's	9:50 AM	DW	Grab			1	250 ml Plastic	Lead	-04
PECC-1-S-05A; Room 108	9:51 AM	DW	Grab			1	250 ml Plastic	Lead	-05
PECC-1-S-06A; Room 104	9:54 AM	DW	Grab			1	250 ml Plastic	Lead	-06
PECC-1-S-07A; Room 102	9:55 AM	DW	Grab			1	250 ml Plastic	Lead	-07
PECC-1-S-08A; Room 103	9:56 AM	DW	Grab			1	250 ml Plastic	Lead	-08
PECC-1-S-09A; Room 118	9:57 AM	DW	Grab			1	250 ml Plastic	Lead	-09
PECC-1-B-04A; Outside Kitchen Right	10:02 AM	DW	Grab			1	250 ml Plastic	Lead	-10
PECC-1-B-03A; Outside Kitchen Left	10:03 AM	DW	Grab			1	250 ml Plastic	Lead	-11
PECC-1-S-11A; Kitchen 3 COMP Right	10:06 AM	DW	Grab			1	250 ml Plastic	Lead	-12
PECC-1-DS-01A; Kitchen 3 COMP Right	10:07 AM	DW	Grab			1	250 ml Plastic	Lead	-13
PECC-1-S-10A; Kitchen 3 COMP Left	10:07 AM	DW	Grab			1	250 ml Plastic	Lead	-14
PECC-1-S-14A; Kitchen by Kettle	10:08 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01632-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std.  PDF Reduce  PDF Full  EDD

Date/Time Preserved with HNO3: *@ 1430 on 02/24*

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATION CODES:** 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	2/18/2025, 1:38 PM
Received:	<i>Peggy Hodges</i>	<i>[Signature]</i>	<i>YAL</i>	<i>2/21/25 1100</i>
Relinquished:	<i>[Signature]</i>	<i>[Signature]</i>	<i>YAL</i>	<i>2/21/25 1707</i>
Received:	<i>[Signature]</i>	<i>[Signature]</i>	<i>YAL</i>	<i>02/24/25 0900</i>
Relinquished:				
Received:				

Customer: Garden State Environmental  
 Address: 555 S. Broad St.  
 Glen Rock, NJ 07452  
 Phone: (201) 652-1119 Office

School Name: Palisades Park #9138 - Early Childhood Center  
 School Address: 270 1st Street, Palisades Park, NJ 07650  
 Sampled By: *Caroline Poskrobko*  
 Print Name: Caroline Poskrobko  
 RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date 2/18/2025 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
PECC-1-S-13A; Kitchen by Coffee Maker	10:12 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01632-16
PECC-1-S-12A; Kitchen Behind Serving Line	10:12 AM	DW	Grab			1	250 ml Plastic	Lead	-17
PPECC-2-S-15A; Room 219	10:21 AM	DW	Grab			1	250 ml Plastic	Lead	-18
PPECC-2-S-16A; Room 218	10:22 AM	DW	Grab			1	250 ml Plastic	Lead	-19
PPECC-2-S-18A; Room 216	10:22 AM	DW	Grab			1	250 ml Plastic	Lead	-20
PPECC-2-S-19A; Room 212	10:24 AM	DW	Grab			1	250 ml Plastic	Lead	-21
PPECC-2-S-21A; Room 209	10:27 AM	DW	Grab			1	250 ml Plastic	Lead	-22
PPECC-2-S-22A; Room 210	10:28 AM	DW	Grab			1	250 ml Plastic	Lead	-23
PPECC-2-B-01A; Across 203 Right	10:32 AM	DW	Grab			1	250 ml Plastic	Lead	-24
PPECC-2-B-02A; Across 203 Left	10:33 AM	DW	Grab			1	250 ml Plastic	Lead	-25
PPECC-2-18-FBA; Field Blank	10:34 AM	DW	Grab			1	250 ml Plastic	Lead	-26
PECC-1-K-01A; Kitchen Kettle	10:10AM	DW	Grab			1	250 ml Plastic	Lead	P25-01632-27
		DW	Grab			1	250 ml Plastic	Lead	<del>-28</del>
		DW	Grab			1	250 ml Plastic	Lead	<del>-29</del>
		DW	Grab			1	250 ml Plastic	Lead	<del>-30</del>

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO3: @ 1430 on 02/24

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATIVE CODES:** 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	2/18/2025; 1:38 PM
Received:	<i>[Signature]</i>	<i>[Signature]</i>	YAL	2/21/25 1100
Relinquished:	<i>[Signature]</i>	<i>[Signature]</i>	YAL	2/21/25 1700
Received:	LAYNE FENCEI	<i>[Signature]</i>	VAL	02/24/25 0900
Relinquished:				
Received:				