

ISB_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
B114 - Classroom Faucet	22434800-005CF	01/17/25	13.1
B114 - Drinking Fountain	22434800-006DW	01/17/25	8.99
A100 - Classroom Faucet	22434800-007CF	01/17/25	6.13
A100 - Drinking Fountain	22434800-008DW	01/17/25	3.22
A102 - Classroom Faucet	22434800-009CF	01/17/25	7.61
A102 - Drinking Fountain	22434800-010DW	01/17/25	2.33
Hall outside A102 - Drinking Fountain	22434800-011DW	01/17/25	0.292
A104 - Classroom Faucet	22434800-012CF	01/17/25	9.24
A104 - Drinking Fountain	22434800-013DW	01/17/25	3.95
A108 - Classroom Faucet	22434800-014CF	01/17/25	0.993
A108 - Drinking Fountain	22434800-015DW	01/17/25	3.43
Hall outside A110 - Drinking Fountain	22434800-016DW	01/17/25	0.426
A112 - Classroom Faucet	22434800-017CF	01/17/25	2.88
A112 - Drinking Fountain	22434800-018DW	01/17/25	4.94
A114 - Classroom Faucet	22434800-019CF	01/17/25	2.26
A114 - Drinking Fountain	22434800-020DW	01/17/25	3.14
Hall outside A114 - Drinking Fountain	22434800-021DW	01/17/25	0.426
B112 - Classroom Faucet	22434800-022CF	01/17/25	5.24
B112 - Drinking Fountain	22434800-023DW	01/17/25	6.89
Library Work Room - Staff/Office Faucet	22434800-024SF	01/17/25	1.56
B110 - Classroom Faucet	22434800-025CF	01/17/25	2.95
B110 - Drinking Fountain	22434800-026DW	01/17/25	0.960
B102 - Classroom Faucet	22434800-027CF	01/17/25	3.16
B102 - Drinking Fountain <i>(restricted access)</i>	22434800-028DW	01/17/25	24.1
B102 - Drinking Fountain <i>(post-mitigation)</i>	22434800-028DW25B	02/21/25	7.39
B108 - Classroom Faucet	22434800-029CF	01/17/25	2.92
B108 - Drinking Fountain	22434800-030DW	01/17/25	2.11
Hallway outside B102 - Drinking Fountain	22434800-031DW	01/17/25	0.797
B104 - Classroom Faucet	22434800-032CF	01/17/25	7.89
B104 - Drinking Fountain	22434800-033DW	01/17/25	4.41
B106 - Classroom Faucet	22434800-034CF	01/17/25	1.80
B106 - Drinking Fountain	22434800-035DW	01/17/25	1.75
Hallway Outside C112 - Water Bottle Filler	22434800-036WB	01/17/25	ND
Hallway Outside C112 - Drinking Fountain	22434800-037DW	01/17/25	ND
Hallway Outside C112 - Drinking Fountain	22434800-038DW	01/17/25	ND
C112 Staff - Staff/Office Faucet	22434800-039SF	01/17/25	0.508
Nurse - Nurse's Sink	22434800-040NS	01/17/25	1.21
Staff Work Room - Staff/Office Faucet	22434800-041SF	01/17/25	2.13
Kettle Filler - Kitchen/Food Prep	22434800-042KF	01/17/25	3.04
Back Left Prep - Kitchen/Food Prep	22434800-043KF	01/17/25	1.43
Central Prep - Kitchen/Food Prep	22434800-044KF	01/17/25	0.603
M112 - Classroom Faucet	22434800-045CF	01/17/25	7.40
M112 - Drinking Fountain	22434800-046DW	01/17/25	3.20
M110 - Classroom Faucet	22434800-047CF	01/17/25	5.81
M110 - Drinking Fountain	22434800-048DW	01/17/25	1.34

Hallway - Drinking Fountain	22434800-049DW	01/17/25	0.330
M104 - Classroom Faucet	22434800-050CF	01/17/25	8.26
M104 - Drinking Fountain	22434800-051DW	01/17/25	1.09
M100 - Classroom Faucet	22434800-052CF	01/17/25	5.01
M100 - Drinking Fountain	22434800-053DW	01/17/25	3.75