



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : STEAM Academy, 370 South 7th Street, Newark NJ 07103

PAS Project ID : P25-01022

Matrix : Drinking Water

Report Date : 2/11/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-01022-01	MEA-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:46	2/6/25 17:49
P25-01022-02	MEB-1-WC-01A	Lead	7.14	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:49	2/6/25 18:16
P25-01022-03	MEB-2-WC-02A	Lead	2.87	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:51	2/6/25 18:20
P25-01022-04	MEC-1-S-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:56	2/6/25 18:25
P25-01022-05	MEC-1-WC-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:58	2/6/25 18:29
P25-01022-06	MEC-1-WC-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 09:58	2/6/25 18:34
P25-01022-07	MEC-1-S-04A	Lead	1.65 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:00	2/6/25 18:38
P25-01022-08	ME-1-26-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:01	2/6/25 18:43

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer:	Garden State Environmental
Address:	555 S. Broad St.
	Glen Rock, NJ 07452
Phone:	(201) 652-1119 Office

School Name:	STEAM Academy
School Address:	370 South 7th Street, Newark, NJ 07103
Sampled By:	Frank Obando
Print Name:	Frank Obando
RESULTS TO:	labreports@gseconsultants.com

Sample ID Location	Date: / 26 / 25 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
1st Floor Hall MEA-1-WC-01A	9:46 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01022-01
Gym MEB-1-WC-01A	9:49 AM	DW	Grab			1	250 ml Plastic	Lead	-02
2nd Floor Hall MEB-2-WC-02A	9:51 AM	DW	Grab			1	250 ml Plastic	Lead	-03
Nurse's Office MEC-1-S-01A	9:56 AM	DW	Grab			1	250 ml Plastic	Lead	-04
Cafeteria (L) MEC-1-WC-03A	9:58 AM	DW	Grab			1	250 ml Plastic	Lead	-05
Cafeteria (R) MEC-1-WC-04A	9:58 AM	DW	Grab			1	250 ml Plastic	Lead	-06
Kitchen MEC-1-S-04A	10:00 AM	DW	Grab			1	250 ml Plastic	Lead	-07
Field Blank ME-1-26-FBA	10:01 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01022-08
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1	Deliverables:	PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO3:
		X				@ 1325 on 2/1

MATRIX CODES:	GW = Ground Water, WW = Waste Water, SW = Surface Water,	PRESERVATI VE CODES:	0 = Ice 1 = HCl
	DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):		2 = H2SO4, 3 = NaOH 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company	Date + Time
Relinquished:	Frank Obando	Frank Obando	GSE	1/28/25 + 3:45 PM
Received:	<i>Nancy Nieves</i>	<i>Nancy Nieves</i>	<i>YAL</i>	<i>1/31/25 9:49 AM</i>
Relinquished:	<i>Nancy Nieves</i>	<i>Nancy Nieves</i>	<i>YAL</i>	<i>1/31/25</i>
Received:	<i>Perry Hodge</i>	<i>Perry Hodge</i>	<i>YAL</i>	<i>1/31/25 14:30</i>
Relinquished:	<i>Perry Hodge</i>	<i>Perry Hodge</i>	<i>YAL</i>	<i>1/31/25 18:08</i>
Received:	<i>Lauren Palumbo</i>	<i>Lauren Palumbo</i>	<i>YAL</i>	<i>2/3/25 9:00</i>