



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Sankofa Academy, 88-108 Shipman Street, Newark NJ 07103

PAS Project ID : P25-01024

Matrix : Drinking Water

Report Date : 2/11/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-01024-01	MA-1-S-01A	Lead	3.48	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:15	2/6/25 19:52
P25-01024-02	MA-1-S-02A	Lead	1.25 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:16	2/6/25 19:56
P25-01024-03	MA-1-S-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:19	2/6/25 20:00
P25-01024-04	MA-2-S-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:21	2/6/25 20:05
P25-01024-05	MA-1-26-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/26/25 10:22	2/6/25 20:22

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer:	Garden State Environmental
Address:	555 S. Broad St.
	Glen Rock, NJ 07452
Phone:	(201) 652-1119 Office

School Name:	Sankofa Academy
School Address:	88-108 Shipman Street, Newark, NJ 07103
Sampled By:	Frank Obando
Print Name:	Frank Obando
RESULTS TO:	labreports@gseconsultants.com

Sample ID Location	Date / 26 / 25 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Container s	Glass or Plastic	Analysis	LAB ID
Room 108 MA-1-S-01A	10:15 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01024-01
Room 107 MA-1-S-02A	10:16 AM	DW	Grab			1	250 ml Plastic	Lead	02
All Purpose Room MA-1-S-03A	10:19 AM	DW	Grab			1	250 ml Plastic	Lead	03
2nd Floor Hall MA-2-S-04A	10:21 AM	DW	Grab			1	250 ml Plastic	Lead	04
Field Blank MA-1-26-FBA	10:22 AM	DW	Grab			1	250 ml Plastic	Lead	P25-01024-05
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1	Deliverables:	PDF Std.	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO ₃ :	@1315 on 02/05
-------------	---------------	-------------	---------------	-------------	-----	---	----------------

MATRIX CODES:	GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):
--------------------------	--

PRESERVATI VE CODES:	0 = Ice 1 = HCl 2 = H ₂ SO ₄ 3 = NaOH 4 = HNO ₃ 5 = Other
-------------------------------------	--

	Print Name:	Signature:	Company	Date + Time
Relinquished:	Frank Obando	Frank Obando	GSE	1/28/25 + 4:00 PM
Received:	Maed N. Nicks	Maed N. Nicks	YAL	1/31/25 9:49 AM
Relinquished:	Maed N. Nicks	Maed N. Nicks	YAL	1/31/25
Received:	Perry Hodges	Perry Hodges	YAL	1/31/25 18:30
Relinquished:	Perry Hodges	Perry Hodges	YAL	1/31/25 18:08
Received:	Lauren Palumbo	Lauren Palumbo	YAL	2/2/25 9:00