

Lead in Water Testing Results
South Washington County Schools
Armstrong Elementary – 8855 Inwood Ave S, Cottage Grove, MN 55016

On December 27th, 2024, Armstrong Elementary School's drinking water was tested for the concentration of lead.

All water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Cafeteria	Bottle Filler	< 1.00
Cafeteria	Fountain	< 1.00
Hallway, outside B1	Bottle Filler	< 1.00
Hallway, outside B1	Fountain	< 1.00
Hallway, outside G1	Bottle Filler	< 1.00
Hallway, outside G1	Fountain	< 1.00
Kitchen	Sprayer	1.75
Staff Dining	Sink	< 1.00

The following water source tested above the action level of 5 parts-per-billion (ppb) for the concentration of lead. This source will not be used for consumption without remediation and re-testing. Actions taken are listed below.

LOCATION	SOURCE	RESULT (ppb)	ACTION
Room B1	Sink	5.31	Identified and labeled as handwashing only
Kitchen	Sink	5.78	Identified and labeled as handwashing only
Health Office	Sink	5.34	Identified and labeled as handwashing only
Office Workroom	Hot/Cold Dispenser	6.37	Discontinued use until vendor replaces