Lead in Water Testing Results
South Washington County Schools
Cottage Grove Elementary – 7447 65th Street S, Cottage Grove, MN 55016

On December 27, 2024, Cottage Grove Elementary School's drinking water was tested for the concentration of lead.

All water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Gym A	Fountain	< 1.00
Gym B	Fountain	< 1.00
Gym C	Fountain	< 1.00
Hallway, outside gym	Bottle Filler	< 1.00
Hallway, outside gym	Fountain	< 1.00
Commons, southwest	Fountain	< 1.00
Commons, southwest	Bottle Filler	< 1.00
Commons, southeast	Fountain	< 1.00
Commons, southeast	Bottle Filler	< 1.00
Northwest bathroom	Fountain, girls	< 1.00
Northwest bathroom	Fountain, boys	< 1.00
Northeast bathroom	Fountain, girls	< 1.00
Northeast bathroom	Fountain, boys	< 1.00
Kitchen	Sink, left	< 1.00
Kitchen	Sink, right	1.61
Kitchen	Sprayer	4.41
Health Office	Sink	< 1.00
Staff Dining	Sink	< 1.00
Media Center Workroom	Culligan Dispenser	< 1.00
E104	Sink	< 1.00
D142	Sink	< 1.00