Lead in Water Testing Results
South Washington County Schools
Nuevas Fronteras Spanish Immersion School – 1020 Third Street, St Paul Park, MN 55071

On December 27, 2024, Nuevas Fronteras Spanish Immersion School's drinking water was tested for the concentration of lead.

All water sources tested less than our action level of 5 parts-per-billion (ppb), no action will be taken to these water sources at this time.

LOCATION	SOURCE	RESULT (ppb)
Cafeteria	Bottle Filler	< 1.00
Cafeteria	Fountain	< 1.00
Hallway by Room 140	Bottle Filler	< 1.00
Hallway by Room 144	Bottle Filler	< 1.00
Hallway by Room 148	Fountain, left	< 1.00
Hallway by Room 148	Fountain, right	< 1.00
Hallway by Room 148	Bottle Filler	< 1.00
Hallway by Room 170	Fountain	4.24
Hallway by Room 174	Bottle Filler	< 1.00
Hallway by Room 174	Fountain, left	< 1.00
Hallway by Room 174	Fountain, right	< 1.00
Outside gym, left	Bottle Filler	< 1.00
Outside gym, left	Fountain, left	< 1.00
Outside gym, left	Fountain, right	< 1.00
Outside gym, right	Bottle Filler	< 1.00
Outside gym, right	Fountain, right	< 1.00
Outside gym, right	Fountain, left	< 1.00
Hallway by Office	Bottle Filler	< 1.00
Kitchen	Sink	< 1.00
Kitchen	Sprayer	< 1.00
Health Office	Sink	< 1.00
Staff Dining	Sink	< 1.00