

Asbestos Hazard Emergency Response Act Three-Year Asbestos Re-Inspection and Management Plan Update

for
Timothy Dwight Elementary School

For Compliance with
State of Connecticut Department of Public Health
Asbestos-Containing Materials in Schools Regulation
(Sections 19a - 333-1 through 19a - 333-13)
and
EPA Asbestos Hazard Emergency Response Act
(Title 40 CFR, Part 763, Subpart E)

Fairfield Public Schools
Fairfield, Connecticut

February 2025

February 8, 2025



59 Elm Street, Suite 500
New Haven, CT 06510
203.374.3748
www.fando.com

Mr. Angelus Papageorge
Executive Director of Operations
Fairfield Public Schools
501 Kings Highway East, Suite 210
Fairfield, CT 06825

RE: Three-Year AHERA Asbestos Re-Inspection and Management Plan Update
Re-Inspection Date: October 3, 2024
Fairfield Public Schools - Timothy Dwight Elementary School
1600 Redding Road, Fairfield, CT.
Fuss & O'Neill Project No. 20190061.A70

Dear Mr. Papageorge:

Enclosed is the three-year Asbestos Hazard Emergency Response Act (AHERA) Asbestos Re-Inspection and Asbestos Management Plan (AMP) Update report prepared by Fuss & O'Neill, Inc. at the Timothy Dwight Elementary School located at 1600 Redding Road, Fairfield, Connecticut (the "Site"). The inspection was performed for Fairfield Public Schools (the "Client"). This report is an important document that must be kept on file at the school as well as at a central location where the AMPs are maintained.

If you should have any questions regarding this report, please do not hesitate to contact me. Thank you for this opportunity to have served your environmental needs.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Kathleen C. Pane'.

Kathleen C. Pane
Associate | Department Manager

Enclosure

Table of Contents

**Asbestos Hazard Emergency Response Act
Three-Year Re-Inspection and Management Plan Update
Timothy Dwight Elementary School**

1	Introduction.....	1
1.1	Background.....	1
1.2	Local Education Agency (LEA) Responsibilities	1
1.3	Accreditation	2
2	Building and Mechanical System Description	3
3	Three Year Re-Inspection	3
3.1	Re-Inspection Procedures.....	3
4	Re-Inspection Report	3
4.1	Review of Existing Records	3
4.2	Re-Inspection Summary	3
4.3	Newly Identified or Re-sampled ACBM Materials	8
4.4	Physical Assessment of ACBM	10
5	Management Plan Update.....	10
5.1	Recommended Response Actions	10
5.2	Periodic Surveillance	11
5.3	Preventive Measures.....	12
5.4	Abatement (Removal) Cost Estimates	12
6	EPA Accreditation Requirements	12

Appendices

End of Report

APPENDIX A	EXISTING RECORDS CHECKLIST
APPENDIX B	RE-INSPECTION FORM 1A
APPENDIX C	RE-INSPECTION FORM 1B
APPENDIX D	RE-INSPECTION FORM 2
APPENDIX E	SAMPLE 6-MONTH PERIODIC SURVEILLANCE FORM
APPENDIX F	PREVENTIVE MEASURES
APPENDIX G	ASBESTOS INSPECTOR AND MANAGEMENT PLANNER STATE LICENSES AND EPA ACCREDITATIONS

1 Introduction

1.1 Background

The Clean Air Act required the United States Environmental Protection Agency (EPA) to develop standards to address the potential health risks associated with adverse effects of asbestos exposure as an indoor contaminant. In October 1986, the EPA promulgated the Asbestos Hazard Emergency Response Act (AHERA) located at Title 40 CFR, Part 763, Subpart E.

The AHERA regulations required that local education agencies (LEAs) conduct inspections of each school building that they lease, own, or otherwise use as a school building to identify friable (easily crumbled or crushed to powder by hand pressure) and non-friable asbestos-containing building materials (ACBM) locations. The original inspections were required to have been completed prior to October 12, 1988.

AHERA also requires that any building leased or acquired on or after October 12, 1988, that is to be used as a school building shall be inspected for friable and non-friable ACBM prior to use as a school building. In the event of an emergency use of a building that has not been inspected for ACBM, the building shall be inspected within 30 days after commencement of such use.

The regulatory requirements remain in effect for private or public-school systems, a church-affiliated school of any denomination, a school dedicated to the education of children with special needs, or a charter school. In the State of Connecticut, the Department of Public Health (CTDPH) is responsible for AHERA regulation enforcement.

1.2 Local Education Agency (LEA) Responsibilities

The LEA is responsible for compliance with the AHERA regulation. The following responsibilities must be followed:

1. The LEA must designate a person to ensure that all of the AHERA requirements are properly implemented. The Designated Person must receive adequate training to perform their duties.
2. The LEA must ensure that the asbestos management plans (AMPs) are maintained in a central location, as well as at each facility, and such plans and records are available for inspection or review at all times.
3. The LEA must inform all workers, building occupants or their legal representative in writing at least once per school year about asbestos-related activities, and the availability of the AHERA AMPs for the school buildings.
4. The LEA must ensure proper accreditations for all persons who perform asbestos inspections, asbestos re-inspections, develop/update AMPs, develop response actions, and perform required response actions including operations and maintenance (O&M) activities that may disturb asbestos.
5. The LEA must provide training for all custodial and maintenance staff who regularly perform building maintenance where ACBM are present. The training must be provided upon initial hire, as well as annual updates.

6. The LEA must provide information (disclosure) to any workers who may perform work and may come into contact with asbestos in school buildings where ACBM or presumed ACBM are present.
7. The LEA must ensure that known ACBM or presumed ACBM are provided with warning labels in routine maintenance areas.
8. The LEA must ensure that periodic surveillance is performed at least once every six months, after AMP implementation, in all school buildings that it leases, owns, or otherwise uses that contains ACBM or presumed ACBM.
9. The LEA must ensure that once every three years, after an AMP is implemented, a Re-Inspection is performed at each school building that it leases owns or otherwise uses that contains ACBM or presumed ACBM.

Refer to above-mentioned regulation for full requirements and responsibilities.

1.3 Accreditation

A. Local Education Agency (LEA):

LEA: Fairfield Public Schools
Address: 501 Kings Highway East, Suite 210
Fairfield, CT
Phone: (203) 255-8235
Fax: (203) 255-8246

B. Designated Person:

Designated Person: Mr. Angelus Papageorge
Address: 501 Kings Highway East, Suite 210
Fairfield, CT
Phone: (203) 255-8352
Fax: (203) 255-8246

C. Asbestos Consultant:

Firm: Fuss & O'Neill, Inc.
Address: 59 Elm Street, Suite 500
New Haven, CT 06510
Phone: (203) 374-3748
Fax: (860) 533-5143

D. Asbestos Inspector:

Inspector: Sandra Guzman
CTDPH License #: 000335

Expiration Date: 8/31/2025

E. Asbestos Management Planner:

Planner: Kathleen C Pane
CTDPH License #: 000200
Expiration: 04/30/2025

2 Building and Mechanical System Description

The original Timothy Dwight Elementary School is a one-story building constructed in 1962. A building addition was reportedly constructed in 1969. At one time, portable classrooms were located at the school. The portable classrooms were removed and/or demolished after the 2017 re-inspection conducted by AMC Environmental, LLC. The building is heated with oil-fired hot water, in addition with rooftop heating, ventilation, and air conditioning (HVAC) units.

3 Three Year Re-Inspection

3.1 Re-Inspection Procedures

This three-year asbestos re-inspection was conducted in accordance with EPA requirements of the AHERA regulation, Title 40 CFR, Part 763, Section 763.85 (b).

On October 3, 2024, Fuss & O'Neill, Inc. (Fuss & O'Neill) representatives Ms. Sandra Guzman performed the re-inspection.

A. During the re-inspection, Fuss & O'Neill conducted the following required tasks:

1. A visual re-inspection and reassessment of all known friable or assumed ACBM.
2. A visual re-inspection of ACBM that was previously considered non-friable to determine if the present condition of the material has become friable.
3. Identification and assessment of any newly-identified homogeneous area that contains friable ACBM since the last inspection or re-inspection.

4 Re-Inspection Report

4.1 Review of Existing Records

An important part of this AHERA re-inspection involved researching prior documentation that is required to be present at the school, as well as at the central recordkeeping location where AMPs are stored.

Please see *Appendix A* for the checklist for existing records.

4.2 Re-Inspection Summary

The on-site portion of the re-inspection was documented on forms modeled after examples provided by the EPA and reviewed with the CTDPH. The first form, **Re-Inspection Form 1A**, identifies previous inspection data gathered during the initial AHERA inspection and subsequent re-inspection (see *Appendix B*). This form is useful to reference response actions (if any), which have been performed since the last inspection, as well as identifies the last known conditions of ACBM in the building. It additionally provides the inspector a “quick glance” reference when performing the re-inspection.

The second EPA form, **Re-Inspection Form 1B**, is used to list all known or assumed asbestos-containing materials that were previously unidentified (See *Appendix C*). It also lists the ACBM in areas newly-acquired by the school for student use either permanently or temporarily.

The third EPA form, **Re-Inspection Form 2**, was used to provide information and justification regarding re-assessment of the ACBM (see *Appendix D*). This form also provides response action recommendations, including a tentative schedule for completing response actions that recommend removal or repair.

No bulk samples were collected during this re-inspection. Bulk samples were last collected during the [insert date/year here] re-inspection.

Using EPA protocol and criteria, the following materials existing in Timothy Dwight Elementary School at the time of this three-year re-inspection have been determined and/or assumed to be **ACBM**. Please refer to the above-mentioned Re-Inspection Forms for specific locations of the materials.

**Table 1
Asbestos-Containing Building Materials**

Material	Location	Reference	Asbestos Content
Duct Breeching Insulation	Boiler Room	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Pipe Fitting Insulation	Boiler Room, Garage, Yard Storage Room, Gym, Gym Storage Rooms, Air Handling Room by Stage, Storage Closets by Library Work Room, Above Ceilings Throughout, Bathrooms, Gym Office	AMC 2017 AHERA Re-Inspection, Fuss & O'Neill May 2015 Inspection	20% Chrysotile
Black Tar Compound associated with Pipe Insulation	Bathrooms (behind fixed walls)	Fuss & O'Neill July 2017 Inspection	3% Chrysotile
Electrical Insulation	All Purpose Room	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Cementitious Panels (assumed to be behind Metal Panels)	Exterior Soffits	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Dark Brown 9" x 9" Floor Tile & associated Mastic	Storage by Room 14, Storage Room between Rooms 15 & 17, Stage Stairs Landings, Stage Storages, Book Room Storage, and Storage across Kitchen	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed

Material	Location	Reference	Asbestos Content
Brown with White 9" x 9" Floor Tile & associated Mastic	Rooms 1, 2, 7 – 9, 12 & 13, Gym Office, and Room 2 IT Storage	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Green 12" x 12" Floor Tile, Tan 12" x 12" Floor Tile (Along Perimeter) & associated Adhesive (9" x 9" Floor Tile assumed to be underneath 12" x 12" Tile)	All Purpose Room	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Light Blue 12"x12" Floor Tile & associated Adhesive (9"x9" Floor Tile assumed to be underneath 12"x12" Tile)	Upper-Level Corridors, Room 14, Reading Room, Custodial Office	AMC 2017 AHERA Re-Inspection	Unknown/ Assumed
Blue with Specks 12"x12" Floor Tile & associated Adhesive	Rooms 3 – 6, 10, 11, 15- 21, Faculty Room, Room 133, Corridor by Rooms 12 & 13, Room 33, Custodial Room by Room 33, Room 26, Main Office, Resource Room by Room 12, Storage by Room 13, and Psychologist Office	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Blue grayish 12" x 12" Floor Tile & associated Adhesive	Hallways by Rooms 1-13, and Media Center and Cafeteria and by Rooms 14-30	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Pink 12" x 12" Floor Tile & associated Adhesive	OT/PT Room, Art Room, and Room 7 by Exterior Door	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Beige 12" x 12" Floor Tile & associated Adhesive	Nurse's Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Brown and Light Tan 12" x 12" Floor Tile & associated Adhesive	Room 9 by Door and Sink Area	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Gray and Light Gray 12" x 12" Floor Tile & associated Adhesive	Main Office and Supplies Closet, Hallway by Rooms 14-30	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Carpet Adhesive	Media Center	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Gray Rubber Stair Tread Adhesive	Stairs	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed

Material	Location	Reference	Asbestos Content
Grout and Thin Set Associated with 2" Green Ceramic Floor Tiles	Kitchen, Kitchen Bathroom & Kitchen Storage	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Grout and Thin Set Associated with 2" Tan/Brown/Light Brown Ceramic Floor Tiles	Water Fountain, Boys and Girls Bathrooms across Room 1, Men and Women Bathrooms, Rooms 15, and 17 Bathroom and Sink Area	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Grout and Thin Set associated with 1" Yellow, Beige/Gray Ceramic Floor Tiles	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Grout and Thin Set associated with 1" x 2" Cream Ceramic Floor Tiles	Nurses Office Bathroom, Rooms 14, 16 and 18 Bathrooms	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Grout and Thin Set Associated with 1' x 2' Stone Tiles	Vestibule	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
4" Black Cove Base Molding and Adhesive	Lower-Level Corridors, Custodial Room, Stage Storages, Media Center Office, Nurse's Office, Rooms 1-21, Psychologist Office, Math Resource, Gym, and Gym Storages	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
4" Brown Cove Base Molding and Adhesive	Room 2 (Storage), 13, Storage Across Kitchen, Art Storage, and Media Center	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
4" Tan Cove Base Molding and Adhesive	Art Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Gray 4" and 6" Cove Base Molding and Adhesive	Main Office	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
6" Black Cove Base Molding and Adhesive	Vestibule and Hallway by Main Office	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
6" Blue Cove Base Molding and Adhesive	All Purpose Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
4" x 6" Ceramic Cove Base Grout and Adhesive	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed

Material	Location	Reference	Asbestos Content
Wall Panel Adhesive (painted multiple with colors)	Hallway near to Classroom 19, Main Office, Media Center, and Rooms 1- 9, 11-13, and 16	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
4" x 4" Ceramic Wall Tile Grout and Adhesive	Men and Women Bathrooms	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Lighting Insulations	Stage	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Black Chalkboard Adhesive	Room 19	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Black Glue Daubs associated with White Board	Material assumed to be present in Classrooms 1 - 9, 11 - 21	Fuss & O'Neill November 2018 Inspection	2% Chrysotile
Gray Countertop/Adhesive	Room 10 and Faculty Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Beige Sink Undercoat	Media Center Office, Nurse's Office, Rooms 1-11, and 15-18	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Gray Sink Undercoat	Room 10 and Faculty Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Black Sink Undercoat	Rooms 12, 13, 19, 20, 21 and Art Room	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed
Black Slate Windowsill and associated Grout	Classroom and Offices Interior of Exterior Windows	Fuss & O'Neill 2024 3-Year AHERA Re-Inspection	Assumed

Using the EPA protocol, samples of the following suspect materials were collected and analyzed. The analytical results indicated that these materials are **non-ACBM**:

**Table 2
Non-Asbestos-Containing Building Materials (Previous Re-Inspections)**

Material	Location	Reference
White Drain Bowl Insulation	Room 12	Fuss & O'Neill May 2015 Inspection
Gray 1' x 1' Suspended Ceiling Tiles	Art Storage, Telephone Room	Fuss & O'Neill May 2015 Inspection
White 2' x 2' Suspended Ceiling Tile – Pin Hole Style	Art Storage, Telephone Room, Hallways	Fuss & O'Neill May 2015 Inspection
White 2' x 4' Suspended Ceiling Tile	Classrooms 12, 14, 20; Throughout Building	Fuss & O'Neill May 2015 Inspection

Material	Location	Reference
White 2' x 4' Suspended Gypsum Ceiling Panel	Kitchen	Fuss & O'Neill May 2015 Inspection
Yellow Mineral Wool Wrap around Fiberglass Pipe Insulation	Hallways	Fuss & O'Neill May 2015 Inspection
Brown/Black Paper Backing on Fiberglass Pipe Insulation	Hallways	Fuss & O'Neill May 2015 Inspection
Plaster Ceiling	Boiler Room	AMC 2017 AHERA Re-Inspection
1' x 2' Ceiling Tiles	*Throughout Building	AMC 2017 AHERA Re-Inspection
Gypsum Wallboard & associated Joint Compound	*Throughout Building	AMC 2017 AHERA Re-Inspection
Cove Base (unknown color) & associated Adhesive	*Throughout Building	AMC 2017 AHERA Re-Inspection
Silver Paper Backing on Fiberglass Pipe Insulation	Classrooms 19 and 20, Bathrooms	Fuss & O'Neill July 2017 Inspection
White Cloth Wrap on Fiberglass Pipe Insulation	Bathrooms	Fuss & O'Neill July 2017 Inspection
Burlap Layer on Wallboard	Room 10	Fuss & O'Neill November 2018 Inspection
Wallboard	Room 10	Fuss & O'Neill November 2018 Inspection

* Additional sampling may be required to satisfy AHERA sampling protocols based on building construction vintage.

Ms. Kathleen C Pane reviewed the information obtained during this re-inspection. Ms. Pane is an EPA-accredited and CTDPH-licensed Asbestos Inspector/Management Planner.

4.3 Newly Identified or Re-sampled ACM Materials

The following newly identified suspect ACM have been identified in the building:

- Duct breaching insulation,
- Pipe fitting insulation,
- Black tar compound associated with pipe insulation,
- Electrical insulation,
- Cementitious panels (assumed to be behind metal panels),
- Dark brown 9" x 9" floor tile & associated mastic,
- Brown with white 9" x 9" floor tile & associated mastic,
- Green 12" x 12" floor tile, tan 12" x 12" floor tile (along perimeter) & associated adhesive (9" x 9" floor tile assumed to be underneath 12" x 12" tile),
- Light blue 12"x12" floor tile & associated adhesive (9"x9" floor tile assumed to be underneath 12"x12" tile)
- Blue with specks 12"x12" floor tile & associated adhesive,

- Blue grayish 12" x 12" floor tile & associated adhesive,
- Pink 12" x 12" floor tile & associated adhesive,
- Beige 12" x 12" floor tile & associated adhesive,
- Brown and light tan 12" x 12" floor tile & associated adhesive
- Gray and light gray 12" x 12" floor tile & associated adhesive,
- Carpet adhesive,
- Gray rubber stair tread adhesive,
- Grout and thin set associated with 2" green ceramic floor tiles,
- Grout and thin set associated with 2" tan/brown/light brown ceramic floor tiles,
- Grout and thin set associated with 1" yellow, beige/gray ceramic floor tiles,
- Grout and thin set associated with 1" x 2" cream ceramic floor tiles,
- Grout and thin set associated with 1' x 2' stone tiles,
- 4" black cove base molding and adhesive,
- 4" brown cove base molding and adhesive,
- 4" tan cove base molding and adhesive,
- Gray 4" and 6" cove base molding and adhesive,
- 6" black cove base molding and adhesive,
- 6" blue cove base molding and adhesive,
- 4" x 6" ceramic cove base grout and adhesive,
- Wall panel adhesive (painted multiple with colors),
- 4" x 4" ceramic wall tile grout and adhesive,
- Lighting insulations,
- Black chalkboard adhesive,
- Black glue daubs associated with white board,
- Gray countertop/adhesive,
- Beige sink undercoat,
- Gray sink undercoat,
- Black sink undercoat, and
- Black slate windowsill and associated grout.

These materials must be assumed to contain asbestos until laboratory analysis determine otherwise. These materials have been added to Table 1 as assumed ACM.

AHERA regulations pertain to interior identified or assumed ACM and limited exterior ACM. AHERA regulations do include ACM located on exterior porticos, covered walkways, and mechanical equipment used to condition interior building air.

Any suspect material encountered during renovation/demolition/maintenance activities that is not specifically identified in the AMP as a non-ACM should be assumed to contain asbestos unless sample results indicate otherwise.

Additional Information:

- Asbestos-containing floor tile and associated mastics may exist below non-moveable objects such as cabinets, platforms, sheetrock walls, lockers, etc.;
- Samples of exterior building materials not covered under AHERA, such as caulking and glazing

compounds, roofing materials and materials behind exterior walls and panels should be collected and analyzed to determine asbestos content prior to performing activities that would disturb them;

- Asbestos-containing vapor barriers and waterproofing materials may exist beneath wood floors, behind walls, exterior below ground surface foundations, etc.; and
- Subsurface cementitious pipe (i.e., asbestos cement pipe).

4.4 Physical Assessment of ACBM

During the inspection, suspect ACBM were separated into three EPA categories. These categories are thermal system insulation (TSI), surfacing ACBM, and miscellaneous ACBM. TSI includes all materials used to prevent heat loss or gain or water condensation on mechanical systems. Examples of TSI are pipe and fitting insulations, boiler insulation, and duct insulation. Surfacing ACBM is commonly used for fireproofing, decorative, and acoustical applications. Miscellaneous materials include all ACBM not listed in TSI or surfacing, such as sheet flooring, vinyl asbestos flooring, ceiling tiles, and construction mastics/adhesives.

Finally, ACBM were quantified in linear and/or square feet, depending on the nature of the material.

The ACBM identified during the inspection and still remaining in the school were re-assessed using the CTDPH and AHERA guidelines for assessment of ACBM. The following assessment categories are listed:

1. Damaged or significantly damaged TSI ACBM
2. Damaged friable surfacing ACBM
3. Significantly damaged friable surfacing ACBM
4. Damaged or significantly damaged friable miscellaneous ACBM
5. ACBM with potential for damage
6. ACBM with potential for significant damage
7. Any remaining friable ACBM or friable suspected ACBM

Material locations, assessments, and recommended response actions are listed in the Re-Inspection forms.

5 Management Plan Update

5.1 Recommended Response Actions

Based on the inspection report, physical walk-through inspection, and existing ACBM conditions, the following response actions are recommended:

1. Removal - Not Applicable
2. Repair - Not Applicable
3. Enclosure - Not Applicable
4. Encapsulation - Not Applicable
5. Operations and Maintenance (O & M) - All remaining ACBM

It should be noted that only ACBM with assessments of 1 or 2 are recommended for removal or repair. The remaining ACBM should be included in the O & M Program. The condition of these ACBM will be monitored until all of the ACBM have been completely removed from the building. A successful O & M Program includes the following elements:

- A. Cleaning: All areas of the school where friable ACBM or assumed friable ACBM are present should be cleaned at least once after completion of the initial inspection. Additional cleaning may be necessary if the Management Planner makes a written recommendation indicating the methods and frequency of such cleaning.

- B. O & M Activities: The LEA shall ensure that the procedures described below are followed to protect building occupants from O & M activities that may disturb known or assumed ACBM:
 - 1. Restrict entry into the area either by physically isolating or by scheduling.
 - 2. Post asbestos warning signs to prevent entry by unauthorized persons.
 - 3. Deactivate or temporarily shut off or divert the air-handling system to the area.
 - 4. Use proper work practices and engineering controls, such as wet methods, protective clothing, High Efficiency Particulate Air (HEPA) vacuums, mini-enclosures/glove bags, etc. to inhibit fiber migration.
 - 5. Place asbestos debris and other contaminated materials into a sealed, leak-tight container for disposal.

- C. Minor Fiber Release Episode: The LEA shall ensure that the procedures described below are followed in the event of a minor fiber release episode (i.e., disturbance of less than or equal to 3 linear/square feet of friable ACBM):
 - 1. Saturate the debris using wet method.
 - 2. Place the debris in a sealed, leak-tight container and clean the area.
 - 3. Repair the area of damaged ACBM with materials such as asbestos-free spackling, plaster or insulation or seal with an encapsulant.

- D. Major Fiber Release Episode: The LEA shall ensure that the procedures described below are followed in the event of a major fiber release episode (i.e., disturbance of greater than 3 linear/square feet of friable ACBM):
 - 1. Restrict entry into the area and post asbestos warning signs.
 - 2. Deactivate or temporarily shut off or divert the air handling system from the area to prevent fiber migration.
 - 3. The response action for any major fiber release episode must be prepared by EPA-accredited Asbestos Project Designers and conducted by EPA-accredited personnel.
 - 4. The LEA shall notify the CTDPH of any major fiber release episode within twenty-four hours of its occurrence and, if necessary, provide written notification as required by applicable federal and/or state regulations.

5.2 Periodic Surveillance

At least once every six months after an AMP is implemented, the LEA will conduct periodic surveillance in the school that contains ACBM or assumed ACBM. The person conducting periodic surveillance will visually inspect all areas in the school where ACBM have been identified in the AMP, record the date of surveillance, their name, any changes in the ACBM condition and submit the record to the LEA Designated Person for inclusion in the AMP.

Please see *Appendix E* for the sample Periodic Surveillance Form that may be used for conducting periodic surveillance.

5.3 Preventive Measures

The LEA shall institute appropriate preventive measures to eliminate the reasonable likelihood that ACBM will become damaged, deteriorated, or delaminated.

Please see *Appendix F* for preventive measures designed for various types of ACBM that may exist in the school.

5.4 Abatement (Removal) Cost Estimates

No damaged ACBM or Assumed ACBM was identified during this re-inspection, therefore, estimated cost for abatement and/or repair have not been included.

6 EPA Accreditation Requirements

The EPA accreditations and the CTDPH Asbestos licenses for Ms. Sandra Guzman and Ms. Kathleen C. Pane are provided in *Appendix G*.

Appendix A

Existing Records Checklist

Existing Records Checklist

Local Education Agency (LEA): Fairfield Public School
501 Kings Highway East, Suite 210
Fairfield, CT 06825

School Building: Timothy Dwight Elementary School - 1600 Redding Road, Fairfield, CT

The following documentation is required to be present in both the LEA’s office, as well as in a centralized location in the school administrative office. The information included in this checklist will be verified to be present and complete as part of three-year Re-Inspection.

DOCUMENTATION		LOCATION	
		School	LEA Office
1	Original AHERA Operations and Maintenance Plan/Inspection Report	Yes	Yes
2	Three Year Re-Inspection (First and All Subsequent Inspections)	Yes*	Yes*
3	Parents and Teachers Notifications (Annually Since Last Re-Inspection)	No	No
4	Designated Person Identification and Proper Training (Person Must Be Named and Have Appropriate Training)	Yes	Yes
5	Designated Person Periodic Surveillance (Once Every Six Months)	Yes*	Yes*
6	Maintenance Staff Awareness Training Records	Yes	Yes
7	Outside Vendor Awareness Notification	No	No
8	Asbestos Warning Signs and Labels (Required Posting in Boiler Rooms and Mechanical Spaces Only)	Yes	NA
9	Response Action Records (Includes Any Abatement Conducted Since Last 3-Year Re-Inspection)	Yes*	Yes*

Comments: Items marked “No” indicate not present/available at the time of this inspection. 2021 Three-year inspection, 6 Months periodic surveillance from 2021 to April 2024, and environmental testing reports from 2012 to July 2024 are posted in: [Search Results - Fairfield Public Schools \(fairfieldschools.org\)](https://www.fairfieldschools.org)

Inspector (LEA Office): Sandra Guzman Date: 10/04/2024

Inspector (School): Sandra Guzman Date: 10/02/2024

Appendix B

Re-Inspection Form 1A

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School
 Address: 1600 Redding Road, Fairfield, CT

Date(s) of Original Inspection: 1999

Date(s) of Subsequent Re-Inspections: 2002, 2005, 2001, 2017, 2021, 2024

Homogeneous Material			Material Category	Friability	Assessment Category (1-7)	Recorded Locations	Response Actions Taken/Renovations/Other Comments
Sample Number	Asbestos Content	Material Description					
N/A	Assumed	Duct Breeching Insulation	TSI	F	5	Boiler Room	Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance
0507JB-01A, 20170724R T-01A	20% Chrysotile	Pipe Fitting Insulation	TSI	F	5	Boiler Room, Garage, Yard Storage Room, Gym, Gym Storage Rooms, Air Handling Room by Stage, Storage Closets by Library Work Room, Above Ceilings Throughout, Bathrooms, Gym Office	Maintain Under O & M Plan
20170724R T-02A	3% Chrysotile	Black Tar Compound associated with Pipe Insulation	Misc.	NF	5	Bathrooms (behind fixed walls)	Maintain Under O & M Plan
N/A	Assumed	Electrical Insulation	TSI	F	5	All Purpose Room	<i>Not Regulated by AHERA, For Informational Purposes Only.</i> Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance
N/A	Assumed	Cementitious Panels (assumed to be behind Metal Panels)	Misc.	NF	5	Exterior Soffits	<i>Not Regulated by AHERA, For Informational Purposes Only.</i> Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School
 Address: 1600 Redding Road, Fairfield, CT

Date(s) of Original Inspection: 1999

Date(s) of Subsequent Re-Inspections: 2002, 2005, 2001, 2017, 2021, 2024

Homogeneous Material			Material Category	Friability	Assessment Category (1-7)	Recorded Locations	Response Actions Taken/Renovations/Other Comments
Sample Number	Asbestos Content	Material Description					
N/A	Assumed	Dark Brown 9" x 9" Floor Tile & associated Mastic	Misc.	NF	5	Storage by Room 14, Storage Room between Rooms 15 & 17, Stage Stairs Landings, Stage Storages, Book Room Storage, and Storage across Kitchen	Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance
N/A	Assumed	Brown with White 9" x 9" Floor Tile & associated Mastic	Misc.	NF	5	Rooms 1, 2, 7 – 9, 12 & 13, Gym Office, and Room 2 IT Storage	One Floor Tile Cracked adjacent to the Door of Room 8. Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance
N/A	Assumed	Green 12" x 12" Floor Tile, Tan 12" x 12" Floor Tile (Along Perimeter) & associated Adhesive (9" x 9" Floor Tile assumed to be underneath 12" x 12" Tile)	Misc.	NF	5	All Purpose Room	Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance
N/A	Assumed	Light Blue 12"x12" Floor Tile & associated Adhesive (9"x9" Floor Tile assumed to be underneath 12"x12" Tile)	Misc.	NF	5	Upper-Level Corridors, Room 14, Reading Room, Custodial Office	Maintain Under O & M Plan Recommend sampling to determine asbestos content prior to disturbance

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School Date(s) of Original Inspection: 1999
 Address: 1600 Redding Road, Fairfield, CT Date(s) of Subsequent Re-Inspections: 2002, 2005, 2001, 2017, 2021, 2024

Homogeneous Material			Material Category	Friability	Assessment Category (1-7)	Recorded Locations	Response Actions Taken/Renovations/Other Comments
Sample Number	Asbestos Content	Material Description					
110218EM M-01A	2% Chrysotile	Black Glue Daubs associated with White Board	Misc.	NF	5	Material assumed to be present in Classrooms 1 - 9, 11 - 21	Maintain Under O & M Plan

Information abstracted by: Sandra Guzman Date: October 3, 2024

Material Category: TSI = Thermal System Insulation, Surf. = Surfacing, Misc. = Miscellaneous

Friability: F = Friable, NF = Non-Friable

AHERA Assessment Categories: 1 = Damaged or significantly damaged TSI ACBM; 2 = Damaged friable surfacing ACBM; 3 = Significantly damaged friable surfacing ACBM; 4 = Damaged or significantly damaged friable miscellaneous ACBM; 5 = ACBM with potential for damage; 6 = ACBM with potential for significant damage; 7 = Any remaining friable ACBM or friable suspected ACBM

Appendix C

Re-Inspection Form 1B

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School

Date(s) of Original AHERA Inspection: 1999

Address: 1600 Redding Road, Fairfield, CT

Date(s) of Re-Inspection: October 3, 2024

Homogeneous Material		Asbestos Content (%)	Material Category	Estimated Quantity (SF/LF)	Friability	Assessment Category (1-7)	Recorded Locations of Material for Each Assessment Category
Sample Number	Material Description						
N/A	Blue with Specks 12"x12" Floor Tile & associated Adhesive	Assumed	Misc.	12,800 SF	NF	5	Rooms 3 – 6, 10, 11, 15- 21, Faculty Room, Room 133, Corridor by Rooms 12 & 13, Room 33, Custodial Room by Room 33, Room 26, Main Office, Resource Room by Room 12, Storage by Room 13, and Psychologist Office
N/A	Blue grayish 12" x 12" Floor Tile & associated Adhesive	Assumed	Misc.	2,000 SF	NF	5	Hallways by Rooms 1-13, and Media Center and Cafeteria and by Rooms 14-30
N/A	Pink 12" x 12" Floor Tile & associated Adhesive	Assumed	Misc.	500 SF	NF	5	OT/PT Room, Art Room, and Room 7 by Exterior Door
N/A	Beige 12" x 12" Floor Tile & associated Adhesive	Assumed	Misc.	400 SF	NF	5	Nurse's Room
N/A	Brown and Light Tan 12" x 12" Floor Tile & associated Adhesive	Assumed	Misc.	60 SF	NF	5	Room 9 by Door and Sink Area
N/A	Gray and Light Gray 12" x 12" Floor Tile & associated Adhesive	Assumed	Misc.	2,100 SF	NF	5	Main Office and Supplies Closet, Hallway by Rooms 14-30
N/A	Carpet Adhesive	Assumed	Misc.	1,600 SF	NF	5	Media Center
N/A	Gray Rubber Stair Tread Adhesive	Assumed	Misc.	120 SF	NF	5	Stairs
N/A	Grout and Thin Set Associated with 2" Green Ceramic Floor Tiles	Assumed	Misc.	1,200 SF	NF	5	Kitchen, Kitchen Bathroom & Kitchen Storage
N/A	Grout and Thin Set Associated with 2" Tan/Brown/Light Brown Ceramic Floor Tiles	Assumed	Misc.	1,000 SF	NF	5	Water Fountain, Boys and Girls Bathrooms across Room 1, Men and Women Bathrooms, Rooms 15, and 17 Bathroom & Sink Area

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School

Date(s) of Original AHERA Inspection: 1999

Address: 1600 Redding Road, Fairfield, CT

Date(s) of Re-Inspection: October 3, 2024

Homogeneous Material		Asbestos Content (%)	Material Category	Estimated Quantity (SF/LF)	Friability	Assessment Category (1-7)	Recorded Locations of Material for Each Assessment Category
Sample Number	Material Description						
N/A	Grout and Thin Set associated with 1" Yellow, Beige/Gray Ceramic Floor Tiles	Assumed	Misc.	1,000 SF	NF	5	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets
N/A	Grout and Thin Set associated with 1" x 2" Cream Ceramic Floor Tiles	Assumed	Misc.	120 SF	NF	5	Nurses Office Bathroom, Rooms 14, 16 and 18 Bathrooms
N/A	Grout and Thin Set Associated with 1' x 2' Stone Tiles	Assumed	Misc.	400 SF	NF	5	Vestibule
N/A	4" Black Cove Base Molding and Adhesive	Assumed	Misc.	1,200 LF	NF	5	Lower-Level Corridors, Custodial Room, Stage Storages, Media Center Office, Nurse's Office, Rooms 1-21, Psychologist Office, Math Resource, Gym, and Gym Storages
N/A	4" Brown Cove Base Molding and Adhesive	Assumed	Misc.	400 LF	NF	5	Room 2 (Storage), 13, Storage Across Kitchen, Art Storage, and Media Center
N/A	4" Tan Cove Base Molding and Adhesive	Assumed	Misc.	240 LF	NF	5	Art Room
N/A	Gray 4" and 6" Cove Base Molding and Adhesive	Assumed	Misc.	120 LF	NF	5	Main Office
N/A	6" Black Cove Base Molding and Adhesive	Assumed	Misc.	350 LF	NF	5	Vestibule and Hallway by Main Office
N/A	6" Blue Cove Base Molding and Adhesive	Assumed	Misc.	240 LF	NF	5	All Purpose Room
N/A	4" x 6" Ceramic Cove Base Grout and Adhesive	Assumed	Misc.	280 LF	NF	5	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets

School: Timothy Dwight Elementary School Building: Timothy Dwight Elementary School

Date(s) of Original AHERA Inspection: 1999

Address: 1600 Redding Road, Fairfield, CT

Date(s) of Re-Inspection: October 3, 2024

Homogeneous Material		Asbestos Content (%)	Material Category	Estimated Quantity (SF/LF)	Friability	Assessment Category (1-7)	Recorded Locations of Material for Each Assessment Category
Sample Number	Material Description						
N/A	Wall Panel Adhesive (painted multiple with colors)	Assumed	Misc.	6,000 SF	NF	5	Hallway near to Classroom 19, Main Office, Media Center, and Rooms 1- 9, 11-13, and 16
N/A	4" x 4" Ceramic Wall Tile Grout and Adhesive	Assumed	Misc.	600 SF	NF	5	Men and Women Bathrooms
N/A	Lighting Insulations	Assumed	Misc.	Unquantified	NF	5	Stage
N/A	Black Chalkboard Adhesive	Assumed	Misc.	64 SF	NF	5	Room 19
N/A	Gray Countertop/Adhesive	Assumed	Misc.	120 SF	NF	5	Room 10 and Faculty Room
N/A	Beige Sink Undercoat	Assumed	Misc.	14 EA	NF	5	Media Center Office, Nurse's Office, Rooms 1-11, and 15-18
N/A	Gray Sink Undercoat	Assumed	Misc.	2 EA	NF	5	Room 10 and Faculty Room
N/A	Black Sink Undercoat	Assumed	Misc.	6 EA	NF	5	Rooms 12, 13, 19, 20, 21 and Art Room
N/A	Black Slate Windowsill and associated Grout	Assumed	Misc.	600 SF	NF	5	Classroom and Offices Interior of Exterior Windows

Inspected by: Sandra Guzman

Date: October 3, 2024

Material Category: TSI = Thermal System Insulation, S = Surfacing, M = Miscellaneous LF = Linear Feet; SF = Square Feet

Friability: F = Friable, NF = Non-Friable

AHERA Assessment Categories: 1 = Damaged or significantly damaged TSI ACBM; 2 = Damaged friable surfacing ACBM; 3 = Significantly damaged friable surfacing ACBM; 4 = Damaged or significantly damaged friable miscellaneous ACBM; 5 = ACBM with potential for damage; 6 = ACBM with potential for significant damage; 7 = Any remaining friable ACBM or friable suspected ACBM

Appendix D



Re-Inspection Form 2

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Duct Breeching Insulation



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Boiler Room	F	6 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024



Homogeneous Material: Pipe Fitting Insulation Sample ID Number: 0507JB-01A, 20170724RT-01A

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Boiler Room, Garage, Yard Storage Room, Gym, Gym Storage Rooms, Air Handling Room by Stage, Storage Closets by Library Work Room, Above Ceilings Throughout, Bathrooms, Gym Office	F	Unknown	5	ACBM with Potential for Damage	Maintain Under O & M Plan.	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024



Homogeneous Material: Black Tar Compound associated with Pipe Insulation Sample ID Number: 20170724RT-02A

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Bathrooms (behind fixed walls)	NF	Unknown	5	ACBM with Potential for Damage	Maintain Under O & M Plan.	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Electrical Insulation Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
All Purpose Room	F	100 LF	5	ACBM with Potential for Damage	Not Regulated by AHERA, For Informational Purposes Only. Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Cementitious Panels (assumed to be behind Metal Panels)

Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Exterior Soffits	NF	Unknown	5	ACBM with Potential for Damage	Not Regulated by AHERA, For Informational Purposes Only. Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Dark Brown 9" x 9" Floor Tile & associated Mastic Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Storage by Room 14, Storage Room between Rooms 15 & 17, Stage Stairs Landings, Stage Storages, Book Room Storage, and Storage across Kitchen	NF	3,500 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Brown with White 9" x 9" Floor Tile & associated Mastic



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Rooms 1, 2, 7 – 9, 12 & 13, Gym Office, and Room 2 IT Storage	NF	1,500 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Green 12" x 12" Floor Tile, Tan 12" x 12" Floor Tile (Along Perimeter) & associated Adhesive (9" x 9" Floor Tile assumed to be underneath 12" x 12" Tile) Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
All Purpose Room	NF	3,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Light Blue 12"x12" Floor Tile & associated Adhesive (9"x9" Floor Tile assumed to be underneath 12"x12" Tile)

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Upper-Level Corridors, Room 14, Reading Room, Custodial Office	NF	3,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Blue with Specks 12"x12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Rooms 3 – 6, 10, 11, 15- 21, Faculty Room, Room 133, Corridor by Rooms 12 & 13, Room 33, Custodial Room by Room 33, Room 26, Main Office, Resource Room by Room 12, Storage by Room 13, and Psychologist Office	NF	12,800 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Blue grayish 12" x 12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Hallways by Rooms 1-13, and Media Center and Cafeteria and by Rooms 14-30	NF	2,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Pink 12" x 12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
OT/PT Room, Art Room, and Room 7 by Exterior Door	NF	500 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Beige 12" x 12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Nurse's Room	NF	400 SF	5	ACBM with Potential for Damage	2 Tiles Cracked at Door to main Office. Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Brown and Light Tan 12" x 12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Room 9 by Door and Sink Area	NF	60 SF	5	ACBM with Potential for Damage	One Tile Missing by Exterior Door. Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Gray and Light Gray 12" x 12" Floor Tile & associated Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Main Office and Supplies Closet, Hallway by Rooms 14-30	NF	2,100 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Carpet Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Media Center	NF	1,600 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Gray Rubber Stair Tread Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Stairs	NF	120 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Grout and Thin Set Associated with 2" Green Ceramic Floor Tiles

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Kitchen, Kitchen Bathroom & Kitchen Storage	NF	1,200 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Grout and Thin Set Associated with 2" Tan/Brown/Light Brown Ceramic Floor Tiles

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Water Fountain, Boys and Girls Bathrooms across Room 1, Men and Women Bathrooms, Rooms 15, and 17 Bathroom and Sink Area	NF	1,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C Pane</u>	
Inspector Signature: 					Management Planner Signature: 	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Grout and Thin Set associated with 1" Yellow, Beige/Gray Ceramic Floor Tiles

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets	NF	1,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Grout and Thin Set associated with 1" x 2" Cream Ceramic Floor Tiles



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Nurses Office Bathroom, Rooms 14, 16 and 18 Bathrooms	NF	120 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Grout and Thin Set Associated with 1' x 2' Stone Tiles Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Vestibule	NF	400 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 4" Black Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Lower-Level Corridors, Custodial Room, Stage Storages, Media Center Office, Nurse's Office, Rooms 1-21, Psychologist Office, Math Resource, Gym, and Gym Storages	NF	1,200 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 4" Brown Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Room 2 (Storage), 13, Storage Across Kitchen, Art Storage, and Media Center	NF	400 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: 					Management Planner Signature: 	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 4" Tan Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Art Room	NF	240 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Gray 4" and 6" Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Main Office	NF	120 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: 					Management Planner Signature: 	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 6" Black Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Vestibule and Hallway by Main Office	NF	350 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 6" Blue Cove Base Molding and Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
All Purpose Room	NF	240 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 4" x 6" Ceramic Cove Base Grout and Adhesive



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets	NF	280 LF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Wall Panel Adhesive (painted multiple with colors) Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Hallway near to Classroom 19, Main Office, Media Center, and Rooms 1- 9, 11-13, and 16	NF	6,000 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: 4" x 4" Ceramic Wall Tile Grout and Adhesive



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Men and Women Bathrooms	NF	600 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Lighting Insulations Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Stage	NF	Unquantified	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Black Chalkboard Adhesive

Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Room 19	NF	64 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Black Glue Daubs associated with White Board

Sample ID Number: 110218EMM-01A



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Material assumed to be present in Classrooms 1 - 9, 11 - 21	NF	1,300 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan.	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u>					Management Planner Name: <u>Kathleen C. Pane</u>	
Inspector Signature: <u></u>					Management Planner Signature: <u></u>	
Accreditation #/State: <u>000335/CT</u>					Accreditation #/State: <u>000200/CT</u>	
Expiration Date: <u>08/31/2025</u>					Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____						
Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Gray Countertop/Adhesive



Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Room 10 and Faculty Room	NF	120 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024



Homogeneous Material: Beige Sink Undercoat Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Media Center Office, Nurse's Office, Rooms 1-11, and 15-18	NF	14 EA	5	ACBM with Potential for Damage	<i>Not Regulated By AHERA; For Informational Purposes Only.</i> Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024



Homogeneous Material: Gray Sink Undercoat Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Room 10 and Faculty Room	NF	2 EA	5	ACBM with Potential for Damage	<p><i>Not Regulated By AHERA; For Informational Purposes Only.</i></p> <p>Maintain Under O & M Plan.</p> <p>Recommend sampling prior to disturbance</p>	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Black Sink Undercoat Sample ID Number: Assumed



ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Rooms 12, 13, 19, 20, 21 and Art Room	NF	6 EA	5	ACBM with Potential for Damage	<i>Not Regulated By AHERA; For Informational Purposes Only.</i> Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

School: Timothy Dwight Elementary School

Date of Re-Inspection: October 3, 2024

Homogeneous Material: Black Slate Windowsill and associated Grout

Sample ID Number: Assumed

ACBM RE-INSPECTION FINDINGS					MANAGEMENT PLANNER RECOMMENDATIONS	
ACBM Location(s) by Assessment Category	Friability	Estimated Quantity	Assessment Category	Physical Description	Recommended Response Action(s)	Date Action Completed
Classroom and Offices Interior of Exterior Windows	NF	600 SF	5	ACBM with Potential for Damage	Maintain Under O & M Plan. Recommend sampling prior to disturbance	Ongoing
Were additional samples of this ACBM collected? (No)					Date of Management Planner Review: _____	
Inspector's Name: <u>Sandra Guzman</u> Inspector Signature: <u></u> Accreditation #/State: <u>000335/CT</u> Expiration Date: <u>08/31/2025</u>					Management Planner Name: <u>Kathleen C. Pane</u> Management Planner Signature: <u></u> Accreditation #/State: <u>000200/CT</u> Expiration Date: <u>04/30/2025</u>	
I, the LEA's Designated Person, have read and understood the recommendations made above: _____ Date: _____						

Appendix E

Sample 6-Month Periodic Surveillance Form

Sample 6- Month Periodic Surveillance Form

Local Education Agency (LEA): Fairfield Public Schools

Facility Address: Timothy Dwight Elementary School - 1600 Redding Road, Fairfield, CT

Date of Surveillance: _____

ACBM Damage Report

Asbestos-Containing Building Material	Location	Previous Condition	Present Condition	Change in Condition (Yes/No)	Estimated Damaged Quantity	Comments
Duct Breaching Insulation	Boiler Room					
Pipe Fitting Insulation	Boiler Room, Garage, Yard Storage Room, Gym, Gym Storage Rooms, Air Handling Room by Stage, Storage Closets by Library Work Room, Above Ceilings Throughout, Bathrooms, Gym Office					
Black Tar Compound associated with Pipe Insulation	Bathrooms (behind fixed walls)					
Electrical Insulation	All Purpose Room					
Cementitious Panels (assumed to be behind Metal Panels)	Exterior Soffits					
Dark Brown 9" x 9" Floor Tile & associated Mastic	Storage by Room 14, Storage Room between Rooms 15 & 17, Stage Stairs Landings, Stage Storages, Book Room Storage, and Storage across Kitchen					
Brown with White 9" x 9" Floor Tile & associated Mastic	Rooms 1, 2, 7 – 9, 12 & 13, Gym Office, and Room 2 IT Storage					
Green 12" x 12" Floor Tile, Tan 12" x 12" Floor Tile (Along Perimeter) & associated Adhesive (9" x 9" Floor Tile	All Purpose Room					

Asbestos-Containing Building Material	Location	Previous Condition	Present Condition	Change in Condition (Yes/No)	Estimated Damaged Quantity	Comments
assumed to be underneath 12" x 12" Tile)						
Light Blue 12"x12" Floor Tile & associated Adhesive (9"x9" Floor Tile assumed to be underneath 12"x12" Tile)	Upper-Level Corridors, Room 14, Reading Room, Custodial Office					
Blue with Specks 12"x12" Floor Tile & associated Adhesive	Rooms 3 – 6, 10, 11, 15- 21, Faculty Room, Room 133, Corridor by Rooms 12 & 13, Room 33, Custodial Room by Room 33, Room 26, Main Office, Resource Room by Room 12, Storage by Room 13, and Psychologist Office					
Blue grayish 12" x 12" Floor Tile & associated Adhesive	Hallways by Rooms 1-13, and Media Center and Cafeteria and by Rooms 14-30					
Pink 12" x 12" Floor Tile & associated Adhesive	OT/PT Room, Art Room, and Room 7 by Exterior Door					
Beige 12" x 12" Floor Tile & associated Adhesive	Nurse's Room					
Brown and Light Tan 12" x 12" Floor Tile & associated Adhesive	Room 9 by Door and Sink Area					
Gray and Light Gray 12" x 12" Floor Tile & associated Adhesive	Main Office and Supplies Closet, Hallway by Rooms 14-30					
Carpet Adhesive	Media Center					
Gray Rubber Stair Tread Adhesive	Stairs					
Grout and Thin Set Associated with 2" Green Ceramic Floor Tiles	Kitchen, Kitchen Bathroom & Kitchen Storage					

Asbestos-Containing Building Material	Location	Previous Condition	Present Condition	Change in Condition (Yes/No)	Estimated Damaged Quantity	Comments
Grout and Thin Set Associated with 2" Tan/Brown/Light Brown Ceramic Floor Tiles	Water Fountain, Boys and Girls Bathrooms across Room 1, Men and Women Bathrooms, Rooms 15, and 17 Bathroom and Sink Area					
Grout and Thin Set associated with 1" Yellow, Beige/Gray Ceramic Floor Tiles	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets					
Grout and Thin Set associated with 1" x 2" Cream Ceramic Floor Tiles	Nurses Office Bathroom, Rooms 14, 16 and 18 Bathrooms					
Grout and Thin Set Associated with 1' x 2' Stone Tiles	Vestibule					
4" Black Cove Base Molding and Adhesive	Lower-Level Corridors, Custodial Room, Stage Storages, Media Center Office, Nurse's Office, Rooms 1-21, Psychologist Office, Math Resource, Gym, and Gym Storages					
4" Brown Cove Base Molding and Adhesive	Room 2 (Storage), 13, Storage Across Kitchen, Art Storage, and Media Center					
4" Tan Cove Base Molding and Adhesive	Art Room					
Gray 4" and 6" Cove Base Molding and Adhesive	Main Office					
6" Black Cove Base Molding and Adhesive	Vestibule and Hallway by Main Office					
6" Blue Cove Base Molding and Adhesive	All Purpose Room					
4" x 6" Ceramic Cove Base Grout and Adhesive	Rooms 19, 20 and 21 Bathrooms, Storage, Bathrooms and Vestibule by Gym and Custodial Closets					

Asbestos-Containing Building Material	Location	Previous Condition	Present Condition	Change in Condition (Yes/No)	Estimated Damaged Quantity	Comments
Wall Panel Adhesive (painted multiple with colors)	Hallway near to Classroom 19, Main Office, Media Center, and Rooms 1- 9, 11-13, and 16					
4" x 4" Ceramic Wall Tile Grout and Adhesive	Men and Women Bathrooms					
Lighting Insulations	Stage					
Black Chalkboard Adhesive	Room 19					
Black Glue Daubs associated with White Board	Material assumed to be present in Classrooms 1 - 9, 11 - 21					
Gray Countertop/Adhesive	Room 10 and Faculty Room					
Beige Sink Undercoat	Media Center Office, Nurse's Office, Rooms 1-11, and 15-18					<i>Not Regulated By AHERA; For Informational Purposes Only.</i>
Gray Sink Undercoat	Room 10 and Faculty Room					<i>Not Regulated By AHERA; For Informational Purposes Only.</i>
Black Sink Undercoat	Rooms 12, 13, 19, 20, 21 and Art Room					<i>Not Regulated By AHERA; For Informational Purposes Only.</i>
Black Slate Windowsill and associated Grout	Classroom and Offices Interior of Exterior Windows					<i>Not Regulated By AHERA; For Informational Purposes Only.</i>

Conditions: D = Damaged; F = Fair; G = Good; IA = Inaccessible; N/A = Not Applicable; SD = Significant Damage; SF = Square Feet

Surveillance conducted by: _____

(print name)

(signature)

I, the LEA's Designated Person, have read and understood the findings noted above: _____

Date: _____

Appendix F

Preventive Measures

Preventive Measures for Various Asbestos-Containing Building Materials

A. Surfacing Materials

“Surfacing Materials” means materials in a school building that are applied by spray, trowel, or otherwise applied to surfaces. These include sprayed-applied fireproofing materials on structural members, ceiling and wall plasters, or other materials applied to surfaces for acoustical, fireproofing, or other purposes.

Surfacing Materials are generally considered friable and can release asbestos fibers if damaged by impact, air erosion, vibration, and/or water intrusion. When properly implemented, the following procedures will reduce the potential for fiber release:

1. Sprayed-Applied Fireproofing

- a) Identify the materials and post warning signs on the laid-in or glued-in ceiling tile. If the decking is not covered, place the sign on the wall.
- b) Maintain the materials in intact state and undamaged condition. During winter, pigeons, squirrels, and other rodents tend to roost in boiler/machine rooms and dislodge sprayed-applied fireproofing on the decking. Prevent such possibilities.
- c) Prevent water leakage. If the material is significantly damaged, removal is the best option. For minor damage, enclosure is a temporary solution. Encapsulation of damaged sprayed-on fireproofing material is not recommended.
- d) Train the custodial people who are responsible for care and maintenance of surfacing materials. Please note that the repair/removal can only be performed by a licensed abatement contractor.

2. Ceiling and Wall Plasters

- a) Identify the materials and post asbestos warning signs.
- b) Maintain the materials in intact state and undamaged condition. Avoid storing/stacking on/near the materials to reduce contact damage.
- c) Prevent water leakage. If the material is significantly damaged, removal is the best option. For minor damage, repair or enclosure is a temporary solution.
- d) Train the custodial people who are responsible for care and maintenance of surfacing materials.

B. Thermal System Insulation (TSI)

“Thermal System Insulation (TSI)” means insulating materials applied to pipes, pipe fittings, boilers, breechings, tanks, ducts, or other components to prevent process heat loss or gain, water condensation, or for other purposes (e.g., fire door insulation core).

TSI are generally considered friable ACBM. This means they can be easily damaged, increasing the potential for fiber release. When properly implemented, the following procedures will reduce the potential for fiber release:

1. Boiler and Breeching Insulation

- a) Identify the locations and label the boiler. Warning signs should be posted outside the boiler room.
- b) Reduce the likelihood of fiber release by ensuring that the insulation is not damaged. Avoid storing/stacking on/near the boiler to reduce contact damage.
- c) Maintain the insulation in intact state and undamaged condition. Repair damaged areas as soon as possible to prevent further deterioration. If repair is not feasible due to extensive damage/deterioration, remove the material.
- d) Train the custodial people who are responsible for care and maintenance of TSI. Please note that the repair/removal can only be performed by a licensed abatement contractor.

2. Pipe, Pipe Fitting, Tank, Duct & Breeching Insulations

- a) Identify the locations and label the materials. Warning signs should be posted outside of rooms that have TSI materials.
- b) Reduce the likelihood of fiber release by ensuring that the materials are not damaged. Avoid storing/stacking near the materials to reduce contact damage.
- c) Maintain all TSI materials in intact state and undamaged condition. Inspect the protective jackets for damage. Repair damaged areas as soon as possible to prevent further deterioration. If repair is not feasible due to extensive damage/deterioration, remove the material.
- d) Train the custodial people who are responsible for care and maintenance of TSI. Please note that the repair/removal can only be performed by a licensed abatement contractor.

C. Miscellaneous Materials

“Miscellaneous Materials” are the other ACBM in a school building that are not categorized as Surfacing Materials or TSI. These include floor tiles, floor tile and carpet mastics, gypsum wallboard and joint compound, ceiling tiles, glue daubs, asbestos cement panels, cove base and associated glue, window/door caulking and glazing compounds, etc. The following maintenance procedures are recommended for these materials:

1. Vinyl Asbestos Floor Tiles (VAT)

Vinyl Asbestos Floor Tiles (VAT) are considered non-friable, however routine maintenance procedures such as spray-buffing, burnishing, wet scrubbing, and stripping can generate asbestos fibers. Following procedures, when properly implemented, will reduce the potential of fiber release:

- a) Do not sand, grind, or abrade the tiles. Stripping of VAT should be done as infrequently as possible. When stripping becomes necessary, follow the appropriate work practices. Never perform dry stripping.
- b) During spray-buffing or burnishing the floor, operate the machine at the lowest workable speed and use the least abrasive pad. Use a wet mop for routine cleaning whenever possible.
- c) Routinely check whether chair and desk glides are in good condition and replace when necessary. Worn glides can gouge the floor and cause fiber release.
- d) Place carpets/floor mats in all entrances to reduce abrasion of floor tiles by sand and pebbles. During winter, have parking lots and walkways swept to the extent possible to avoid the tracking of salt and ice-melting compounds into the school by the students.

- e) Train the custodial people who are responsible for care and maintenance of VAT. Please note that the repair/removal can only be performed by a licensed abatement contractor.
2. Wallboard and Joint Compound Assembly
- a) Since a number of different homogeneous assemblies may exist in a building, sheetrock/joint compound must be assumed to be ACM unless sample results prove otherwise. If any specific areas are going to be disturbed, samples of the material in that area should be collected and analyzed.
 - b) Reduce the likelihood of fiber release by avoiding cutting or drilling holes through the sheetrock panels.
3. Ceiling Tile and Glue Daubs
- a) Reduce the likelihood of fiber release by limiting access to the space above the ceiling tiles. Maintain the ceiling tiles in undamaged condition. Replace any damaged or water-stained tile.
 - b) If the ceiling tiles are non-asbestos, collect samples and analyze the glue daubs to identify asbestos-content before disturbing the tiles.
4. Asbestos Cement Panels, Window/Door Caulking and Glazing Compounds
- a) Maintain asbestos cement panels and window/door caulking and glazing compounds in undamaged condition.
5. Carpet Glue, Blackboard/Tack Board Glue, Floor Tile Mastic, Cove Base, and Mastic
- a) Reduce the likelihood of fiber release by leaving materials in place.
 - b) Maintain materials in good condition. Collect samples and analyze to identify asbestos-content before disturbing.


Appendix G

Asbestos Inspector and Management Planner State Licenses and EPA Accreditations

Dear SANDRA L GUZMAN,

Attached you will find your validated certificate for the coming year. Should you have any questions about your certificate renewal, please do not hesitate to write or call:

Department of Public Health (860) 509-7603
P.O. Box 340308 opic.dph@ct.gov
M.S.#12MQA www.ct.gov/dph/license
Hartford, CT 06134-0308

Sincerely,

MANISHA JUTHANI, MD, COMMISSIONER
DEPARTMENT OF PUBLIC HEALTH

EMPLOYER'S COPY

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

NAME
SANDRA L GUZMAN


VALIDATION NO. 03-138620

CERTIFICATE NO. 000335

CURRENT THROUGH 08/31/25

PROFESSION
ASBESTOS CONSULTANT-INSP/MGMT PLANNER


SIGNATURE


COMMISSIONER

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT
THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A


ASBESTOS CONSULTANT-INSP/MGMT PLANNER


CERTIFICATE NO. 000335

CURRENT THROUGH 08/31/25

VALIDATION NO. 03-138620

SANDRA L GUZMAN


SIGNATURE


COMMISSIONER

INSTRUCTIONS:

1. Detach and sign each of the cards on this form
2. Display the large card in a prominent place in your office or place of business.
3. The wallet card is for you to carry on your person. If you do not wish to carry the wallet card, place it in a secure place.
4. The employer's copy is for persons who must demonstrate current licensure/certification in order to retain employment or privileges. The employer's card is to be presented to the employer and kept by them as a part of your personnel file. Only one copy of this card can be supplied to you.

WALLET CARD

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

NAME
SANDRA L GUZMAN

VALIDATION NO. 03-138620

CERTIFICATE NO. 000335

CURRENT THROUGH 08/31/25

PROFESSION
ASBESTOS CONSULTANT-INSP/MGMT PLANNER


SIGNATURE


COMMISSIONER

New York State Department of Health Certificate of Asbestos Safety Training

This form is the official record of successful completion of a New York State accredited asbestos safety training course.

Certificate No. 954378

I - To be completed by Trainee

Name of Trainee (print) Sandra Guzman NYS Dept. of Motor Vehicles ID (DMV ID)¹ 275 374 644

Signature of Trainee Sandra Guzman

Telephone Number 203-223-7601

Date of Birth¹ 08/05/1976

Address

19 Robertson Road Hamden CT 06518

(City)

(State)

(Zip Code)

II - To be completed by Training Sponsor

Provider's Name

Telephone Number

ATC ATC

Telephone Number 212-353-8280

Address

GROUP SERVICES LLC
104 EAST 25TH STREET, 8TH FL
NEW YORK, NY 10010

Course Location: Online

Zip Code

Course Title: Inspector English Other: Initial Refresher NYS DOH use only DOH Equivalency ²

Training Language: English Other: Exam Grade/Date: 100% / 5/20/24

Dates of Training: From: 5/20/24 To: 5/20/24 Expires: 5/20/25

I certify that the asbestos safety training course given on the above date complied with both 10 NYCRR Part 73 and TSCA Title II, was consistent with the curriculum and instructors approved by the New York State Department of Health, and the trainee receiving this certificate completed the training course and successfully passed the examination.

Training Director²: Sandra Guzman

(Print)

(Signature)

ATC GROUP SERVICES LLC

104 East 25th Street, New York, NY 10010
(212) 353-8280

This certifies that

Sandra Guzman

has successfully completed the

*4-hour EPA-AHERA/ASHARA Training, accredited under TSCA Title II 40 CFR 763,
and the New York State Department of Health Approved Course and Examination for*

Asbestos Management Planner Refresher

on

May 20, 2024

**** Please note that the official record of successful completion is the
DOH 2832 Certificate of Asbestos Safety Training****

Course Location: Online Course

Examination Date: May 20, 2024

Certificate#: NYS - MPR - 2460

Expiration Date: May 20, 2025

Signed:




John P. Springston, CIH, CSP, FAIHA

Dear KATHLEEN C. PANE,

Attached you will find your validated certificate for the coming year. Should you have any questions about your certificate renewal, please do not hesitate to write or call:

Department of Public Health (860) 509-7603
P.O. Box 340308 oplc.dph@ct.gov
M.S.#12MQA www.ct.gov/dph/license
Hartford, CT 06134-0308

Sincerely,

MANISHA JUTHANI, MD, COMMISSIONER
DEPARTMENT OF PUBLIC HEALTH

EMPLOYER'S COPY
STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

NAME
KATHLEEN C. PANE
CURRENT THROUGH
04/30/25

VALIDATION NO.
03-094747
CERTIFICATE NO.
000200

PROFESSION
ASBESTOS CONSULTANT-INSPI/MGMT PLANNER


SIGNATURE
COMMISSIONER

INSTRUCTIONS:
1. Detach and sign each of the cards on this form
2. Display the large card in a prominent place in your office or place of business.
3. The wallet card is for you to carry on your person. If you do not wish to carry the wallet card, place it in a secure place.
4. The employer's copy is for persons who must demonstrate current licensure/certification in order to retain employment or privileges. The employer's card is to be presented to the employer and kept by them as a part of your personnel file. Only one copy of this card can be supplied to you.


STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT
THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A
ASBESTOS CONSULTANT-INSPI/MGMT PLANNER

CERTIFICATE NO.
000200
CURRENT THROUGH
04/30/25

VALIDATION NO.
03-094747

KATHLEEN C. PANE


SIGNATURE
COMMISSIONER

WALLET CARD
STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

NAME
KATHLEEN C. PANE
CURRENT THROUGH
04/30/25

VALIDATION NO.
03-094747
CERTIFICATE NO.
000200

PROFESSION
ASBESTOS CONSULTANT-INSPI/MGMT PLANNER


SIGNATURE
COMMISSIONER

CERT#: A-508-Virtual.677

CHEMSCOPE TRAINING DIVISION
ASBESTOS INSPECTOR/MANAGEMENT PLANNER REFRESHER
8-HOUR TRAINING CERTIFICATE

Kathleen C. Pane

59 Elm Street, Suite 500, New Haven CT

Has attended an 8-hour course on the subject discipline on
01/03/2025 and has passed a written examination.

"The person receiving this certificate has completed the requisite training required for asbestos accreditation as an
Inspector/Management Planner under TSCA Title II"

Course topics include a review and update on asbestos health hazards, functions of inspectors & management planners,
building systems, planning, inspecting for asbestos, sampling & analysis, respiratory protection, government regulations
and preparing the inspection report. The training course has been accredited by the State of Connecticut.

Examination 1 Score: 100%
Examination 2 Score: 100%
Exam Date: 01/03/2025
Expiration Date: 01/03/2026



Daniel Sullivan
Training Manager

Chem Scope, Inc.
15 Moulthrop Street
North Haven CT 06473
Phone: 203.865.5605
www.chem-scope.com