

# Lead in School Drinking Water Report

## Goldendale Primary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-01-23

Date(s) analyzed: 2025-02-12

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	400064	Primary School	Sink	Rm27	1 of 1	Tap	center	10
2	400083	Primary School	Sink	Rm15 Media	1 of 1	Tap	center	6
3	398876	Primary Portables	Fountain/Tap Combo	P-C	1 of 1	Water Fountain	left	4
4	400073	Primary School	Fountain/Tap Combo	Rm12	1 of 1	Water Fountain	right	4
5	397980	Primary School	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	center	2
6	397982	Primary School	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	center	2
7	398878	Primary Portables	Fountain/Tap Combo	P-C	1 of 1	Tap	right	2
8	400065	Primary School	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	2
9	400079	Primary School	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	2
10	398872	Primary School	Fountain/Tap Combo	Rm26	1 of 1	Tap	left	1
11	400067	Primary School	Fountain	Next To Rm12	1 of 1	Water Fountain	center	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	400070	Primary School	Fountain/Tap Combo	Rm2	1 of 1	Tap	left	1
13	400071	Primary School	Fountain/Tap Combo	Rm12	1 of 1	Tap	left	1
14	400072	Primary School	Fountain/Tap Combo	Rm2	1 of 1	Water Fountain	right	1
15	400077	Primary School	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	1
16	400078	Primary School	Fountain/Tap Combo	Rm4	1 of 1	Tap	left	1
17	400082	Primary School	Fountain/Tap Combo	Rm5	1 of 1	Water Fountain	right	1
18	400085	Primary School	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	1
19	400088	Primary School	Fountain/Tap Combo	Rm7	1 of 1	Tap	left	1
20	400092	Primary School	Fountain/Tap Combo	Rm8	1 of 1	Tap	left	1
21	397984	Primary School	Sink	Kitchen	2 of 2	Tap	center	<1
22	398860	Primary School	Fountain/Tap Combo	Rm23	1 of 1	Tap	left	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	398862	Primary School	Fountain/Tap Combo	Rm23	1 of 1	Water Fountain	left	<1
24	398864	Primary School	Fountain/Tap Combo	Rm24	1 of 1	Tap	left	<1
25	398866	Primary School	Fountain/Tap Combo	Rm24	1 of 1	Water Fountain	right	<1
26	398868	Primary School	Fountain/Tap Combo	Rm25	1 of 1	Tap	left	<1
27	398870	Primary School	Fountain/Tap Combo	Rm25	1 of 1	Water Fountain	right	<1
28	398874	Primary School	Fountain/Tap Combo	Rm26	1 of 1	Water Fountain	right	<1
29	400060	Primary School	Fountain	Gym	1 of 2	Water Fountain	right	<1
30	400061	Primary School	Sink	Staff Lounge	1 of 1	Tap	center	<1
31	400062	Primary School	Fountain	Gym	2 of 2	Water Fountain	right	<1
32	400063	Primary School	Sink	Nurses Office	1 of 1	Tap	center	<1
33	400066	Primary School	Fountain with Bottle Filler	Across From Rm18 Hallway	1 of 1	Water Bottle Filler	center	<1
34	400068	Primary School	Fountain with Bottle Filler	Across From Rm18 Hallway	1 of 1	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
35	400069	Primary School	Fountain/Tap Combo	Rm11	1 of 1	Tap	left	<1
36	400074	Primary School	Fountain/Tap Combo	Rm3	1 of 1	Tap	left	<1
37	400075	Primary School	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	<1
38	400076	Primary School	Fountain/Tap Combo	Rm3	1 of 1	Water Fountain	right	<1
39	400080	Primary School	Fountain/Tap Combo	Rm5	1 of 1	Tap	left	<1
40	400081	Primary School	Fountain/Tap Combo	Rm14	1 of 1	Water Fountain	right	<1
41	400084	Primary School	Fountain/Tap Combo	Rm6	1 of 1	Tap	left	<1
42	400086	Primary School	Fountain/Tap Combo	Rm6	1 of 1	Water Fountain	right	<1
43	400087	Primary School	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	<1
44	400089	Primary School	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	<1
45	400090	Primary School	Fountain/Tap Combo	Rm7	1 of 1	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
46	400091	Primary School	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	<1
47	400093	Primary School	Fountain/Tap Combo	Rm21	1 of 1	Tap	left	<1
48	400094	Primary School	Fountain/Tap Combo	Rm8	1 of 1	Water Bottle Filler	right	<1
49	400095	Primary School	Fountain/Tap Combo	Rm21	1 of 1	Water Fountain	right	<1
50	400096	Primary School	Fountain/Tap Combo	Rm9	1 of 1	Tap	left	<1
51	400097	Primary School	Fountain/Tap Combo	Rm22	1 of 1	Tap	left	<1
52	400098	Primary School	Fountain/Tap Combo	Rm9	1 of 1	Water Fountain	right	<1
53	400099	Primary School	Fountain/Tap Combo	Rm22	1 of 1	Water Fountain	right	<1