

Lead in School Drinking Water Report

Goldendale Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-01-24

Date(s) analyzed: 2025-01-28, 2025-02-13, 2025-02-18, 2025-02-19

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	398112	Goldendale Middle School	Sink	Student Store	1 of 1	Tap	center	202
2	398123	Goldendale Middle School	Fountain/Tap Combo	Rm6	1 of 1	Water Fountain	right	46
3	398030	Goldendale Middle School	Sink	Counselor Office	1 of 1	Tap	center	32
4	398106	Goldendale Middle School	Sink	Rm18	1 of 3	Tap	center	32
5	398026	Goldendale Middle School	Fountain/Tap Combo	Art Room	1 of 1	Tap	left	23
6	398116	Goldendale Middle School	Fountain/Tap Combo	Rm17	1 of 1	Tap	left	19
7	398108	Goldendale Middle School	Sink	Rm18	2 of 3	Tap	center	15
8	398132	Goldendale Middle School	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	14
9	398137	Goldendale Middle School	Fountain/Tap Combo	Rm2	1 of 1	Tap	left	13
10	398102	Goldendale Middle School	Sink - Multi-Compartment	Rm19	1 of 1	Tap	center	12

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	398136	Goldendale Middle School	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	12
12	398105	Goldendale Middle School	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	11
13	398032	Goldendale Middle School	Sink	Office	1 of 1	Tap	center	10
14	398109	Goldendale Middle School	Fountain/Tap Combo	Rm9	1 of 1	Tap	left	10
15	398124	Goldendale Middle School	Fountain/Tap Combo	Rm16	1 of 1	Tap	left	10
16	398110	Goldendale Middle School	Sink	Rm18	3 of 3	Tap	center	7
17	398020	Goldendale Middle School	Pot Filler	Kitchen	1 of 2	Tap	center	6
18	398028	Goldendale Middle School	Fountain/Tap Combo	Art Room	1 of 1	Water Fountain	right	6
19	398128	Goldendale Middle School	Fountain/Tap Combo	Rm15	1 of 1	Tap	left	6
20	398113	Goldendale Middle School	Fountain/Tap Combo	Rm8	1 of 1	Tap	left	5
21	398117	Goldendale Middle School	Fountain/Tap Combo	Rm7	1 of 1	Tap	left	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	398125	Goldendale Middle School	Fountain/Tap Combo	Rm5	1 of 1	Tap	left	5
23	398129	Goldendale Middle School	Fountain/Tap Combo	Rm4	1 of 1	Tap	left	5
24	398022	Goldendale Middle School	Fountain/Tap Combo	Rm1	1 of 1	Tap	left	3
25	398133	Goldendale Middle School	Fountain/Tap Combo	Rm3	1 of 1	Tap	left	3
26	398139	Goldendale Middle School	Fountain/Tap Combo	Rm2	1 of 1	Water Fountain	right	3
27	398024	Goldendale Middle School	Fountain/Tap Combo	Rm1	1 of 1	Water Fountain	right	2
28	398104	Goldendale Middle School	Sink	Staff Workroom	1 of 1	Tap	center	2
29	398107	Goldendale Middle School	Fountain/Tap Combo	Rm10	1 of 1	Water Fountain	right	2
30	398111	Goldendale Middle School	Fountain/Tap Combo	Rm9	1 of 1	Water Fountain	right	2
31	398114	Goldendale Middle School	Fountain	Gym	1 of 2	Water Fountain	center	2
32	398118	Goldendale Middle School	Fountain/Tap Combo	Rm17	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	398121	Goldendale Middle School	Fountain/Tap Combo	Rm6	1 of 1	Tap	left	2
34	398100	Goldendale Middle School	Sink - Multi-Compartment	Kitchen	2 of 2	Tap	center	1
35	398115	Goldendale Middle School	Fountain/Tap Combo	Rm8	1 of 1	Water Fountain	right	1
36	398119	Goldendale Middle School	Fountain/Tap Combo	Rm7	1 of 1	Water Fountain	right	1
37	398120	Goldendale Middle School	Fountain with Bottle Filler	7th/8th Hallway	1 of 1	Water Bottle Filler	center	1
38	398126	Goldendale Middle School	Fountain/Tap Combo	Rm16	1 of 1	Water Fountain	right	1
39	398127	Goldendale Middle School	Fountain/Tap Combo	Rm5	1 of 1	Water Fountain	right	1
40	398130	Goldendale Middle School	Fountain/Tap Combo	Rm15	1 of 1	Water Fountain	right	1
41	398131	Goldendale Middle School	Fountain/Tap Combo	Rm4	1 of 1	Water Fountain	right	1
42	398134	Goldendale Middle School	Fountain/Tap Combo	Rm14	1 of 1	Water Fountain	right	1
43	398135	Goldendale Middle School	Fountain/Tap Combo	Rm3	1 of 1	Water Fountain	right	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	398138	Goldendale Middle School	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	1
45	398101	Goldendale Middle School	Fountain with Bottle Filler	5th/6th Hallway	1 of 1	Water Bottle Filler	center	<1
46	398103	Goldendale Middle School	Fountain with Bottle Filler	5th/6th Hallway	1 of 1	Water Fountain	right	<1
47	398122	Goldendale Middle School	Fountain with Bottle Filler	7th/8th Hallway	1 of 1	Water Fountain	right	<1