

Lead in School Drinking Water Report

Goldendale High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-01-22

Date(s) analyzed: 2025-02-07, 2025-02-13

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	398972	Goldendale High School	Sink	Rm113	1 of 1	Tap	center	168
2	398259	Goldendale High School	Sink	Principal Office	1 of 1	Tap	center	70
3	398245	Goldendale High School	Sink	Rm318	1 of 4	Tap	right	54
4	398237	Goldendale High School	Sink	Rm311	4 of 7	Tap	center	51
5	398229	CTE Building	Sink	Rm104 Backroom	1 of 1	Tap	center	40
6	398234	Goldendale High School	Sink	Rm229	1 of 1	Tap	center	38
7	398249	Goldendale High School	Sink	Rm318	3 of 4	Tap	right	37
8	398230	Goldendale High School	Sink	Music Room Storage	1 of 1	Tap	center	30
9	398239	Goldendale High School	Sink - Multi-Compartment	Rm311	5 of 7	Tap	center	30
10	398225	CTE Building	Fountain/Tap Combo	Rm123	1 of 1	Water Fountain	right	23

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	398241	Goldendale High School	Sink - Multi-Compartment	Rm311	6 of 7	Tap	center	23
12	398233	Goldendale High School	Sink - Multi-Compartment	Rm311	2 of 7	Tap	center	21
13	398223	CTE Building	Fountain/Tap Combo	Rm123	1 of 1	Tap	left	18
14	398231	Goldendale High School	Sink - Multi-Compartment	Rm311	1 of 7	Tap	center	18
15	398253	Goldendale High School	Sink	Rm319	1 of 1	Tap	center	18
16	398255	Goldendale High School	Sink	Rm319	1 of 1	Sprayer	right	14
17	398235	Goldendale High School	Sink - Multi-Compartment	Rm311	3 of 7	Tap	center	12
18	398250	Goldendale High School	Sink - Multi-Compartment	Kitchen	1 of 1	Tap	center	12
19	398224	Goldendale High School	Fountain	Main Gym	1 of 2	Water Fountain	center	10
20	398247	Goldendale High School	Sink	Rm318	2 of 4	Tap	right	10
21	398968	Goldendale High School	Sink	Nurses Office	1 of 1	Tap	center	10

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	398221	CTE Building	Fountain/Tap Combo	Rm125(Fountainoff)	1 of 1	Tap	right	7
23	398232	Goldendale High School	Sink	Concession	1 of 1	Tap	center	6
24	398243	Goldendale High School	Sink - Multi-Compartment	Rm311	7 of 7	Tap	center	6
25	398226	Goldendale High School	Fountain	Main Gym	2 of 2	Water Fountain	center	5
26	398246	Goldendale High School	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	5
27	398256	Goldendale High School	Sink	Rm312	2 of 2	Tap	center	5
28	398227	CTE Building	Sink	Rm101	1 of 1	Tap	center	4
29	398228	Goldendale High School	Fountain	Music Rm230	1 of 1	Water Fountain	center	4
30	398248	Goldendale High School	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	4
31	398257	Goldendale High School	Sink	Staff Lounge	1 of 1	Tap	center	4
32	398970	Goldendale High School	Fountain	Library	1 of 1	Water Fountain	center	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	398251	Goldendale High School	Sink	Rm318	4 of 4	Tap	center	3
34	398254	Goldendale High School	Fountain	Rm312	1 of 2	Water Fountain	center	3
35	398252	Goldendale High School	Sink - Multi-Compartment	Kitchen	1 of 1	Sprayer	center	2
36	398220	Goldendale High School	Fountain with Bottle Filler	Foyer Bathroom	1 of 1	Water Bottle Filler	center	<1
37	398222	Goldendale High School	Fountain with Bottle Filler	Foyer Bathroom	1 of 1	Water Fountain	right	<1
38	398236	Goldendale High School	Fountain with Bottle Filler	Next To Janitors Closet	1 of 1	Water Bottle Filler	center	<1
39	398238	Goldendale High School	Fountain with Bottle Filler	Next To Janitors Closet	1 of 1	Water Fountain	right	<1
40	398240	Goldendale High School	Water Bottle Filling Station	Next To Faculty	1 of 1	Water Bottle Filler	center	<1
41	398242	Goldendale High School	Fountain with Bottle Filler	Near Boiler Room	1 of 1	Water Bottle Filler	center	<1
42	398244	Goldendale High School	Fountain with Bottle Filler	Near Boiler Room	1 of 1	Water Fountain	right	<1
43	398258	CTE Building	Fountain	Hallway	1 of 1	Water Fountain	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	398974	Goldendale High School	Ice Machine	Ice Room	1 of 1	Other	center	<1