

Adopted [Click here to enter date (Month DD, YYYY)]

Updated [Click here to enter date (Month DD, YYYY)]

Goldendale Primary School Action Plan: Lead in Drinking Water

School Information

School Name(s): Primary School

School District: Goldendale School District

County: Klickitat

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Primary School	1/23/2025	3/8/2025	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

Primary School – Goldendale School District has identified 2 drinking water outlets with elevated lead levels requiring mitigation.

Mitigation measures have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	1/23/2025	400064	Goldendale SD Primary School	Sink – Rm 27 (Tap)	10	Hand Washing Only signs installed <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	3/10/2025
2)	1/23/2025	40083	Goldendale SD Primary School	Sink – Rm 15 Media (Tap)	6	Hand Washing Only signs installed <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	3/10/2025

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

Primary School – Goldendale SD has identified 2 drinking water outlets with elevated lead levels requiring remediation. Hand Washing Only signs were posted on the two sinks that tested over 5 ppb. We plan on replacing these two faucets with certified lead-free faucets by Mid – April 2025

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	1/23/2025	400064	Goldendale SD Primary School	Sink – Rm 27 (Tap)	10	Faucets scheduled to be replaced with certified lead-free faucets by Mid-April 2025	Mid - April
2)	1/23/2025	400083	Goldendale SD Primary School	Sink – Rm 15 (Tap)	6	Faucets scheduled to be replaced with certified lead-free faucets by Mid- April 2025	Mid-April

Post-Remediation Testing

School Name	Completed Post-Remediation Testing	Planned Post-Remediation Testing
Primary School	Zero outlets have been sampled and retested by: <input type="checkbox"/> DOH <input type="checkbox"/> a contractor Sampling date: [Click here to enter date]	Two outlets will be sampled and retested by: <input type="checkbox"/> DOH <input checked="" type="checkbox"/> a contractor <input type="checkbox"/> TBD Sampling is scheduled for: [Click here to enter date]

Communication Plan

Primary School Goldendale SD will communicate information about the plan for remedial action to reduce lead concentrations in drinking water through Public Comments time in an open Board Meeting, along with all information related to these tests being posted on the Districts website. Board meeting to take place in April. Documents will be posted March of 2025. This information will be communicated annually until post-remediation retesting does not detect an elevated lead level (above 5 ppb) at any drinking water outlet.

Contact Information

The following person(s) is the main point of contact for more information related to this action plan.

Name: Dean M. Schlenker, Business and Operations Manager or Dr. Ellen Perconti, Superintendent

Role: Superintendent and Business and Operations Manager

Email: dean.schlenker@gsd404.org, ellen.perconti@gsd404.org

Phone: 509-773-5177

Preferred contact method: ☒ Email ☐ Phone