

ADDENDUM #1

SAN DIEGO COUNTY SUPERINTENDENT OF SCHOOLS CAMP PALOMAR POOL DEMOLITION PROJECT

April 3, 2025

Addendum documentation:	1 Page(s)
8 1/2" x 11" Addendum Drawings	0 Drawing(s)
30" x 42" Addendum Sheet Drawings	0 Sheets
Specification Sections	0 Drawing

The following is issued to supplement or revise the Contract Documents. The revisions to the documents are described below. Unless specifically changed by this addendum, the remainder of the drawings, documents and specifications shall remain in effect as originally issued.

GENERAL:

1. **Bid Date/Time Change:** No Change Bid Date and Time. Bid Date and Time is **Tuesday, April 8, 2025 at 3:00 pm.**
2. **Questions from Bidders:**
 1. Are we replacing just one side of the guardrail where it collapsed or on both sides of the road? Is the replacement guardrail to match the existing wood guardrail? **Response: Yes, contractor is just replacing the collapsed guardrail. Yes, the replacement guardrail is to match the existing wood guardrail.**
 2. Please clarify the scope of asphalt repair required. Is the damaged asphalt road area to be removed and regraded to receive new asphalt per county standards? What is the estimated affected area (sf) and required repair specification? **Response: The asphalt road area is not to be removed and regraded to receive new asphalt. The expectation is to install the new guardrail with new concrete footings, patching the asphalt as needed around the new guardrail installation along the edge of the road.**
3. **General Note:** You may acquire the bid documents in any manner desired. It is the **SOLE** responsibility of the bidder to verify that all addenda have been received and considered, and that all addenda are being used at the time of the bid.

End of Addendum # 1